1104

154116

CALLED CALSPAN FRIDAY 7-23-76 GAVE THE FOLLOWING INFORMATION TO MIKE WILKINSON

IRON TANK FLOW
MON → FRI 48,000 GPD
SAT. SUN. 10,000 GPD

ANODE FICE SCRUBBER WATER DISCHARGE FROM RECYCLE TANK
APPROX. 144,000 GPD 5.5 days / wk

BILLET REVERB. SCRUBBER WATER DISCHARGE
APPROX. 72,000 GPD 5.5 days/wk

FRIDAY 8-6-76
MIKE WILKINSON OF CALSPAN CALLED AND REQUESTED INFORMATION ON THE FOLLOWING —
1. BLDG 19 COOLING TOWER OVERFLOW TO SEWER – 50 GPM (8HRS/DAY) HE WAS ALSO INFORMED OF OUR PLANS TO CLOSE THIS SYSTEM BY PUMPING THE WATER TO THE No. 6 A.P. UNIT
2. ANODE COOLING FLOW TO POND — 850 GPM (6HRS/DAY)

C03511