157424

# PCB LEAK INSPECTIONS

| DATE | ITEMS | RESULT |
|---|---|---|
| 6/20/83 | 3 Transformers in 107 & 101 | No leaks noted |
| | Heat Transfer System Unit 275 | " " " |
| 2/9/84 | 3 Transformers in 107 & 101 | leaks not detected |