EPA Region 5 Records Ctr.
312151

Station 1 Summer Well Analysis Summary
2007

		WELL	1-1	1-2	1-3	1-4	1-5	1-6
	Methods	SAMPLE DATE	9/18/2007	9/18/2007	9/18/2007	9/18/2007	9/18/2007	9/18/2007
		SAMPLER	DH/BOD	DH/BOD	DH/BOD	DH/BOD	DH/BOD	DH/BOD
pH	EPA 150.1	(pH units)	6.9	6.7	6.8	6.8	6.7	6.7
Temperature	EPA 170.1	(deg C)	12.9	12.7	12.9	12.3	11.8	11.6
Temperature	EPA 170.1	(deg F)	55.22	54.86	55.22	54.14	53.24	52.88
Ammonia Nitrogen	EPA 350.2,3	(mg/L)	0.05	0.06	0.04	0.08	0.04	0.05
Ortho Phosphorus	EPA 365.1	(mg/L)	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
Chloride	SM 4500-CL-	(mg/L)	109.9	131.87	104.4	123.63	63.19	85.17
Fluoride	EPA 340.2	(mg/L)	0.104	0.107	0.117	0.098	0.093	0.105
Total Hardness	EPA 130.2	(grains/gal)	23	24	23	22	22	22
Total Hardness	EPA 130.2	(mg/L CaCO3)	393.3	410.4	393.3	376.2	376.2	376.2
Alkalinity	EPA 310.1	(mg/L)	293.9	300.2	306.4	289.8	279.4	285.7
Conductivity	EPA 120.1	(umhos/cm)	985	1087	978	1008	797	894
Total Dissolved Solids	EPA 160.1	(mg/L)	569	620	567	584	447	515
Dissolved Oxygen	EPA 360.1	(mg/L)	2.7	2.7	2.8	2.2	2.5	2.9
Nitrate Nitrogen*	EPA 353.2	(mg/L)	<0.1	<0.1	0.3	0.7	0.6	0.8
Nitrite Nitrogen*	EPA 353.2	(mg/L)	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
Sulfate*	EPA 300.0A	(mg/L)	40	45	47	39	35	38
Antimony*	EPA 200.8	(ug/L)	<5	<5	<5	<5	<5	38
Arsenic*	EPA 200.8	(ug/L)	<1	<1	<1	<1	<1	<1
Beryllium*	EPA 200.8	(ug/L)	<1	<1	<1	<1	<1	<1
Cadmium*	EPA 200.8	(ug/L)	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2
Calcium*	EPA 200.7	(ug/L)	100000	106000	104000	104000	92600	94400
Chromium, Total*	EPA 200.8	(ug/L)	<10	<10	<10	<10	<10	<10
Cobalt*	EPA 200.8	(ug/L)	<20	<20	<20	<20	<20	<20
Copper*	EPA 200.8	(ug/L)	<20	<20	<20	<20	<20	<20
Iron*	EPA 200.7	(ug/L)	20	940	10	250	310	250
Lead*	EPA 200.8	(ug/L)	<3	<3	<3	<3	<3	<3
Magnesium*	EPA 200.7	(ug/L)	35000	36700	32100	34000	30700	32500
Manganese*	EPA 200.8	(ug/L)	106	140	96	73	69	49
Nickel*	EPA 200.8	(ug/L)	<20	<20	<20	<20	<20	<20
Potassium*	EPA 200.7	(ug/L)	2200	2800	2900	2500	2000	2000
Selenium*	EPA 200.8	(ug/L)	<5	<5	<5	<5	<5	<5
Silver*	EPA 200.8	(ug/L)	<5	<5	<5	<5	<5	<5
Sodium*	EPA 200.7	(ug/L)	61000	78400	59500	67500	37300	48500
Thallium*	EPA 200.8	(ug/L)	<2	<2	<2	<2	<2	<2
Zinc*	EPA 200.8	(ug/L)	<20	<20	<20	<20	<20	<20
Silicate*	SM 4500-SI E	(mg/L)	13.1	13.4	13.5	13.2	13	13.3

*These analyses are performed at Kar Laboratories of Kalamazoo. Other analyses are performed by the Environmental Services Laboratory.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *072291*

Date Reported : *06/18/07*

Project Desc. : *Analysis of 13 drinking water samples.*

Sample ID : *"07-155, 1-3"*

Sampled By : *TW of KWRP*

Sample Date : *6/4/2007*

Sample Time : *1240*

Date Received : *6/5/2007*

Sample Type : *SDWA*

KAR Sample No. : *072291-03*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/12/07	KTL	
Prep, VOA	Completed		EPA 524.2	06/12/07	KTL	
1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
1,1-Trichloroethane	0.6	ug/L	EPA 524.2	06/12/07	KTL	MCL*=200 ug/L
1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=5 ug/L
1-Dichloroethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=7 ug/L
1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=70 ug/L
2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=0.2 ug/L
2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=600 ug/L
2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=5 ug/L
2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=5 ug/L
3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Benzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Bromoform	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Bromomethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Chloroform	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Chloromethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Cis-1,2-Dichloroethene	1.1	ug/L	EPA 524.2	06/12/07	KTL	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *072291*

Date Reported : *06/18/07*

Project Desc. : *Analysis of 13 drinking water samples.*

Sample ID : *"07-155, 1-3"*

Sampled By : *TW of KWRP*

Sample Date : *6/4/2007*

Sample Time : *1240*

Date Received : *6/5/2007*

Sample Type : *SDWA*

KAR Sample No. : *072291-03*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
M-and/or p-xylene	<1	ug/L	EPA 524.2	06/12/07	KTL	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Naphthalene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
O-Xylene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Styrene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Tetrachloroethene	5.6	ug/L	EPA 524.2	06/12/07	KTL	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Trichloroethene	1.2	ug/L	EPA 524.2	06/12/07	KTL	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=2 ug/L

* MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *072291*

Date Reported : *06/18/07*

Project Desc. : *Analysis of 13 drinking water samples.*

Sample ID : *"07-155, 1-4"*

Sampled By : *TW of KWRP*

Sample Date : *6/4/2007*

Sample Time : *1245*

Date Received : *6/5/2007*

Sample Type : *SDWA*

KAR Sample No. : *072291-04*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/12/07	KTL	
Prep, VOA	Completed		EPA 524.2	06/12/07	KTL	
1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=200 ug/L
1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=5 ug/L
1-Dichloroethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=7 ug/L
1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=70 ug/L
2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=0.2 ug/L
2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=600 ug/L
2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=5 ug/L
2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=5 ug/L
3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Benzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Bromoform	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Bromomethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Chloroform	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Chloromethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Cis-1,2-Dichloroethene	1.8	ug/L	EPA 524.2	06/12/07	KTL	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *072291*

Date Reported : *06/18/07*

Project Desc. : *Analysis of 13 drinking water samples.*

Sample ID : *"07-155, 1-4"*

Sampled By : *TW of KWRP*

Sample Date : *6/4/2007*

Sample Time : *1245*

Date Received : *6/5/2007*

Sample Type : *SDWA*

KAR Sample No. : *072291-04*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
M-and/or p-xylene	<1	ug/L	EPA 524.2	06/12/07	KTL	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Naphthalene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
O-Xylene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Styrene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Tetrachloroethene	1.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Trichloroethene	1.1	ug/L	EPA 524.2	06/12/07	KTL	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *072291*
Date Reported : *06/18/07*

Project Desc. : *Analysis of 13 drinking water samples.*

Sample ID : *"07-155, 1-6"*
Sampled By : *TW of KWRP*
Sample Date : *6/4/2007*
Sample Time : *1250*

Date Received : *6/5/2007*
Sample Type : *SDWA*
KAR Sample No. : *072291-05*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/12/07	KTL	
Prep, VOA	Completed		EPA 524.2	06/12/07	KTL	
1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=200 ug/L
1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=5 ug/L
1-Dichloroethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=7 ug/L
1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=70 ug/L
2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=0.2 ug/L
2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=600 ug/L
2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=5 ug/L
2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=5 ug/L
3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=75 [5] ug/L
2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Benzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Bromoform	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Bromomethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Chloroform	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Chloromethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Cis-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *072291*

Date Reported : *06/18/07*

Project Desc. : *Analysis of 13 drinking water samples.*

Sample ID : *"07-155, 1-6"*

Sampled By : *TW of KWRP*

Sample Date : *6/4/2007*

Sample Time : *1250*

Date Received : *6/5/2007*

Sample Type : *SDWA*

KAR Sample No. : *072291-05*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	0.8	ug/L	EPA 524.2	06/12/07	KTL	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
M-and/or p-xylene	<1	ug/L	EPA 524.2	06/12/07	KTL	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Naphthalene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
O-Xylene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Styrene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Tetrachloroethene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Trichloroethene	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/12/07	KTL	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/12/07	KTL	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *072424*

Date Reported : *06/29/07*

Project Desc. : *Analysis of 16 drinking water samples.*

Sample ID : *"Central Station, Station 1, 07-163"*

Sampled By : *JH of KWRP*

Sample Date : *6/12/2007*

Sample Time : *1020*

Date Received : *6/12/2007*

Sample Type : *SDWA*

KAR Sample No. : *072424-01*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, metals	Completed		EPA 30xx,200.x	06/15/07	PML	
Antimony, total, low level	<0.005	mg/L	EPA 200.8	06/25/07	PML	MCL*=0.006 mg/L
Arsenic, total, low level	<0.001	mg/L	EPA 200.8	06/26/07	PML	MCL*=0.01 mg/L
Beryllium, total, low level	<0.001	mg/L	EPA 200.8	06/25/07	PML	MCL*=0.004 mg/L
Cadmium, total, low level	<0.0002	mg/L	EPA 200.8	06/25/07	PML	MCL*=0.005 mg/L
Calcium, total	100	mg/L	EPA 200.7	06/18/07	DBL	
Chromium, total	<0.01	mg/L	EPA 200.8	06/25/07	PML	MCL*=0.1 mg/L
Cobalt, total	<0.02	mg/L	EPA 200.8	06/25/07	PML	
Copper, total	<0.02	mg/L	EPA 200.8	06/25/07	PML	MCL*=1.3 mg/L
Iron, total	<0.01	mg/L	EPA 200.7	06/18/07	DBL	MCL*=[0.3 mg/L]
Lead, total	<0.003	mg/L	EPA 200.8	06/25/07	PML	MCL*=0.015 mg/L
Magnesium, total	31.8	mg/L	EPA 200.7	06/18/07	DBL	
Manganese, total	<0.005	mg/L	EPA 200.8	06/26/07	PML	MCL*=[0.05 mg/L]
Nickel, total	<0.02	mg/L	EPA 200.8	06/25/07	PML	MCL*=0.1 mg/L
Potassium, total	2.4	mg/L	EPA 200.7	06/18/07	DBL	
Selenium, total	<0.005	mg/L	EPA 200.8	06/25/07	PML	MCL*=0.05 mg/L
Silver, total	<0.005	mg/L	EPA 200.8	06/25/07	PML	MCL*=[0.1 mg/L]
Sodium, total	56.8	mg/L	EPA 200.7	06/21/07	DBL	MCL*=[20 mg/L]
Thallium, total, low level	<0.002	mg/L	EPA 200.8	06/25/07	PML	MCL*=0.002 mg/L
Zinc, total	<0.02	mg/L	EPA 200.8	06/25/07	PML	MCL*=[5 mg/L]
Fluoride	0.07	mg/L	EPA 300.0A	06/14/07	MTW	MCL*=4 mg/L
Nitrogen, nitrate	0.5	mg/L	EPA 353.2	06/13/07	MTW	MCL*=10 mg/L
Nitrogen, nitrite	<0.1	mg/L	EPA 353.2	06/13/07	MTW	MCL*=1 mg/L
Silica	13.2	mg/L	SM 4500-Si E	06/20/07	DMC	Result represents molybdate-reactive silica only.
Sulfate	41	mg/L	EPA 300.0A	06/14/07	MTW	MCL*=[250 mg/L]
Regulated/Unregulated VOC's	See below		EPA 524.2	06/20/07	JAR	
Prep, VOA	Completed		EPA 524.2	06/20/07	JAR	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
1,1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	06/20/07	JAR	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/20/07	JAR	MCL*=5 ug/L
1,1-Dichloroethane	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/20/07	JAR	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	MCL*=600 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *072424*

Date Reported : *06/29/07*

Project Desc. : *Analysis of 16 drinking water samples.*

Sample ID : *"Central Station, Station 1, 07-163"*

Sampled By : *JH of KWRP*

Sample Date : *6/12/2007*

Sample Time : *1020*

Date Received : *6/12/2007*

Sample Type : *SDWA*

KAR Sample No. : *072424-01*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/20/07	JAR	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/20/07	JAR	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
Benzene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
Bromodichloromethane	0.9	ug/L	EPA 524.2	06/20/07	JAR	
Bromoform	0.5	ug/L	EPA 524.2	06/20/07	JAR	
Bromomethane	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/20/07	JAR	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
Chloroform	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
Chloromethane	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
Cis-1,2-Dichloroethene	0.7	ug/L	EPA 524.2	06/20/07	JAR	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
Dibromochloromethane	1.1	ug/L	EPA 524.2	06/20/07	JAR	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/20/07	JAR	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
M and/or p-xylene	<1	ug/L	EPA 524.2	06/20/07	JAR	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/20/07	JAR	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
Naphthalene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
O-Xylene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
Styrene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *072424*

Date Reported : *06/29/07*

Project Desc. : *Analysis of 16 drinking water samples.*

Sample ID : *"Central Station, Station 1, 07-163"*

Sampled By : *JH of KWRP*

Sample Date : *6/12/2007*

Sample Time : *1020*

Date Received : *6/12/2007*

Sample Type : *SDWA*

KAR Sample No. : *072424-01*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Tetrachloroethene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
Trichloroethene	<0.5	ug/L	EPA 524.2	06/20/07	JAR	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/20/07	JAR	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/20/07	JAR	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *073914*

Date Reported : *10/01/07*

Project Desc. : *Analysis of 11 drinking water samples.*

Sample ID : *"07-261-1-1"*

Sampled By : *BOD of KWRP*

Sample Date : *09/18/07*

Sample Time : *1120*

Date Received : *09/19/07*

Sample Type : *SDWA*

KAR Sample No. : *073914-06*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, metals	Completed		EPA 30xx,200.x	09/24/07	DBL	
Antimony, total, low level	<0.005	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.006 mg/L
Arsenic, total, low level	<0.001	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.01 mg/L
Beryllium, total, low level	<0.001	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.004 mg/L
Cadmium, total, low level	<0.0002	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.005 mg/L
Calcium, total	100	mg/L	EPA 200.7	09/26/07	DBL	
Chromium, total	<0.01	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.1 mg/L
Cobalt, total	<0.02	mg/L	EPA 200.8	09/25/07	PML	
Copper, total	<0.02	mg/L	EPA 200.8	09/25/07	PML	MCL*=1.3 mg/L
Iron, total	0.02	mg/L	EPA 200.7	09/26/07	DBL	MCL*=[0.3 mg/L]
Lead, total	<0.003	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.015 mg/L
Magnesium, total	35.0	mg/L	EPA 200.7	09/26/07	DBL	
Manganese, total	0.106	mg/L	EPA 200.8	09/25/07	PML	MCL*=[0.05 mg/L]
Nickel, total	<0.02	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.1 mg/L
Potassium, total	2.2	mg/L	EPA 200.7	09/27/07	DBL	
Selenium, total	<0.005	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.05 mg/L
Silver, total	<0.005	mg/L	EPA 200.8	09/25/07	PML	MCL*=[0.1 mg/L]
Sodium, total	61.0	mg/L	EPA 200.7	09/26/07	DBL	MCL*=[20 mg/L]
Thallium, total, low level	<0.002	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.002 mg/L
Zinc, total	<0.02	mg/L	EPA 200.8	09/25/07	PML	MCL*=[5 mg/L]
Nitrogen, nitrate	<0.1	mg/L	EPA 353.2	09/19/07	DRA	MCL*=10 mg/L
Nitrogen, nitrite	<0.1	mg/L	EPA 353.2	09/19/07	DRA	MCL*=1 mg/L
Silica	13.1	mg/L	SM 4500-SI E	09/27/07	DMC	Result represents molybdate-reactive silica only.
Sulfate	40	mg/L	EPA 300.0A	09/20/07	DMC	MCL*=[250 mg/L]
Regulated/Unregulated VOC's	See below		EPA 524.2	09/24/07	JAR	
Prep, VOA	Completed		EPA 524.2	09/24/07	JAR	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
1,1-Dichloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *073914*

Date Reported : *10/01/07*

Project Desc. : *Analysis of 11 drinking water samples.*

Sample ID : *"07-261-1-1"*

Sampled By : *BOD of KWRP*

Sample Date : *09/18/07*

Sample Time : *1120*

Date Received : *09/19/07*

Sample Type : *SDWA*

KAR Sample No. : *073914-06*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Benzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Bromochloromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Bromoform	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Bromomethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Chloroform	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Chloromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Cis-1,2-Dichloroethene	1.2	ug/L	EPA 524.2	09/24/07	JAR	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Dibromochloromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Dibromomethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Ethylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
M-and/or p-xylene	<1	ug/L	EPA 524.2	09/24/07	JAR	
Methylene chloride	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Naphthalene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
O-Xylene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Styrene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Tetrachloroethene	2.4	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *073914*

Date Reported : *10/01/07*

Project Desc. : *Analysis of 11 drinking water samples.*

Sample ID : *"07-261-1-1"*

Sampled By : *BOD of KWRP*

Sample Date : *09/18/07*

Sample Time : *1120*

Date Received : *09/19/07*

Sample Type : *SDWA*

KAR Sample No. : *073914-06*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Toluene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Trichloroethene	1.1	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Vinyl chloride	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *073914*

Date Reported : *10/01/07*

Project Desc. : *Analysis of 11 drinking water samples.*

Sample ID : *"07-261-1-2"*

Sampled By : *BOD of KWRP*

Sample Date : *09/18/07*

Sample Time : *0826*

Date Received : *09/19/07*

Sample Type : *SDWA*

KAR Sample No. : *073914-07*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, metals	Completed		EPA 30xx,200.x	09/24/07	DBL	
Antimony, total, low level	<0.005	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.006 mg/L
Arsenic, total, low level	<0.001	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.01 mg/L
Beryllium, total, low level	<0.001	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.004 mg/L
Cadmium, total, low level	<0.0002	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.005 mg/L
Calcium, total	106	mg/L	EPA 200.7	09/26/07	DBL	
Chromium, total	<0.01	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.1 mg/L
Cobalt, total	<0.02	mg/L	EPA 200.8	09/25/07	PML	
Copper, total	<0.02	mg/L	EPA 200.8	09/25/07	PML	MCL*=1.3 mg/L
Iron, total	0.94	mg/L	EPA 200.7	09/26/07	DBL	MCL*=[0.3 mg/L]
Lead, total	<0.003	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.015 mg/L
Magnesium, total	36.7	mg/L	EPA 200.7	09/26/07	DBL	
Manganese, total	0.140	mg/L	EPA 200.8	09/25/07	PML	MCL*=[0.05 mg/L]
Nickel, total	<0.02	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.1 mg/L
Potassium, total	2.8	mg/L	EPA 200.7	09/27/07	DBL	
Selenium, total	<0.005	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.05 mg/L
Silver, total	<0.005	mg/L	EPA 200.8	09/25/07	PML	MCL*=[0.1 mg/L]
Sodium, total	78.4	mg/L	EPA 200.7	09/26/07	DBL	MCL*=[20 mg/L]
Thallium, total, low level	<0.002	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.002 mg/L
Zinc, total	<0.02	mg/L	EPA 200.8	09/25/07	PML	MCL*=[5 mg/L]
Nitrogen, nitrate	<0.1	mg/L	EPA 353.2	09/19/07	DRA	MCL*=10 mg/L
Nitrogen, nitrite	<0.1	mg/L	EPA 353.2	09/19/07	DRA	MCL*=1 mg/L
Silica	13.4	mg/L	SM 4500-Si E	09/27/07	DMC	Result represents molybdate-reactive silica only.
Sulfate	45	mg/L	EPA 300.0A	09/20/07	DMC	MCL*=[250 mg/L]
Regulated/Unregulated VOC's	See below		EPA 524.2	09/24/07	JAR	
Prep, VOA	Completed		EPA 524.2	09/24/07	JAR	
1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=200 ug/L
1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
1,1-Dichloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=600 ug/L
1,2-Dichloromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *073914*

Date Reported : *10/01/07*

Project Desc. : *Analysis of 11 drinking water samples.*

Sample ID : *"07-261-1-2"*

Sampled By : *BOD of KWRP*

Sample Date : *09/18/07*

Sample Time : *0826*

Date Received : *09/19/07*

Sample Type : *SDWA*

KAR Sample No. : *073914-07*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Benzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Bromochloromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Bromoform	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Bromomethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Chloroform	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Chloromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Cis-1,2-Dichloroethene	8.2	ug/L	EPA 524.2	09/24/07	JAR	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Dibromochloromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Dibromomethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Ethylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
M-and/or p-xylene	<1	ug/L	EPA 524.2	09/24/07	JAR	
Methylene chloride	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Naphthalene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
O-Xylene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Styrene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Tetrachloroethene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *073914*

Date Reported : *10/01/07*

Project Desc. : *Analysis of 11 drinking water samples.*

Sample ID : *"07-261-1-2"*

Sampled By : *BOD of KWRP*

Sample Date : *09/18/07*

Sample Time : *0826*

Date Received : *09/19/07*

Sample Type : *SDWA*

KAR Sample No. : *073914-07*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Toluene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Trichloroethene	3.0	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Vinyl chloride	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *073914*

Date Reported : *10/01/07*

Project Desc. : *Analysis of 11 drinking water samples.*

Sample ID : *"07-261-1-3"*

Sampled By : *BOD of KWRP*

Sample Date : *09/18/07*

Sample Time : *0820*

Date Received : *09/19/07*

Sample Type : *SDWA*

KAR Sample No. : *073914-08*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, metals	Completed		EPA 30xx,200.x	09/24/07	DBL	
Antimony, total, low level	<0.005	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.006 mg/L
Arsenic, total, low level	<0.001	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.01 mg/L
Beryllium, total, low level	<0.001	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.004 mg/L
Cadmium, total, low level	<0.0002	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.005 mg/L
Calcium, total	104	mg/L	EPA 200.7	09/26/07	DBL	
Chromium, total	<0.01	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.1 mg/L
Cobalt, total	<0.02	mg/L	EPA 200.8	09/25/07	PML	
Copper, total	<0.02	mg/L	EPA 200.8	09/25/07	PML	MCL*=1.3 mg/L
Iron, total	0.01	mg/L	EPA 200.7	09/26/07	DBL	MCL*=[0.3 mg/L]
Lead, total	<0.003	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.015 mg/L
Magnesium, total	32.1	mg/L	EPA 200.7	09/26/07	DBL	
Manganese, total	0.096	mg/L	EPA 200.8	09/25/07	PML	MCL*=[0.05 mg/L]
Nickel, total	<0.02	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.1 mg/L
Potassium, total	2.9	mg/L	EPA 200.7	09/27/07	DBL	
Selenium, total	<0.005	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.05 mg/L
Silver, total	<0.005	mg/L	EPA 200.8	09/25/07	PML	MCL*=[0.1 mg/L]
Sodium, total	59.5	mg/L	EPA 200.7	09/26/07	DBL	MCL*=[20 mg/L]
Thallium, total, low level	<0.002	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.002 mg/L
Zinc, total	<0.02	mg/L	EPA 200.8	09/25/07	PML	MCL*=[5 mg/L]
Nitrogen, nitrate	0.3	mg/L	EPA 353.2	09/19/07	DRA	MCL*=10 mg/L
Nitrogen, nitrite	<0.1	mg/L	EPA 353.2	09/19/07	DRA	MCL*=1 mg/L
Silica	13.5	mg/L	SM 4500-Si E	09/27/07	DMC	Result represents molybdate-reactive silica only.
Sulfate	47	mg/L	EPA 300.0A	09/20/07	DMC	MCL*=[250 mg/L]
Regulated/Unregulated VOC's	See below		EPA 524.2	09/24/07	JAR	
Prep, VOA	Completed		EPA 524.2	09/24/07	JAR	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,1,1-Trichloroethane	0.7	ug/L	EPA 524.2	09/24/07	JAR	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
1,1-Dichloroethane	0.6	ug/L	EPA 524.2	09/24/07	JAR	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *073914*

Date Reported : *10/01/07*

Project Desc. : *Analysis of 11 drinking water samples.*

Sample ID : *"07-261-1-3"*

Sampled By : *BOD of KWRP*

Sample Date : *09/18/07*

Sample Time : *0820*

Date Received : *09/19/07*

Sample Type : *SDWA*

KAR Sample No. : *073914-08*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Benzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Bromochloromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Bromoform	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Bromomethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Chloroform	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Chloromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Cis-1,2-Dichloroethene	0.8	ug/L	EPA 524.2	09/24/07	JAR	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Dibromochloromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Dibromomethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Ethylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
m-and/or p-xylene	<1	ug/L	EPA 524.2	09/24/07	JAR	
Methylene chloride	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Naphthalene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
O-Xylene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Styrene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Tetrachloroethene	3.7	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *073914*

Date Reported : *10/01/07*

Project Desc. : *Analysis of 11 drinking water samples.*

Sample ID : *"07-261-1-3"*

Sampled By : *BOD of KWRP*

Sample Date : *09/18/07*

Sample Time : *0820*

Date Received : *09/19/07*

Sample Type : *SDWA*

KAR Sample No. : *073914-08*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Toluene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Trichloroethene	1.2	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Vinyl chloride	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *073914*

Date Reported : *10/01/07*

Project Desc. : *Analysis of 11 drinking water samples.*

Sample ID : *"07-261-1-4"*

Sampled By : *BOD of KWRP*

Sample Date : *09/18/07*

Sample Time : *0840*

Date Received : *09/19/07*

Sample Type : *SDWA*

KAR Sample No. : *073914-09*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, metals	Completed		EPA 30xx,200.x	09/24/07	DBL	
Antimony, total, low level	<0.005	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.006 mg/L
Arsenic, total, low level	<0.001	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.01 mg/L
Beryllium, total, low level	<0.001	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.004 mg/L
Cadmium, total, low level	<0.0002	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.005 mg/L
Calcium, total	104	mg/L	EPA 200.7	09/26/07	DBL	
Chromium, total	<0.01	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.1 mg/L
Cobalt, total	<0.02	mg/L	EPA 200.8	09/25/07	PML	
Copper, total	<0.02	mg/L	EPA 200.8	09/25/07	PML	MCL*=1.3 mg/L
Iron, total	0.25	mg/L	EPA 200.7	09/26/07	DBL	MCL*=[0.3 mg/L]
Lead, total	<0.003	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.015 mg/L
Magnesium, total	34.0	mg/L	EPA 200.7	09/26/07	DBL	
Manganese, total	0.073	mg/L	EPA 200.8	09/25/07	PML	MCL*=[0.05 mg/L]
Nickel, total	<0.02	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.1 mg/L
Potassium, total	2.5	mg/L	EPA 200.7	09/27/07	DBL	
Selenium, total	<0.005	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.05 mg/L
Silver, total	<0.005	mg/L	EPA 200.8	09/25/07	PML	MCL*=[0.1 mg/L]
Sodium, total	67.5	mg/L	EPA 200.7	09/26/07	DBL	MCL*=[20 mg/L]
Thallium, total, low level	<0.002	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.002 mg/L
Zinc, total	<0.02	mg/L	EPA 200.8	09/25/07	PML	MCL*=[5 mg/L]
Nitrogen, nitrate	0.7	mg/L	EPA 353.2	09/19/07	DRA	MCL*=10 mg/L
Nitrogen, nitrite	<0.1	mg/L	EPA 353.2	09/19/07	DRA	MCL*=1 mg/L
Silica	13.2	mg/L	SM 4500-Si E	09/27/07	DMC	Result represents molybdate-reactive silica only.
Sulfate	39	mg/L	EPA 300.0A	09/20/07	DMC	MCL*=[250 mg/L]
Regulated/Unregulated VOC's	See below		EPA 524.2	09/24/07	JAR	
Prep, VOA	Completed		EPA 524.2	09/24/07	JAR	
1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=200 ug/L
1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
1-Dichloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1-Dichloroethene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=7 ug/L
1-Dichloropropene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=70 ug/L
2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=0.2 ug/L
2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=600 ug/L
2-Dichloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *073914*

Date Reported : *10/01/07*

Project Desc. : *Analysis of 11 drinking water samples.*

Sample ID : *"07-261-1-4"*

Sampled By : *BOD of KWRP*

Sample Date : *09/18/07*

Sample Time : *0840*

Date Received : *09/19/07*

Sample Type : *SDWA*

KAR Sample No. : *073914-09*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Benzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Bromochloromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Bromoform	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Bromomethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Chloroform	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Chloromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Cis-1,2-Dichloroethene	1.7	ug/L	EPA 524.2	09/24/07	JAR	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Dibromochloromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Dibromomethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Ethylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
M-and/or p-xylene	<1	ug/L	EPA 524.2	09/24/07	JAR	
Methylene chloride	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Naphthalene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
O-Xylene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Styrene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Tetrachloroethene	1.0	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *073914*

Date Reported : *10/01/07*

Project Desc. : *Analysis of 11 drinking water samples.*

Sample ID : *"07-261-1-4"*

Sampled By : *BOD of KWRP*

Sample Date : *09/18/07*

Sample Time : *0840*

Date Received : *09/19/07*

Sample Type : *SDWA*

KAR Sample No. : *073914-09*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Toluene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Trichloroethene	1.1	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Vinyl chloride	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *073914*

Date Reported : *10/01/07*

Project Desc. : *Analysis of 11 drinking water samples.*

Sample ID : *"07-261-1-5"*

Sampled By : *BOD of KWRP*

Sample Date : *09/18/07*

Sample Time : *0905*

Date Received : *09/19/07*

Sample Type : *SDWA*

KAR Sample No. : *073914-10*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, metals	Completed		EPA 30xx,200.x	09/24/07	DBL	
Antimony, total, low level	<0.005	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.006 mg/L
Arsenic, total, low level	<0.001	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.01 mg/L
Beryllium, total, low level	<0.001	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.004 mg/L
Cadmium, total, low level	<0.0002	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.005 mg/L
Calcium, total	92.6	mg/L	EPA 200.7	09/26/07	DBL	
Chromium, total	<0.01	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.1 mg/L
Cobalt, total	<0.02	mg/L	EPA 200.8	09/25/07	PML	
Copper, total	<0.02	mg/L	EPA 200.8	09/25/07	PML	MCL*=1.3 mg/L
Iron, total	0.31	mg/L	EPA 200.7	09/26/07	DBL	MCL*=[0.3 mg/L]
Lead, total	<0.003	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.015 mg/L
Magnesium, total	30.7	mg/L	EPA 200.7	09/26/07	DBL	
Manganese, total	0.069	mg/L	EPA 200.8	09/25/07	PML	MCL*=[0.05 mg/L]
Nickel, total	<0.02	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.1 mg/L
Potassium, total	2.0	mg/L	EPA 200.7	09/27/07	DBL	
Selenium, total	<0.005	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.05 mg/L
Silver, total	<0.005	mg/L	EPA 200.8	09/25/07	PML	MCL*=[0.1 mg/L]
Sodium, total	37.3	mg/L	EPA 200.7	09/26/07	DBL	MCL*=[20 mg/L]
Thallium, total, low level	<0.002	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.002 mg/L
Zinc, total	<0.02	mg/L	EPA 200.8	09/25/07	PML	MCL*=[5 mg/L]
Nitrogen, nitrate	0.6	mg/L	EPA 353.2	09/19/07	DRA	MCL*=10 mg/L
Nitrogen, nitrite	<0.1	mg/L	EPA 353.2	09/19/07	DRA	MCL*=1 mg/L
Silica	13.0	mg/L	SM 4500-Si E	09/27/07	DMC	Result represents molybdate-reactive silica only.
Sulfate	35	mg/L	EPA 300.0A	09/20/07	DMC	MCL*=[250 mg/L]
Regulated/Unregulated VOC's	See below		EPA 524.2	09/24/07	JAR	
Prep, VOA	Completed		EPA 524.2	09/24/07	JAR	
1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=200 ug/L
1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
1-Dichloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1-Dichloroethene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=7 ug/L
1-Dichloropropene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=70 ug/L
2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=0.2 ug/L
2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=600 ug/L
2-Dichloromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *073914*

Date Reported : *10/01/07*

Project Desc. : *Analysis of 11 drinking water samples.*

Sample ID : *"07-261-1-5"*

Sampled By : *BOD of KWRP*

Sample Date : *09/18/07*

Sample Time : *0905*

Date Received : *09/19/07*

Sample Type : *SDWA*

KAR Sample No. : *073914-10*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Benzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Bromochloromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Bromoform	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Bromomethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Chloroform	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Chloromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Cis-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Dibromochloromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Dibromomethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Ethylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
M-and/or p-xylene	<1	ug/L	EPA 524.2	09/24/07	JAR	
Methylene chloride	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Naphthalene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
O-Xylene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Styrene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Tetrachloroethene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *073914*

Date Reported : *10/01/07*

Project Desc. : *Analysis of 11 drinking water samples.*

Sample ID : *"07-261-1-5"*
Sampled By : *BOD of KWRP*
Sample Date : *09/18/07*
Sample Time : *0905*

Date Received : *09/19/07*
Sample Type : *SDWA*
KAR Sample No. : *073914-10*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Toluene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Trichloroethene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Vinyl chloride	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *073914*

Date Reported : *10/01/07*

Project Desc. : *Analysis of 11 drinking water samples.*

Sample ID : *"07-261-1-6"*

Sampled By : *BOD of KWRP*

Sample Date : *09/18/07*

Sample Time : *0855*

Date Received : *09/19/07*

Sample Type : *SDWA*

KAR Sample No. : *073914-11*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, metals	Completed		EPA 30xx,200.x	09/24/07	DBL	
Antimony, total, low level	<0.005	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.006 mg/L
Arsenic, total, low level	<0.001	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.01 mg/L
Beryllium, total, low level	<0.001	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.004 mg/L
Cadmium, total, low level	<0.0002	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.005 mg/L
Calcium, total	94.4	mg/L	EPA 200.7	09/26/07	DBL	
Chromium, total	<0.01	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.1 mg/L
Cobalt, total	<0.02	mg/L	EPA 200.8	09/25/07	PML	
Copper, total	<0.02	mg/L	EPA 200.8	09/25/07	PML	MCL*=1.3 mg/L
Iron, total	0.25	mg/L	EPA 200.7	09/26/07	DBL	MCL*=[0.3 mg/L]
Lead, total	<0.003	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.015 mg/L
Magnesium, total	32.5	mg/L	EPA 200.7	09/26/07	DBL	
Manganese, total	0.049	mg/L	EPA 200.8	09/25/07	PML	MCL*=[0.05 mg/L]
Nickel, total	<0.02	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.1 mg/L
Potassium, total	2.0	mg/L	EPA 200.7	09/27/07	DBL	
Selenium, total	<0.005	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.05 mg/L
Silver, total	<0.005	mg/L	EPA 200.8	09/25/07	PML	MCL*=[0.1 mg/L]
Sodium, total	48.5	mg/L	EPA 200.7	09/26/07	DBL	MCL*=[20 mg/L]
Thallium, total, low level	<0.002	mg/L	EPA 200.8	09/25/07	PML	MCL*=0.002 mg/L
Zinc, total	<0.02	mg/L	EPA 200.8	09/25/07	PML	MCL*=[5 mg/L]
Nitrogen, nitrate	0.8	mg/L	EPA 353.2	09/19/07	DRA	MCL*=10 mg/L
Nitrogen, nitrite	<0.1	mg/L	EPA 353.2	09/19/07	DRA	MCL*=1 mg/L
Silica	13.3	mg/L	SM 4500-Si E	09/27/07	DMC	Result represents molybdate-reactive silica only.
Sulfate	38	mg/L	EPA 300.0A	09/20/07	DMC	MCL*=[250 mg/L]
Regulated/Unregulated VOC's	See below		EPA 524.2	09/24/07	JAR	
Prep, VOA	Completed		EPA 524.2	09/24/07	JAR	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
1,1-Dichloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *073914*

Date Reported : *10/01/07*

Project Desc. : *Analysis of 11 drinking water samples.*

Sample ID : *"07-261-1-6"*

Sampled By : *BOD of KWRP*

Sample Date : *09/18/07*

Sample Time : *0855*

Date Received : *09/19/07*

Sample Type : *SDWA*

KAR Sample No. : *073914-11*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Benzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Bromochloromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Bromoform	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Bromomethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Chloroform	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Chloromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Cis-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Dibromochloromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Dibromomethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Ethylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
M-and/or p-xylene	<1	ug/L	EPA 524.2	09/24/07	JAR	
Methylene chloride	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Naphthalene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
O-Xylene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Styrene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Tetrachloroethene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *073914*

Date Reported : *10/01/07*

Project Desc. : *Analysis of 11 drinking water samples.*

Sample ID : *"07-261-1-6"*

Sampled By : *BOD of KWRP*

Sample Date : *09/18/07*

Sample Time : *0855*

Date Received : *09/19/07*

Sample Type : *SDWA*

KAR Sample No. : *073914-11*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Toluene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Trichloroethene	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	09/24/07	JAR	
Vinyl chloride	<0.5	ug/L	EPA 524.2	09/24/07	JAR	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
DRINKING WATER LABORATORY
USEPA Region V Drinking Water Cert. No. MI00003
P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Sample Number
LA94909

Official Laboratory Report

Report To: CITY OF KALAMAZOO- SUE FOUNE
1415 NORTH HARRISON ST
KALAMAZOO MI 49007

System Name/Owner:	CITY OF KALAMAZOO	WSSN/Pool ID:	03520
Collection Address:	215 W. STOCKBRIDGE,KALAMAZOO	Source:	TYPE I
Collected By:	JIM HOYT	Site Code:	C001 CENTRAL
Township/Well#/Section:	//	Collector:	Other
County:	Kalamazoo	Date Collected:	06/27/2006 08:17
Sample Point:	STD SAMPLE PT	Date Received:	06/28/2006 16:17
Water System:	Treated Public Distribution System	Purpose:	Routine Monitoring

TESTING INFORMATION			REGULATORY INFORMATION			
Analyte Name	Result (mg/L)	Date Tested	RL (mg/L)	MCL/AL (mg/L)	Method	CAS #
Chloride	112	06/29/2006	4		SM 4500-Cl E	7647-14-5
Fluoride	1.0	06/29/2006	0.1	4.0	SM 4500 FC	16984-48-8
Hardness as CaCO3	370	06/29/2006	20		SM 2340 C	HARD-00-C
Iron (automated)	Not detected	06/29/2006	0.1		SM 3500 FeB	7439-89-6
Nitrate as N	0.4	06/29/2006	0.4	10	SM 4500 NO3H	14797-55-8
Nitrite as N	Not detected	06/29/2006	0.05	1	SM 4500 NO3H	14797-65-0
Sodium (automated)	56	06/29/2006	5		SM 3500 NaB	7440-23-5
Sulfate	40	06/29/2006	10		SM 4500 SO4E	14808-79-8
Carbamates by HPLC						
3 Hydroxycarbofuran	Not Detected	07/05/2006	0.001		EPA 531.2	16655-82-6
Aldicarb	Not Detected	07/05/2006	0.001		EPA 531.2	116-06-3
Aldicarb sulfone	Not Detected	07/05/2006	0.001		EPA 531.2	1646-88-4
Aldicarb sulfoxide	Not Detected	07/05/2006	0.001		EPA 531.2	1646-87-3
Carbaryl	Not Detected	07/05/2006	0.001		EPA 531.2	63-25-2
Carbofuran	Not Detected	07/05/2006	0.001	0.04	EPA 531.2	1563-66-2
Methiocarb	Not Detected	07/05/2006	0.001		EPA 531.2	2032-65-7
Methomyl	Not Detected	07/05/2006	0.001		EPA 531.2	16752-77-5
Oxamyl	Not Detected	07/05/2006	0.001	0.2	EPA 531.2	23135-22-0
Propoxur	Not Detected	07/05/2006	0.001		EPA 531.2	114-26-1
Chlorinated Acid Herbicides						
2,4,5-T	Not Detected	07/05/2006	0.002		EPA 515.2	93-76-5
2,4,5-TP (silvex)	Not Detected	07/05/2006	0.0003	0.05	EPA 515.2	93-72-1
2,4-D	Not Detected	07/05/2006	0.002	0.07	EPA 515.2	94-75-7

CAS# : Chemical Abstract Service Registry Number
MCL : Maximum Contaminent Level
AL : Action Level
RL : Reporting Limit

mg/L : milligrams / Liter (ppm)
ppm : parts per million
MPN : Most Probable Number
CFU : Colony Forming Unit

Laboratory Contacts
Drinking Water Unit Mgr: Sandy Kerns
Systems Mgmt. Unit Mgr: George Krisztian

MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
DRINKING WATER LABORATORY
USEPA Region V Drinking Water Cert. No. MI00003
P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Sample Number
LA94909

TESTING INFORMATION			REGULATORY INFORMATION			
Analyte Name	Result (mg/L)	Date Tested	RL (mg/L)	MCL/AL (mg/L)	Method	CAS #
Chlorinated Acid Herbicides						
Acifluorfen	Not Detected	07/05/2006	0.004		EPA 515.2	50594-66-6
Bentazon	Not Detected	07/05/2006	0.002		EPA 515.2	25057-89-0
DCPA, mono	Not Detected	07/05/2006	0.001		EPA 515.2	887-54-7
Dicamba	Not Detected	07/05/2006	0.002		EPA 515.2	1918-00-9
Dinoseb	Not Detected	07/05/2006	0.0003	0.007	EPA 515.2	88-85-7
Pentachlorophenol	Not Detected	07/05/2006	0.00006	0.001	EPA 515.2	87-86-5
Picloram	Not Detected	07/05/2006	0.002	0.5	EPA 515.2	1918-02-1
Pesticides Analysis by GC/MS						
4,4'-DDD	Not Detected	07/19/2006	0.001		EPA 525.2	72-54-8
4,4'-DDE	Not Detected	07/19/2006	0.001		EPA 525.2	72-55-9
4,4'-DDT	Not Detected	07/19/2006	0.001		EPA 525.2	50-29-3
Acetochlor	Not Detected	07/19/2006	0.001		EPA 525.2	34256-82-1
Alachlor	Not Detected	07/19/2006	0.0002	0.002	EPA 525.2	15972-60-8
Aldrin	Not Detected	07/19/2006	0.0004		EPA 525.2	309-00-2
alpha-Chlordane	Not Detected	07/19/2006	0.0002	0.002	EPA 525.2	5103-71-9
alpha-Endosulfan	Not Detected	07/19/2006	0.001		EPA 525.2	959-98-8
Ametryn	Not Detected	07/19/2006	0.001		EPA 525.2	834-12-8
Atrazine	Not Detected	07/19/2006	0.0002	0.003	EPA 525.2	1912-24-9
beta-Endosulfan	Not Detected	07/19/2006	0.001		EPA 525.2	33213-65-9
Bromacil	Not Detected	07/19/2006	0.002		EPA 525.2	314-40-9
Butachlor	Not Detected	07/19/2006	0.002		EPA 525.2	23184-66-9
Butylate	Not Detected	07/19/2006	0.002		EPA 525.2	2008-41-5
Carboxin	Not Detected	07/19/2006	0.002		EPA 525.2	5234-68-4
Chlorothalonil	Not Detected	07/19/2006	0.001		EPA 525.2	1897-45-6
Cycloate	Not Detected	07/19/2006	0.002		EPA 525.2	1134-23-2
Cyprazine	Not Detected	07/19/2006	0.001		EPA 525.2	22936-86-3
Dieldrin	Not Detected	07/19/2006	0.0005		EPA 525.2	60-57-1
Diphenamid	Not Detected	07/19/2006	0.001		EPA 525.2	957-51-7
Endrin	Not Detected	07/19/2006	0.00005	0.002	EPA 525.2	72-20-8
Endrin aldehyde	Not Detected	07/19/2006	0.002		EPA 525.2	7421-93-4
EPTC	Not Detected	07/19/2006	0.001		EPA 525.2	759-94-4
gamma-Chlordane	Not Detected	07/19/2006	0.0002	0.002	EPA 525.2	5103-74-2
Heptachlor	Not Detected	07/19/2006	0.00008	0.0004	EPA 525.2	76-44-8
Heptachlor epoxide	Not Detected	07/19/2006	0.00004	0.0002	EPA 525.2	1024-57-3
Hexachlorobenzene	Not Detected	07/19/2006	0.0001	0.001	EPA 525.2	118-74-1
Hexachlorocyclohexane (alpha-BHC)	Not Detected	07/19/2006	0.001		EPA 525.2	319-84-6
Hexachlorocyclohexane (beta-BHC)	Not Detected	07/19/2006	0.001		EPA 525.2	319-85-7
Hexachlorocyclohexane (delta-BHC)	Not Detected	07/19/2006	0.001		EPA 525.2	319-86-8

CAS# : Chemical Abstract Service Registry Number
MCL : Maximum Contaminent Level
AL : Action Level
RL : Reporting Limit

mg/L : milligrams / Liter (ppm)
ppm : parts per million
MPN : Most Probable Number
CFU : Colony Forming Unit

Laboratory Contacts
Drinking Water Unit Mgr: Sandy Kerns
Systems Mgmt. Unit Mgr: George Krisztian

MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
DRINKING WATER LABORATORY
USEPA Region V Drinking Water Cert. No. MI00003
P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Sample Number
LA94909

TESTING INFORMATION			REGULATORY INFORMATION			
Analyte Name	Result (mg/L)	Date Tested	RL (mg/L)	MCL/AL (mg/L)	Method	CAS #
Pesticides Analysis by GC/MS						
Hexachlorocyclopentadiene	Not Detected	07/19/2006	0.0002	0.05	EPA 525.2	77-47-4
Hexazinone	Not Detected	07/19/2006	0.003		EPA 525.2	51235-04-2
Lindane (gamma-BHC)	Not Detected	07/19/2006	0.00004	0.0002	EPA 525.2	58-89-9
Methoxychlor	Not Detected	07/19/2006	0.0002	0.04	EPA 525.2	72-43-5
Metolachlor	Not Detected	07/19/2006	0.001		EPA 525.2	51218-45-2
Metribuzin	Not Detected	07/19/2006	0.001		EPA 525.2	21087-64-9
Molinate	Not Detected	07/19/2006	0.002		EPA 525.2	2212-67-1
Octachlorocyclopentene	Not Detected	07/19/2006	0.002		EPA 525.2	706-78-5
PCB (aroclor 1016)	Not Detected	07/19/2006	0.0002	0.0005	EPA 525.2	12674-11-2
PCB (aroclor 1221)	Not Detected	07/19/2006	0.0002	0.0005	EPA 525.2	11104-28-2
PCB (aroclor 1232)	Not Detected	07/19/2006	0.0002	0.0005	EPA 525.2	11141-16-5
PCB (aroclor 1242)	Not Detected	07/19/2006	0.0002	0.0005	EPA 525.2	53469-21-9
PCB (aroclor 1248)	Not Detected	07/19/2006	0.0002	0.0005	EPA 525.2	12672-29-6
PCB (aroclor 1254)	Not Detected	07/19/2006	0.0002	0.0005	EPA 525.2	11097-69-1
PCB (aroclor 1260)	Not Detected	07/19/2006	0.0002	0.0005	EPA 525.2	11096-82-5
Polybrominated biphenyls	Not Detected	07/19/2006	0.001		EPA 525.2	59536-65-1
Prometon	Not Detected	07/19/2006	0.001		EPA 525.2	1610-18-0
Pronamide	Not Detected	07/19/2006	0.001		EPA 525.2	23950-58-5
Propachlor	Not Detected	07/19/2006	0.001		EPA 525.2	1918-16-7
Propazine	Not Detected	07/19/2006	0.001		EPA 525.2	139-40-2
Simazine	Not Detected	07/19/2006	0.0002	0.004	EPA 525.2	122-34-9
Tebuthiuron	Not Detected	07/19/2006	0.005		EPA 525.2	34014-18-1
Terbacil	Not Detected	07/19/2006	0.002		EPA 525.2	5902-51-2
Toxaphene	Not Detected	07/19/2006	0.002	0.003	EPA 525.2	8001-35-2
Trifluralin	Not Detected	07/19/2006	0.001		EPA 525.2	1582-09-8

The analyses performed by the MDEQ Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below:

Kalamazoo County Human Services Dept.
3299 Gull Rd.
Nazareth, MI 49048
269 373-5200

CAS# : Chemical Abstract Service Registry Number
MCL : Maximum Contaminent Level
AL : Action Level
RL : Reporting Limit

mg/L : milligrams / Liter (ppm)
ppm : parts per million
MPN : Most Probable Number
CFU : Colony Forming Unit

Laboratory Contacts
Drinking Water Unit Mgr: Sandy Kerns
Systems Mgmt. Unit Mgr: George Krisztian

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *062504*

Date Reported : *06/26/06*

Project Desc. : *Analysis of 14 drinking water samples.*

Sample ID : *"06-163-1-3"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/12/2006*

Sample Time : *1315*

Date Received : *6/13/2006*

Sample Type : *SDWA*

KAR Sample No. : *062504-03*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/19/06	JAR	
Prep, VOA	Completed		EPA 524.2	06/19/06	JAR	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,1,1-Trichloroethane	0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=5 ug/L
1,1-Dichloroethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Benzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Bromoform	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Bromomethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Chloroform	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Chloromethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Cis-1,2-Dichloroethene	1.2	ug/L	EPA 524.2	06/19/06	JAR	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *062504*

Date Reported : *06/26/06*

Project Desc. : *Analysis of 14 drinking water samples.*

Sample ID : *"06-163-1-3"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/12/2006*

Sample Time : *1315*

Date Received : *6/13/2006*

Sample Type : *SDWA*

KAR Sample No. : *062504-03*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
M-and/or p-xylene	<1	ug/L	EPA 524.2	06/19/06	JAR	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Naphthalene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
O-Xylene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Styrene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Tetrachloroethene	5.4	ug/L	EPA 524.2	06/19/06	JAR	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Trichloroethene	0.8	ug/L	EPA 524.2	06/19/06	JAR	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *062504*

Date Reported : *06/26/06*

Project Desc. : *Analysis of 14 drinking water samples.*

Sample ID : *"06-163-1-4"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/12/2006*

Sample Time : *1325*

Date Received : *6/13/2006*

Sample Type : *SDWA*

KAR Sample No. : *062504-04*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/19/06	JAR	
Prep. VOA	Completed		EPA 524.2	06/19/06	JAR	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=5 ug/L
1,1-Dichloroethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Benzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Bromoform	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Bromomethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Chloroform	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Chloromethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Cis-1,2-Dichloroethene	1.0	ug/L	EPA 524.2	06/19/06	JAR	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *062504*
Date Reported : *06/26/06*

Project Desc. : *Analysis of 14 drinking water samples.*

Sample ID : *"06-163-1-4"*
Sampled By : *RDLS of KWRP*
Sample Date : *6/12/2006*
Sample Time : *1325*

Date Received : *6/13/2006*
Sample Type : *SDWA*
KAR Sample No. : *062504-04*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
M-and/or p-xylene	<1	ug/L	EPA 524.2	06/19/06	JAR	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Naphthalene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
O-Xylene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Styrene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Tetrachloroethene	1.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Trichloroethene	0.7	ug/L	EPA 524.2	06/19/06	JAR	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *062504*
Date Reported : *06/26/06*

Project Desc. : *Analysis of 14 drinking water samples.*

Sample ID : *"06-163-1-6"*
Sampled By : *RDLS of KWRP*
Sample Date : *6/12/2006*
Sample Time : *1335*

Date Received : *6/13/2006*
Sample Type : *SDWA*
KAR Sample No. : *062504-05*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/19/06	JAR	
Prep, VOA	Completed		EPA 524.2	06/19/06	JAR	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=5 ug/L
1,1-Dichloroethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Benzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Bromoform	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Bromomethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Chloroform	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Chloromethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Cis-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *062504*
Date Reported : *06/26/06*

Project Desc. : *Analysis of 14 drinking water samples.*

Sample ID : *"06-163-1-6"*
Sampled By : *RDLS of KWRP*
Sample Date : *6/12/2006*
Sample Time : *1335*

Date Received : *6/13/2006*
Sample Type : *SDWA*
KAR Sample No. : *062504-05*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
M-and/or p-xylene	<1	ug/L	EPA 524.2	06/19/06	JAR	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Naphthalene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
O-Xylene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Styrene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Tetrachloroethene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Trichloroethene	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/19/06	JAR	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/19/06	JAR	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *052925*
Date Reported : *07/05/05*

Project Desc. : *Analysis of 17 drinking water samples.*

Sample ID : *"05-178, Station 1-1"*
Sampled By : *TW of KWRP*
Sample Date : *6/27/2005*
Sample Time : *1317*

Date Received : *6/28/2005*
Sample Type : *SDWA*
KAR Sample No. : *052925-03*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/30/05	JAR	
Prep. VOA	Completed		EPA 524.2	06/30/05	JAR	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
1,1-Dichloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Benzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Bromoform	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Bromomethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Chloroform	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Chloromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Cis-1,2-Dichloroethene	2.2	ug/L	EPA 524.2	06/30/05	JAR	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *052925*

Date Reported : *07/05/05*

Project Desc. : *Analysis of 17 drinking water samples.*

Sample ID : *"05-178, Station 1-1"*

Sampled By : *TW of KWRP*

Sample Date : *6/27/2005*

Sample Time : *1317*

Date Received : *6/28/2005*

Sample Type : *SDWA*

KAR Sample No. : *052925-03*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
M-and/or p-xylene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Naphthalene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
O-Xylene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Styrene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Tetrachloroethene	3.8	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Trichloroethene	1.4	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *052925*

Date Reported : *07/05/05*

Project Desc. : *Analysis of 17 drinking water samples.*

Sample ID : *"05-175, Station 1-2"*

Sampled By : *ROD of KWRP*

Sample Date : *6/24/2005*

Sample Time : *1338*

Date Received : *6/28/2005*

Sample Type : *SDWA*

KAR Sample No. : *052925-04*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/30/05	JAR	
Prep, VOA	Completed		EPA 524.2	06/30/05	JAR	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
1,1-Dichloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Benzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Bromoform	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Bromomethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Chloroform	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Chloromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Cis-1,2-Dichloroethene	8.3	ug/L	EPA 524.2	06/30/05	JAR	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *052925*

Date Reported : *07/05/05*

Project Desc. : *Analysis of 17 drinking water samples.*

Sample ID : *"05-175, Station 1-2"*

Sampled By : *ROD of KWRP*

Sample Date : *6/24/2005*

Sample Time : *1338*

Date Received : *6/28/2005*

Sample Type : *SDWA*

KAR Sample No. : *052925-04*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
M-and/or p-xylene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Naphthalene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
O-Xylene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Styrene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Tetrachloroethene	1.2	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Trichloroethene	3.6	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *052925*

Date Reported : *07/05/05*

Project Desc. : *Analysis of 17 drinking water samples.*

Sample ID : *"05-175, Station 1-3"*

Sampled By : *ROD of KWRP*

Sample Date : *6/24/2005*

Sample Time : *1333*

Date Received : *6/28/2005*

Sample Type : *SDWA*

KAR Sample No. : *052925-05*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/30/05	JAR	
Prep, VOA	Completed		EPA 524.2	06/30/05	JAR	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,1,1-Trichloroethane	1.1	ug/L	EPA 524.2	06/30/05	JAR	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
1,1-Dichloroethane	0.8	ug/L	EPA 524.2	06/30/05	JAR	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Benzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Bromoform	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Bromomethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Chloroform	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Chloromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Cis-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *052925*

Date Reported : *07/05/05*

Project Desc. : *Analysis of 17 drinking water samples.*

Sample ID : *"05-175, Station 1-3"*

Sampled By : *ROD of KWRP*

Sample Date : *6/24/2005*

Sample Time : *1333*

Date Received : *6/28/2005*

Sample Type : *SDWA*

KAR Sample No. : *052925-05*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
M-and/or p-xylene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Naphthalene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
O-Xylene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Styrene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Tetrachloroethene	5.0	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Trichloroethene	1.2	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *052925*

Date Reported : *07/05/05*

Project Desc. : *Analysis of 17 drinking water samples.*

Sample ID : *"05-175, Station 1-4"*

Sampled By : *ROD of KWRP*

Sample Date : *6/24/2005*

Sample Time : *1330*

Date Received : *6/28/2005*

Sample Type : *SDWA*

KAR Sample No. : *052925-06*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/30/05	JAR	
Prep, VOA	Completed		EPA 524.2	06/30/05	JAR	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
1,1-Dichloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Benzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Bromoform	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Bromomethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Chloroform	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Chloromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Cis-1,2-Dichloroethene	1.3	ug/L	EPA 524.2	06/30/05	JAR	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *052925*

Date Reported : *07/05/05*

Project Desc. : *Analysis of 17 drinking water samples.*

Sample ID : *"05-175, Station 1-4"*

Sampled By : *ROD of KWRP*

Sample Date : *6/24/2005*

Sample Time : *1330*

Date Received : *6/28/2005*

Sample Type : *SDWA*

KAR Sample No. : *052925-06*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
M-and/or p-xylene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Naphthalene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
O-Xylene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Styrene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Tetrachloroethene	2.4	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Trichloroethene	0.7	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *052925*
Date Reported : *07/05/05*

Project Desc. : *Analysis of 17 drinking water samples.*

Sample ID : *"05-178, Station 1-5"*
Sampled By : *TW of KWRP*
Sample Date : *6/27/2005*
Sample Time : *1324*

Date Received : *6/28/2005*
Sample Type : *SDWA*
KAR Sample No. : *052925-07*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/30/05	JAR	
Prep. VOA	Completed		EPA 524.2	06/30/05	JAR	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
1,1-Dichloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Benzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Bromoform	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Bromomethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Chloroform	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Chloromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Cis-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *052925*

Date Reported : *07/05/05*

Project Desc. : *Analysis of 17 drinking water samples.*

Sample ID : *"05-178, Station 1-5"*

Sampled By : *TW of KWRP*

Sample Date : *6/27/2005*

Sample Time : *1324*

Date Received : *6/28/2005*

Sample Type : *SDWA*

KAR Sample No. : *052925-07*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
M-and/or p-xylene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Naphthalene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
O-Xylene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Styrene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Tetrachloroethene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Trichloroethene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *052925*

Date Reported : *07/05/05*

Project Desc. : *Analysis of 17 drinking water samples.*

Sample ID : *"05-175, Station 1-6"*

Sampled By : *ROD of KWRP*

Sample Date : *6/24/2005*

Sample Time : *1325*

Date Received : *6/28/2005*

Sample Type : *SDWA*

KAR Sample No. : *052925-08*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/30/05	JAR	
Prep. VOA	Completed		EPA 524.2	06/30/05	JAR	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
1,1-Dichloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Benzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Bromoform	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Bromomethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Chloroform	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Chloromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Cis-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *052925*
Date Reported : *07/05/05*

Project Desc. : *Analysis of 17 drinking water samples.*

Sample ID : *"05-175, Station 1-6"*
Sampled By : *ROD of KWRP*
Sample Date : *6/24/2005*
Sample Time : *1325*
Date Received : *6/28/2005*
Sample Type : *SDWA*
KAR Sample No. : *052925-08*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
M-and/or p-xylene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Naphthalene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
O-Xylene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Styrene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Tetrachloroethene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Trichloroethene	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/30/05	JAR	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/30/05	JAR	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *042661*

Date Reported : *06/15/04*

Project Desc. : *Analysis of 16 drinking water samples.*

Sample ID : *"Station 1-1, 04156"*

Sampled By : *CL of KWRP*

Sample Date : *6/4/2004*

Sample Time : *1350*

Date Received : *6/8/2004*

Sample Type : *SDWA*

KAR Sample No. : *042661-03*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/11/04	DLB	
Prep. VOA	Completed		EPA 524.2	06/11/04	DLB	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
1,1-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Benzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Bromoform	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Bromomethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Chloroform	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Chloromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Cis-1,2-Dichloroethene	1.4	ug/L	EPA 524.2	06/11/04	DLB	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *042661*

Date Reported : *06/15/04*

Project Desc. : *Analysis of 16 drinking water samples.*

Sample ID : *"Station 1-1, 04156"*

Sampled By : *CL of KWRP*

Sample Date : *6/4/2004*

Sample Time : *1350*

Date Received : *6/8/2004*

Sample Type : *SDWA*

KAR Sample No. : *042661-03*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
M-and/or p-xylene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Naphthalene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
O-Xylene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Styrene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Tetrachloroethene	2.9	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Trichloroethene	1.1	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *042661*

Date Reported : *06/15/04*

Project Desc. : *Analysis of 16 drinking water samples.*

Sample ID : *"Station 1-2, 04156"*

Sampled By : *CL of KWRP*

Sample Date : *6/4/2004*

Sample Time : *1355*

Date Received : *6/8/2004*

Sample Type : *SDWA*

KAR Sample No. : *042661-04*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/11/04	DLB	
Prep, VOA	Completed		EPA 524.2	06/11/04	DLB	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
1,1-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Benzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Bromoform	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Bromomethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Chloroform	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Chloromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Cis-1,2-Dichloroethene	5.1	ug/L	EPA 524.2	06/11/04	DLB	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *042661*

Date Reported : *06/15/04*

Project Desc. : *Analysis of 16 drinking water samples.*

Sample ID : *"Station 1-2, 04156"*

Sampled By : *CL of KWRP*

Sample Date : *6/4/2004*

Sample Time : *1355*

Date Received : *6/8/2004*

Sample Type : *SDWA*

KAR Sample No. : *042661-04*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
M-and/or p-xylene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Naphthalene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
O-Xylene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Styrene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Tetrachloroethene	1.4	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Trichloroethene	2.8	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *042661*

Date Reported : *06/15/04*

Project Desc. : *Analysis of 16 drinking water samples.*

Sample ID : *"Station 1-3, 04156"*

Sampled By : *CL of KWRP*

Sample Date : *6/4/2004*

Sample Time : *1400*

Date Received : *6/8/2004*

Sample Type : *SDWA*

KAR Sample No. : *042661-05*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/11/04	DLB	
Prep, VOA	Completed		EPA 524.2	06/11/04	DLB	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,1,1-Trichloroethane	0.9	ug/L	EPA 524.2	06/11/04	DLB	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
1,1-Dichloroethane	0.6	ug/L	EPA 524.2	06/11/04	DLB	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Benzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Bromoform	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Bromomethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Chloroform	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Chloromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Cis-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *042661*

Date Reported : *06/15/04*

Project Desc. : *Analysis of 16 drinking water samples.*

Sample ID : *"Station 1-3, 04156"*

Sampled By : *CL of KWRP*

Sample Date : *6/4/2004*

Sample Time : *1400*

Date Received : *6/8/2004*

Sample Type : *SDWA*

KAR Sample No. : *042661-05*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
M-and/or p-xylene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Naphthalene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
O-Xylene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Styrene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Tetrachloroethene	5.6	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Trichloroethene	1.0	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *042661*

Date Reported : *06/15/04*

Project Desc. : *Analysis of 16 drinking water samples.*

Sample ID : *"Station 1-4, 04156"*

Sampled By : *CL of KWRP*

Sample Date : *6/4/2004*

Sample Time : *1352*

Date Received : *6/8/2004*

Sample Type : *SDWA*

KAR Sample No. : *042661-06*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/11/04	DLB	
Prep VOA	Completed		EPA 524.2	06/11/04	DLB	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
1,1-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Benzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Bromoform	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Bromomethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Chloroform	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Chloromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Cis-1,2-Dichloroethene	0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *042661*
Date Reported : *06/15/04*

Project Desc. : *Analysis of 16 drinking water samples.*

Sample ID : *"Station 1-4, 04156"*
Sampled By : *CL of KWRP*
Sample Date : *6/4/2004*
Sample Time : *1352*

Date Received : *6/8/2004*
Sample Type : *SDWA*
KAR Sample No. : *042661-06*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
M-and/or p-xylene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Naphthalene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
O-Xylene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Styrene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Tetrachloroethene	1.9	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Trichloroethene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *042661*

Date Reported : *06/15/04*

Project Desc. : *Analysis of 16 drinking water samples.*

Sample ID : *"Station 1-5, 04156"*

Sampled By : *CL of KWRP*

Sample Date : *6/4/2004*

Sample Time : *1405*

Date Received : *6/8/2004*

Sample Type : *SDWA*

KAR Sample No. : *042661-07*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/11/04	DLB	
Prep. VOA	Completed		EPA 524.2	06/11/04	DLB	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
1,1-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Benzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Bromoform	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Bromomethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Chloroform	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Chloromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Cis-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *042661*

Date Reported : *06/15/04*

Project Desc. : *Analysis of 16 drinking water samples.*

Sample ID : *"Station 1-5, 04156"*

Sampled By : *CL of KWRP*

Sample Date : *6/4/2004*

Sample Time : *1405*

Date Received : *6/8/2004*

Sample Type : *SDWA*

KAR Sample No. : *042661-07*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
M-and/or p-xylene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Naphthalene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
O-Xylene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Styrene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Tetrachloroethene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Trichloroethene	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/11/04	DLB	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/11/04	DLB	MCL*=2 ug/L

* MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032924*

Date Reported : *06/30/03*

Project Desc. : *Analysis of six drinking water samples (KWRP #6997, #6998 & #7200).*

Sample ID : ***"Station 1, Well 1-1, 15603"***

Sampled By : *RDLS of KWRP*

Sample Date : *6/5/03*

Sample Time : *2:40pm*

Date Received : *6/6/03*

Sample Type : *SDWA*

KAR Sample No. : *032924-01*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep. metals	Completed		EPA 30xx,200.x	06/11/03	PML	
Antimony, total, low level	<0.005	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.006 mg/L
Arsenic, total, low level	<0.001	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.05 mg/L
Beryllium, total, low level	<0.001	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.004 mg/L
Cadmium, total, low level	<0.0002	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.005 mg/L
Calcium, total	113	mg/L	EPA 200.7	06/12/03	PML	
Chromium, total	<0.01	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.1 mg/L
Cobalt, total	<0.02	mg/L	EPA 200.8	06/12/03	DBL	
Copper, total	<0.02	mg/L	EPA 200.8	06/12/03	DBL	MCL*=1.3 mg/L
Iron, total	0.01	mg/L	EPA 200.7	06/12/03	PML	MCL*=[0.3 mg/L]
Lead, total	<0.003	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.015 mg/L
Magnesium, total	38.8	mg/L	EPA 200.7	06/12/03	PML	
Manganese, total	0.080	mg/L	EPA 200.8	06/12/03	DBL	MCL*=[0.05 mg/L]
Nickel, total	<0.02	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.1 mg/L
Potassium, total	2.5	mg/L	EPA 200.7	06/12/03	PML	
Selenium, total	<0.005	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.05 mg/L
Silver, total	<0.005	mg/L	EPA 200.8	06/12/03	DBL	MCL*=[0.1 mg/L]
Sodium, total	69.6	mg/L	EPA 200.7	06/12/03	PML	MCL*=[20 mg/L]
Thallium, total, low level	<0.002	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.002 mg/L
Zinc, total	<0.02	mg/L	EPA 200.8	06/12/03	DBL	MCL*=[5 mg/L]
Silicate	12.2	mg/L	SM(18) 4500-Si E	06/26/03	DMC	Analysis does not detect complex silicates.
Sulfate	52	mg/L	EPA 300.0A	06/20/03	MTW	MCL*=[250 mg/L]

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032924*

Date Reported : *06/30/03*

Project Desc. : *Analysis of six drinking water samples (KWRP #6997, #6998 & #7200).*

Sample ID : *"Station 1, Well 1-2, 15603"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/5/03*

Sample Time : *1:15pm*

Date Received : *6/6/03*

Sample Type : *SDWA*

KAR Sample No. : *032924-02*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, metals	Completed		EPA 30xx,200.x	06/11/03	PML	
Antimony, total, low level	<0.005	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.006 mg/L
Arsenic, total, low level	<0.001	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.05 mg/L
Beryllium, total, low level	<0.001	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.004 mg/L
Cadmium, total, low level	<0.0002	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.005 mg/L
Calcium, total	104	mg/L	EPA 200.7	06/12/03	PML	
Chromium, total	<0.01	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.1 mg/L
Cobalt, total	<0.02	mg/L	EPA 200.8	06/12/03	DBL	
Copper, total	<0.02	mg/L	EPA 200.8	06/12/03	DBL	MCL*=1.3 mg/L
Iron, total	0.85	mg/L	EPA 200.7	06/12/03	PML	MCL*=[0.3 mg/L]
Lead, total	<0.003	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.015 mg/L
Magnesium, total	34.8	mg/L	EPA 200.7	06/12/03	PML	
Manganese, total	0.135	mg/L	EPA 200.8	06/12/03	DBL	MCL*=[0.05 mg/L]
Nickel, total	<0.02	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.1 mg/L
Potassium, total	2.8	mg/L	EPA 200.7	06/12/03	PML	
Selenium, total	<0.005	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.05 mg/L
Silver, total	<0.005	mg/L	EPA 200.8	06/12/03	DBL	MCL*=[0.1 mg/L]
Sodium, total	64.3	mg/L	EPA 200.7	06/12/03	PML	MCL*=[20 mg/L]
Thallium, total, low level	<0.002	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.002 mg/L
Zinc, total	<0.02	mg/L	EPA 200.8	06/12/03	DBL	MCL*=[5 mg/L]
Silicate	12.4	mg/L	SM(18) 4500-Si E	06/26/03	DMC	Analysis does not detect complex silicates.
Sulfate	42	mg/L	EPA 300.0A	06/20/03	MTW	MCL*=[250 mg/L]

* MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032924*

Date Reported : *06/30/03*

Project Desc. : *Analysis of six drinking water samples (KWRP #6997, #6998 & #7200).*

Sample ID : *"Station 1, Well 1-3, 15603"*

Sampled By : *RDLS of KWRP*
Sample Date : *6/5/03*
Sample Time : *2:20pm*

Date Received : *6/6/03*
Sample Type : *SDWA*
KAR Sample No. : *032924-03*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, metals	Completed		EPA 30xx,200.x	06/11/03	PML	
Antimony, total, low level	<0.005	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.006 mg/L
Arsenic, total, low level	<0.001	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.05 mg/L
Beryllium, total, low level	<0.001	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.004 mg/L
Cadmium, total, low level	<0.0002	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.005 mg/L
Calcium, total	100	mg/L	EPA 200.7	06/12/03	PML	
Chromium, total	<0.01	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.1 mg/L
Cobalt, total	<0.02	mg/L	EPA 200.8	06/12/03	DBL	
Copper, total	<0.02	mg/L	EPA 200.8	06/12/03	DBL	MCL*=1.3 mg/L
Iron, total	0.24	mg/L	EPA 200.7	06/12/03	PML	MCL*=[0.3 mg/L]
Lead, total	<0.003	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.015 mg/L
Magnesium, total	33.5	mg/L	EPA 200.7	06/12/03	PML	
Manganese, total	0.117	mg/L	EPA 200.8	06/12/03	DBL	MCL*=[0.05 mg/L]
Nickel, total	<0.02	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.1 mg/L
Potassium, total	2.7	mg/L	EPA 200.7	06/12/03	PML	
Selenium, total	<0.005	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.05 mg/L
Silver, total	<0.005	mg/L	EPA 200.8	06/12/03	DBL	MCL*=[0.1 mg/L]
Sodium, total	62.0	mg/L	EPA 200.7	06/12/03	PML	MCL*=[20 mg/L]
Thallium, total, low level	<0.002	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.002 mg/L
Zinc, total	<0.02	mg/L	EPA 200.8	06/12/03	DBL	MCL*=[5 mg/L]
Silicate	12.4	mg/L	SM(18) 4500-Si E	06/26/03	DMC	Analysis does not detect complex silicates.
Sulfate	42	mg/L	EPA 300.0A	06/20/03	MTW	MCL*=[250 mg/L]

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032924*

Date Reported : *06/30/03*

Project Desc. : *Analysis of six drinking water samples (KWRP #6997, #6998 & #7200).*

Sample ID : *"Station 1, Well 1-4, 15603"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/5/03*

Sample Time : *1:35pm*

Date Received : *6/6/03*

Sample Type : *SDWA*

KAR Sample No. : *032924-04*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, metals	Completed		EPA 30xx,200.x	06/11/03	PML	
Antimony, total, low level	<0.005	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.006 mg/L
Arsenic, total, low level	<0.001	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.05 mg/L
Beryllium, total, low level	<0.001	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.004 mg/L
Cadmium, total, low level	<0.0002	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.005 mg/L
Calcium, total	99.1	mg/L	EPA 200.7	06/12/03	PML	
Chromium, total	<0.01	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.1 mg/L
Cobalt, total	<0.02	mg/L	EPA 200.8	06/12/03	DBL	
Copper, total	<0.02	mg/L	EPA 200.8	06/12/03	DBL	MCL*=1.3 mg/L
Iron, total	0.18	mg/L	EPA 200.7	06/12/03	PML	MCL*=[0.3 mg/L]
Lead, total	<0.003	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.015 mg/L
Magnesium, total	31.3	mg/L	EPA 200.7	06/12/03	PML	
Manganese, total	0.076	mg/L	EPA 200.8	06/12/03	DBL	MCL*=[0.05 mg/L]
Nickel, total	<0.02	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.1 mg/L
Potassium, total	2.5	mg/L	EPA 200.7	06/12/03	PML	
Selenium, total	<0.005	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.05 mg/L
Silver, total	<0.005	mg/L	EPA 200.8	06/12/03	DBL	MCL*=[0.1 mg/L]
Sodium, total	51.1	mg/L	EPA 200.7	06/12/03	PML	MCL*=[20 mg/L]
Thallium, total, low level	<0.002	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.002 mg/L
Zinc, total	<0.02	mg/L	EPA 200.8	06/12/03	DBL	MCL*=[5 mg/L]
Silicate	12.1	mg/L	SM(18) 4500-Si E	06/26/03	DMC	Analysis does not detect complex silicates.
Sulfate	37	mg/L	EPA 300.0A	06/20/03	MTW	MCL*=[250 mg/L]

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032924*

Date Reported : *06/30/03*

Project Desc. : *Analysis of six drinking water samples (KWRP #6997, #6998 & #7200).*

Sample ID : *"Station 1, Well 1-5, 15603"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/5/03*

Sample Time : *2:05pm*

Date Received : *6/6/03*

Sample Type : *SDWA*

KAR Sample No. : *032924-05*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, metals	Completed		EPA 30xx,200.x	06/11/03	PML	
Antimony, total, low level	<0.005	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.006 mg/L
Arsenic, total, low level	<0.001	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.05 mg/L
Beryllium, total, low level	<0.001	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.004 mg/L
Cadmium, total, low level	<0.0002	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.005 mg/L
Calcium, total	90.4	mg/L	EPA 200.7	06/12/03	PML	
Chromium, total	<0.01	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.1 mg/L
Cobalt, total	<0.02	mg/L	EPA 200.8	06/12/03	DBL	
Copper, total	<0.02	mg/L	EPA 200.8	06/12/03	DBL	MCL*=1.3 mg/L
Iron, total	0.28	mg/L	EPA 200.7	06/12/03	PML	MCL*=[0.3 mg/L]
Lead, total	<0.003	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.015 mg/L
Magnesium, total	29.4	mg/L	EPA 200.7	06/12/03	PML	
Manganese, total	0.069	mg/L	EPA 200.8	06/12/03	DBL	MCL*=[0.05 mg/L]
Nickel, total	<0.02	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.1 mg/L
Potassium, total	1.8	mg/L	EPA 200.7	06/12/03	PML	
Selenium, total	<0.005	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.05 mg/L
Silver, total	<0.005	mg/L	EPA 200.8	06/12/03	DBL	MCL*=[0.1 mg/L]
Sodium, total	29.0	mg/L	EPA 200.7	06/12/03	PML	MCL*=[20 mg/L]
Thallium, total, low level	<0.002	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.002 mg/L
Zinc, total	<0.02	mg/L	EPA 200.8	06/12/03	DBL	MCL*=[5 mg/L]
Silicate	12.8	mg/L	SM(18) 4500-Si E	06/26/03	DMC	Analysis does not detect complex silicates.
Sulfate	32	mg/L	EPA 300.0A	06/20/03	MTW	MCL*=[250 mg/L]

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032924*

Date Reported : *06/30/03*

Project Desc. : *Analysis of six drinking water samples (KWRP #6997, #6998 & #7200).*

Sample ID : *"Station 1, Well 1-6, 15603"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/5/03*

Sample Time : *1:50pm*

Date Received : *6/6/03*

Sample Type : *SDWA*

KAR Sample No. : *032924-06*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, metals	Completed		EPA 30xx,200.x	06/11/03	PML	
Antimony, total, low level	<0.005	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.006 mg/L
Arsenic, total, low level	<0.001	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.05 mg/L
Beryllium, total, low level	<0.001	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.004 mg/L
Cadmium, total, low level	<0.0002	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.005 mg/L
Calcium, total	93.7	mg/L	EPA 200.7	06/12/03	PML	
Chromium, total	<0.01	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.1 mg/L
Cobalt, total	<0.02	mg/L	EPA 200.8	06/12/03	DBL	
Copper, total	<0.02	mg/L	EPA 200.8	06/12/03	DBL	MCL*=1.3 mg/L
Iron, total	0.49	mg/L	EPA 200.7	06/12/03	PML	MCL*=[0.3 mg/L]
Lead, total	<0.003	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.015 mg/L
Magnesium, total	30.8	mg/L	EPA 200.7	06/12/03	PML	
Manganese, total	0.054	mg/L	EPA 200.8	06/12/03	DBL	MCL*=[0.05 mg/L]
Nickel, total	<0.02	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.1 mg/L
Potassium, total	1.9	mg/L	EPA 200.7	06/12/03	PML	
Selenium, total	<0.005	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.05 mg/L
Silver, total	<0.005	mg/L	EPA 200.8	06/12/03	DBL	MCL*=[0.1 mg/L]
Sodium, total	37.7	mg/L	EPA 200.7	06/12/03	PML	MCL*=[20 mg/L]
Thallium, total, low level	<0.002	mg/L	EPA 200.8	06/12/03	DBL	MCL*=0.002 mg/L
Zinc, total	<0.02	mg/L	EPA 200.8	06/12/03	DBL	MCL*=[5 mg/L]
Silicate	12.4	mg/L	SM(18) 4500-Si E	06/26/03	DMC	Analysis does not detect complex silicates.
Sulfate	37	mg/L	EPA 300.0A	06/20/03	MTW	MCL*=[250 mg/L]

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032930*

Date Reported : *06/13/03*

Project Desc. : *Analysis of three drinking water samples.*

Sample ID : *"Sta. 1-2"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/3/03*

Sample Time : *0830*

Date Received : *6/6/03*

Sample Type : *SDWA*

KAR Sample No. : *032930-01*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/11/03	DLB	
Prep, VOA	Completed		EPA 524.2	06/11/03	DLB	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
1,1-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Benzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Bromoform	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Bromomethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Chloroform	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Chloromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Cis-1,2-Dichloroethene	5.2	ug/L	EPA 524.2	06/11/03	DLB	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032930*

Date Reported : *06/13/03*

Project Desc. : *Analysis of three drinking water samples.*

Sample ID : *"Sta. 1-2"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/3/03*

Sample Time : *0830*

Date Received : *6/6/03*

Sample Type : *SDWA*

KAR Sample No. : *032930-01*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/11/03	DLB	
Prep, VOA	Completed		EPA 524.2	06/11/03	DLB	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
1,1-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Benzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Bromoform	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Bromomethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Chloroform	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Chloromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Cis-1,2-Dichloroethene	5.2	ug/L	EPA 524.2	06/11/03	DLB	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032930*

Date Reported : *06/13/03*

Project Desc. : *Analysis of three drinking water samples.*

Sample ID : *"Sta. 1-2"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/3/03*

Sample Time : *0830*

Date Received : *6/6/03*

Sample Type : *SDWA*

KAR Sample No. : *032930-01*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
M-and/or p-xylene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Naphthalene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
O-Xylene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Styrene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Tetrachloroethene	1.0	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Trichloroethene	2.6	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032930*

Date Reported : *06/13/03*

Project Desc. : *Analysis of three drinking water samples.*

Sample ID : *"Sta. 1-2"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/3/03*

Sample Time : *0830*

Date Received : *6/6/03*

Sample Type : *SDWA*

KAR Sample No. : *032930-01*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
M-and/or p-xylene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Naphthalene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
O-Xylene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Styrene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Tetrachloroethene	1.0	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Trichloroetnene	2.6	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032930*

Date Reported : *06/13/03*

Project Desc. : *Analysis of three drinking water samples.*

Sample ID : *"1-5, 15603"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/5/03*

Sample Time : *1405*

Date Received : *6/6/03*

Sample Type : *SDWA*

KAR Sample No. : *032930-02*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/11/03	DLB	
Prep. VOA	Completed		EPA 524.2	06/11/03	DLB	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
1,1-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Benzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Bromoform	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Bromomethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Chloroform	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Chloromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Cis-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032930*

Date Reported : *06/13/03*

Project Desc. : *Analysis of three drinking water samples.*

Sample ID : *"1-5, 15603"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/5/03*

Sample Time : *1405*

Date Received : *6/6/03*

Sample Type : *SDWA*

KAR Sample No. : *032930-02*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/11/03	DLB	
Prep, VOA	Completed		EPA 524.2	06/11/03	DLB	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
1,1-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Benzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Bromoform	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Bromomethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Chloroform	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Chloromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Cis-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032930*

Date Reported : *06/13/03*

Project Desc. : *Analysis of three drinking water samples.*

Sample ID : *"1-5, 15603"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/5/03*

Sample Time : *1405*

Date Received : *6/6/03*

Sample Type : *SDWA*

KAR Sample No. : *032930-02*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
M-and/or p-xylene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Naphthalene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
O-Xylene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Styrene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Tetrachloroethene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Trichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032930*

Date Reported : *06/13/03*

Project Desc. : *Analysis of three drinking water samples.*

Sample ID : *"1-5, 15603"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/5/03*

Sample Time : *1405*

Date Received : *6/6/03*

Sample Type : *SDWA*

KAR Sample No. : *032930-02*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
M-and/or p-xylene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Naphthalene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
O-Xylene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Styrene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Tetrachloroethene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Trichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032930*

Date Reported : *06/13/03*

Project Desc. : *Analysis of three drinking water samples.*

Sample ID : *"1-6, 15603"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/5/03*

Sample Time : *1350*

Date Received : *6/6/03*

Sample Type : *SDWA*

KAR Sample No. : *032930-03*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/11/03	DLB	
Prep, VOA	Completed		EPA 524.2	06/11/03	DLB	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
1,1-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Benzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Bromoform	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Bromomethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Chloroform	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Chloromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Cis-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	

* MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032930*

Date Reported : *06/13/03*

Project Desc. : *Analysis of three drinking water samples.*

Sample ID : *"1-6, 15603"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/5/03*

Sample Time : *1350*

Date Received : *6/6/03*

Sample Type : *SDWA*

KAR Sample No. : *032930-03*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/11/03	DLB	
Prep. VOA	Completed		EPA 524.2	06/11/03	DLB	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
1,1-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Benzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Bromoform	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Bromomethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Chloroform	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Chloromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Cis-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032930*

Date Reported : *06/13/03*

Project Desc. : *Analysis of three drinking water samples.*

Sample ID : *"1-6, 15603"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/5/03*

Sample Time : *1350*

Date Received : *6/6/03*

Sample Type : *SDWA*

KAR Sample No. : *032930-03*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
M-and/or p-xylene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Naphthalene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
O-Xylene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Styrene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Tetrachloroethene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Trichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032930*

Date Reported : *06/13/03*

Project Desc. : *Analysis of three drinking water samples.*

Sample ID : *"1-6, 15603"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/5/03*

Sample Time : *1350*

Date Received : *6/6/03*

Sample Type : *SDWA*

KAR Sample No. : *032930-03*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
M-and/or p-xylene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Naphthalene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
O-Xylene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Styrene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Tetrachloroethene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Trichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/11/03	DLB	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/11/03	DLB	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032899*

Date Reported : *06/13/03*

Project Desc. : *Analysis of 19 drinking water samples.*

Sample ID : *"1-1, 15403"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/3/03*

Sample Time : *0840*

Date Received : *6/5/03*

Sample Type : *SDWA*

KAR Sample No. : *032899-03*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/11/03	JAR	
Prep. VOA	Completed		EPA 524.2	06/11/03	JAR	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
1,1-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Benzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Bromoform	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Bromomethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Chloroform	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Chloromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Cis-1,2-Dichloroethene	0.6	ug/L	EPA 524.2	06/11/03	JAR	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032899*

Date Reported : *06/13/03*

Project Desc. : *Analysis of 19 drinking water samples.*

Sample ID : *"1-1, 15403"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/3/03*

Sample Time : *0840*

Date Received : *6/5/03*

Sample Type : *SDWA*

KAR Sample No. : *032899-03*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/11/03	JAR	
Prep. VOA	Completed		EPA 524.2	06/11/03	JAR	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
1,1-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Benzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Bromoform	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Bromomethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Chloroform	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Chloromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Cis-1,2-Dichloroethene	0.6	ug/L	EPA 524.2	06/11/03	JAR	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032899*

Date Reported : *06/13/03*

Project Desc. : *Analysis of 19 drinking water samples.*

Sample ID : *"1-1, 15403"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/3/03*

Sample Time : *0840*

Date Received : *6/5/03*

Sample Type : *SDWA*

KAR Sample No. : *032899-03*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
M-and/or p-xylene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Naphthalene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
O-Xylene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Styrene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Tetrachloroethene	1.6	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Trichloroethene	0.6	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. *Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.*

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032899*

Date Reported : *06/13/03*

Project Desc. : *Analysis of 19 drinking water samples.*

Sample ID : *"1-1, 15403"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/3/03*

Sample Time : *0840*

Date Received : *6/5/03*

Sample Type : *SDWA*

KAR Sample No. : *032899-03*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
M-and/or p-xylene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Naphthalene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
O-Xylene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Styrene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Tetrachloroethene	1.6	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Trichloroethene	0.6	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032899*

Date Reported : *06/13/03*

Project Desc. : *Analysis of 19 drinking water samples.*

Sample ID : *"1-3, 15403"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/3/03*

Sample Time : *0830*

Date Received : *6/5/03*

Sample Type : *SDWA*

KAR Sample No. : *032899-04*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/11/03	JAR	
Prep, VOA	Completed		EPA 524.2	06/11/03	JAR	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,1,1-Trichloroethane	1.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
1,1-Dichloroethane	0.8	ug/L	EPA 524.2	06/11/03	JAR	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Benzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Bromoform	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Bromomethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Chloroform	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Chloromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Cis-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032899*

Date Reported : *06/13/03*

Project Desc. : *Analysis of 19 drinking water samples.*

Sample ID : *"1-3, 15403"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/3/03*

Sample Time : *0830*

Date Received : *6/5/03*

Sample Type : *SDWA*

KAR Sample No. : *032899-04*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/11/03	JAR	
Prep. VOA	Completed		EPA 524.2	06/11/03	JAR	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,1,1-Trichloroethane	1.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
1,1-Dichloroethane	0.8	ug/L	EPA 524.2	06/11/03	JAR	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Benzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Bromoform	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Bromomethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Chloroform	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Chloromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Cis-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032899*

Date Reported : *06/13/03*

Project Desc. : *Analysis of 19 drinking water samples.*

Sample ID : *"1-3, 15403"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/3/03*

Sample Time : *0830*

Date Received : *6/5/03*

Sample Type : *SDWA*

KAR Sample No. : *032899-04*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
M-and/or p-xylene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Naphthalene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
O-Xylene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Styrene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Tetrachloroethene	4.0	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Trichloroethene	1.2	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032899*

Date Reported : *06/13/03*

Project Desc. : *Analysis of 19 drinking water samples.*

Sample ID : *"1-3, 15403"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/3/03*

Sample Time : *0830*

Date Received : *6/5/03*

Sample Type : *SDWA*

KAR Sample No. : *032899-04*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
M-and/or p-xylene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Naphthalene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
O-Xylene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Styrene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Tetrachloroethene	4.0	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Trichloroethene	1.2	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032899*

Date Reported : *06/13/03*

Project Desc. : *Analysis of 19 drinking water samples.*

Sample ID : *"1-4, 15403"*

Sampled By : *RDLS of KWRP*
Sample Date : *6/3/03*
Sample Time : *0825*

Date Received : *6/5/03*
Sample Type : *SDWA*
KAR Sample No. : *032899-05*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/11/03	JAR	
Prep, VOA	Completed		EPA 524.2	06/11/03	JAR	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
1,1-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Benzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Bromoform	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Bromomethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Chloroform	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Chloromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Cis-1,2-Dichloroethene	1.1	ug/L	EPA 524.2	06/11/03	JAR	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032899*

Date Reported : *06/13/03*

Project Desc. : *Analysis of 19 drinking water samples.*

Sample ID : *"1-4, 15403"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/3/03*

Sample Time : *0825*

Date Received : *6/5/03*

Sample Type : *SDWA*

KAR Sample No. : *032899-05*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Regulated/Unregulated VOC's	See below		EPA 524.2	06/11/03	JAR	
Prep, VOA	Completed		EPA 524.2	06/11/03	JAR	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=200 ug/L
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
1,1-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,1-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=7 ug/L
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,2,3-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=70 ug/L
1,2,4-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,2-Dibromo-3-chloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=0.2 ug/L
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=600 ug/L
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=75 [5] ug/L
2,2-Dichloropropane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Benzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
Bromobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Bromochloromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Bromodichloromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Bromoform	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Bromomethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
Chlorobenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=100 ug/L
Chloroethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Chloroform	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Chloromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Cis-1,2-Dichloroethene	1.1	ug/L	EPA 524.2	06/11/03	JAR	MCL*=70 ug/L
Cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032899*

Date Reported : *06/13/03*

Project Desc. : *Analysis of 19 drinking water samples.*

Sample ID : *"1-4, 15403"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/3/03*

Sample Time : *0825*

Date Received : *6/5/03*

Sample Type : *SDWA*

KAR Sample No. : *032899-05*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
M-and/or p-xylene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Naphthalene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
O-Xylene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Styrene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Tetrachloroethene	1.2	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Trichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

LABORATORY DETAIL REPORT

Client: *Kalamazoo Water Reclamation Plant*

KAR Project No. : *032899*

Date Reported : *06/13/03*

Project Desc. : *Analysis of 19 drinking water samples.*

Sample ID : *"1-4, 15403"*

Sampled By : *RDLS of KWRP*

Sample Date : *6/3/03*

Sample Time : *0825*

Date Received : *6/5/03*

Sample Type : *SDWA*

KAR Sample No. : *032899-05*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Dibromochloromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Dibromomethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Ethylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=700 ug/L
Ethylene dibromide	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=0.05 ug/L
Hexachlorobutadiene by 524.2	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Isopropylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
M-and/or p-xylene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Methylene chloride	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
N-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
N-Propylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Naphthalene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
O-Xylene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
P-Isopropyltoluene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Sec-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Styrene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=100 ug/L
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Tetrachloroethene	1.2	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
Toluene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=1000 ug/L
Trans-1,2-Dichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=100 ug/L
Trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Trichloroethene	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=5 ug/L
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	06/11/03	JAR	
Vinyl chloride	<0.5	ug/L	EPA 524.2	06/11/03	JAR	MCL*=2 ug/L

*MCL = Maximum Contaminant Level set by USEPA. Values enclosed in brackets ([]) are Secondary MCL's and are non-enforceable guidelines for aesthetic quality.

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL#1	WELL#2
Sample Date:			6/17/02	6/17/02	6/17/02	6/17/02
Sampled by:			TW	TW	TW	TW
Analysis Date:			6/19/02	6/19/02	6/19/02	6/19/02
Analyzed by:			JB	JB	JB	JB
	MDL	MCL				
WARNING NOTICES:						
Dichlorodifluoromethane	0.5		ND	ND	ND	ND
Chloromethane	0.5		ND	ND	ND	ND
Vinyl Chloride	0.5	2	ND	ND	ND	ND
Bromomethane	0.5		ND	ND	ND	ND
Chloroethane	0.5		ND	ND	ND	ND
Trichlorofluoromethane	0.5		ND	ND	ND	ND
Diethyl Ether	0.5		ND	ND	ND	ND
1,1-Dichloroethene	0.5	7	ND	ND	ND	ND
Acetone	0.5		ND	ND	ND	ND
Iodomethane	0.5		ND	ND	ND	ND
Carbon Disulfide	0.5		ND	ND	ND	ND
Allyl Chloride	0.5		ND	ND	ND	ND
Methylene Chloride	0.5	5	ND	ND	ND	ND
Acrylonitrile	0.5		ND	ND	ND	ND
t-1,2-Dichloroethene	0.5	100	ND	ND	ND	ND
Methyl -t-Butyl Ether	0.5		ND	ND	ND	ND
1,1-Dichloroethane	0.5		ND	ND	ND	ND
2,2-Dichloropropane	0.5		ND	ND	ND	ND
c-1,2-Dichloroethene	0.5	70	0.7	2.4	1.4	5.1
Methyl Ethyl Ketone	0.5		ND	ND	ND	ND
Propionitrile	0.5		ND	ND	ND	ND
Methyl Acrylate	0.5		ND	ND	ND	ND
Bromochloromethane	0.5		ND	ND	ND	ND
Methacrylonitrile	0.5		ND	ND	ND	ND
Tetrahydrofuran	0.5		ND	ND	ND	ND
Chloroform	0.5	TTHM*	ND	ND	ND	ND
1,1,1-Trichloroethane	0.5	200	ND	ND	ND	ND
n-Butyl Chloride	0.5		ND	ND	ND	ND
Carbon Tetrachloride	0.5	5	ND	ND	ND	ND
1,1-Dichloropropene	0.5		ND	ND	ND	ND
Benzene	0.5	5	ND	ND	ND	ND
1,2-Dichloroethane	0.5	5	ND	ND	ND	ND
Trichloroethene	0.5	5	ND	1.5	1.1	2.3
1,2-Dichloropropane	0.5	5	ND	ND	ND	ND
Dibromomethane	0.5		ND	ND	ND	ND
Methyl Methacrylate	0.5		ND	ND	ND	ND
Bromodichloromethane	0.5	TTHM*	1.1	ND	ND	ND
2-Nitropropane	0.5		ND	ND	ND	ND
Chloroacetonitrile	0.5		ND	ND	ND	ND
c-1,3-Dichloropropene	0.5		ND	ND	ND	ND
4-Methyl 2-Pentanone	0.5		ND	ND	ND	ND
Ethyl Methacrylate	0.5		ND	ND	ND	ND
Dichloroacetone	0.5		ND	ND	ND	ND
Toluene	0.5	1000	ND	ND	ND	ND
t-1,3-Dichloropropene	0.5		ND	ND	ND	ND
1,1,2-Trichloroethane	0.5	5	ND	ND	ND	ND
Tetrachloroethene	0.5	5	ND	1.1	1.2	0.8
1,3-Dichloropropane	0.5		ND	ND	ND	ND
Methyl Butyl Ketone	0.5		ND	ND	ND	ND
Dibromochloromethane	0.5	TTHM*	1.9	ND	ND	ND

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).
NA = Data Not Available, Parameter failed to meet acceptable QC criteria.

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL#1	WELL#2
Sample Date:			6/17/02	6/17/02	6/17/02	6/17/02
Sampled by:			TW	TW	TW	TW
Analysis Date:			6/19/02	6/19/02	6/19/02	6/19/02
Analyzed by:			JB	JB	JB	JB
	MDL	MCL				
1,2-Dibromoethane	0.5		ND	ND	ND	ND
Chlorobenzene	0.5	100	ND	ND	ND	ND
1,1,1,2-Tetrachloroethene	0.5		ND	ND	ND	ND
Ethylbenzene	0.5	700	ND	ND	ND	ND
m&p-Xylene	0.5	XYLENES**	ND	ND	ND	ND
o-Xylene	0.5	XYLENES**	ND	ND	ND	ND
Styrene	0.5	100	ND	ND	ND	ND
Bromoform	0.5	TTHM*	1.6	ND	ND	ND
Isopropyl Benzene	0.5		ND	ND	ND	ND
1,1,2,2-Tetrachlorethane	0.5		ND	ND	ND	ND
1,2,3-Trichloropropane	0.5		ND	ND	ND	ND
Bromobenzene	0.5		ND	ND	ND	ND
T-1,4-Dichloro-2-Butene	0.5		ND	ND	ND	ND
n-Propyl Benzene	0.5		ND	ND	ND	ND
2-Chloro Toluene	0.5		ND	ND	ND	ND
1,3,5-Trimethyl Benzene	0.5		ND	ND	ND	ND
4-Chloro Toluene	0.5		ND	ND	ND	ND
t-Butyl Benzene	0.5		ND	ND	ND	ND
1,2,4-Trimethyl Benzene	0.5		ND	ND	ND	ND
Pentachloroethane	0.5		ND	ND	ND	ND
sec-Butyl Benzene	0.5		ND	ND	ND	ND
p-Isopropyl Toluene	0.5		ND	ND	ND	ND
1,4-Dichlorobenzene	0.5	75	ND	ND	ND	ND
1,3-Dichlorobenzene	0.5		ND	ND	ND	ND
n-Butyl Benzene	0.5		ND	ND	ND	ND
1,2-Dichlorobenzene	0.5	600	ND	ND	ND	ND
Hexachloroethane	0.5		ND	ND	ND	ND
1,2-Dibromo-3-Chloro Propane	0.5		ND	ND	ND	ND
Nitrobenzene	0.5		ND	ND	ND	ND
1,2,4-Trichlorobenzene	0.5	70	ND	ND	ND	ND
Hexachlorobutadiene	0.5		ND	ND	ND	ND
Naphthalene	0.5		ND	ND	ND	ND
1,2,3-Trichloro Benzene	0.5		ND	ND	ND	ND
WARNING NOTICES:						

***TTHM = Regulated as Total Trihalomethanes with the total not to exceed 100 u**
****XYLENES= Regulated as Total Xylenes with the total not to exceed 10,000 ug**

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).
NA = Data Not Available, Parameter failed to meet acceptable QC criteria.

CENTRAL REPORT

Sample Location:			WELL#3	WELL#4	WELL#5	WELL#6
Sample Date:			OUT	6/17/02	6/25/02	OUT
Sampled by:			OF	TW	TW	OF
Analysis Date:			SERVICE	6/19/02	7/1/02	SERVICE
Analyzed by:			JB	JB	JB	JB
	MDL	MCL				
WARNING NOTICES:						
Dichlorodifluoromethane	0.5		ND	ND	ND	ND
Chloromethane	0.5		ND	ND	ND	ND
Vinyl Chloride	0.5	2	ND	ND	ND	ND
Bromomethane	0.5		ND	ND	ND	ND
Chloroethane	0.5		ND	ND	ND	ND
Trichlorofluoromethane	0.5		ND	ND	ND	ND
Diethyl Ether	0.5		ND	ND	ND	ND
1,1-Dichloroethene	0.5	7	ND	ND	ND	ND
Acetone	0.5		ND	ND	ND	ND
Iodomethane	0.5		ND	ND	ND	ND
Carbon Disulfide	0.5		ND	ND	ND	ND
Allyl Chloride	0.5		ND	ND	ND	ND
Methylene Chloride	0.5	5	ND	ND	ND	ND
Acrylonitrile	0.5		ND	ND	ND	ND
t-1,2-Dichloroethene	0.5	100	ND	ND	ND	ND
Methyl -t-Butyl Ether	0.5		ND	ND	ND	ND
1,1-Dichloroethane	0.5		ND	ND	ND	ND
2,2-Dichloropropane	0.5		ND	ND	ND	ND
c-1,2-Dichloroethene	0.5	70	ND	ND	ND	ND
Methyl Ethyl Ketone	0.5		ND	ND	ND	ND
Propionitrile	0.5		ND	ND	ND	ND
Methyl Acrylate	0.5		ND	ND	ND	ND
Bromochloromethane	0.5		ND	ND	ND	ND
Methacrylonitrile	0.5		ND	ND	ND	ND
Tetrahydrofuran	0.5		ND	ND	ND	ND
Chloroform	0.5	TTHM*	ND	ND	ND	ND
1,1,1-Trichloroethane	0.5	200	ND	ND	ND	ND
n-Butyl Chloride	0.5		ND	ND	ND	ND
Carbon Tetrachloride	0.5	5	ND	ND	ND	ND
1,1-Dichloropropene	0.5		ND	ND	ND	ND
Benzene	0.5	5	ND	ND	ND	ND
1,2-Dichloroethane	0.5	5	ND	ND	ND	ND
Trichloroethene	0.5	5	ND	ND	ND	ND
1,2-Dichloropropane	0.5	5	ND	ND	ND	ND
Dibromomethane	0.5		ND	ND	ND	ND
Methyl Methacrylate	0.5		ND	ND	ND	ND
Bromodichloromethane	0.5	TTHM*	ND	ND	ND	ND
2-Nitropropane	0.5		ND	ND	ND	ND
Chloroacetonitrile	0.5		ND	ND	ND	ND
c-1,3-Dichloropropene	0.5		ND	ND	ND	ND
4-Methyl 2-Pentanone	0.5		ND	ND	ND	ND
Ethyl Methacrylate	0.5		ND	ND	ND	ND
Dichloroacetone	0.5		ND	ND	ND	ND
Toluene	0.5	1000	ND	ND	ND	ND
t-1,3-Dichloropropene	0.5		ND	ND	ND	ND
1,1,2-Trichloroethane	0.5	5	ND	ND	ND	ND
Tetrachloroethene	0.5	5	ND	0.7	ND	ND
1,3-Dichloropropane	0.5		ND	ND	ND	ND
Methyl Butyl Ketone	0.5		ND	ND	ND	ND
Dibromochloromethane	0.5	TTHM*	ND	ND	ND	ND

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).
NA = Data Not Available, Parameter failed to meet acceptable QC criteria.

H2ojun02
7/1/02

CENTRAL REPORT

Sample Location:			WELL#3	WELL#4	WELL#5	WELL#6
Sample Date:			OUT	6/17/02	6/26/02	OUT
Sampled by:			OF	TW	TW	OF
Analysis Date:			SERVICE	6/19/02	7/1/02	SERVICE
Analyzed by:			JB	JB	JB	JB
	MDL	MCL				
1,2-Dibromoethane	0.5		ND	ND	ND	ND
Chlorobenzene	0.5	100	ND	ND	ND	ND
1,1,1,2-Tetrachloroethene	0.5		ND	ND	ND	ND
Ethylbenzene	0.5	700	ND	ND	ND	ND
m&p-Xylene	0.5	XYLENES**	ND	ND	ND	ND
o-Xylene	0.5	XYLENES**	ND	ND	ND	ND
Styrene	0.5	100	ND	ND	ND	ND
Bromoform	0.5	TTHM*	ND	ND	ND	ND
Isopropyl Benzene	0.5		ND	ND	ND	ND
1,1,2,2-Tetrachlorethane	0.5		ND	ND	ND	ND
1,2,3-Trichloropropane	0.5		ND	ND	ND	ND
Bromobenzene	0.5		ND	ND	ND	ND
T-1,4-Dichloro-2-Butene	0.5		ND	ND	ND	ND
n-Propyl Benzene	0.5		ND	ND	ND	ND
2-Chloro Toluene	0.5		ND	ND	ND	ND
1,3,5-Trimethyl Benzene	0.5		ND	ND	ND	ND
4-Chloro Toluene	0.5		ND	ND	ND	ND
t-Butyl Benzene	0.5		ND	ND	ND	ND
1,2,4-Trimethyl Benzene	0.5		ND	ND	ND	ND
Pentachloroethane	0.5		ND	ND	ND	ND
sec-Butyl Benzene	0.5		ND	ND	ND	ND
p-Isopropyl Toluene	0.5		ND	ND	ND	ND
1,4-Dichlorobenzene	0.5	75	ND	ND	ND	ND
1,3-Dichlorobenzene	0.5		ND	ND	ND	ND
n-Butyl Benzene	0.5		ND	ND	ND	ND
1,2-Dichlorobenzene	0.5	600	ND	ND	ND	ND
Hexachloroethane	0.5		ND	ND	ND	ND
1,2-Dibromo-3-Chloro Propane	0.5		ND	ND	ND	ND
Nitrobenzene	0.5		ND	ND	ND	ND
1,2,4-Trichlorobenzene	0.5	70	ND	ND	ND	ND
Hexachlorobutadiene	0.5		ND	ND	ND	ND
Naphthalene	0.5		ND	ND	ND	ND
1,2,3-Trichloro Benzene	0.5		ND	ND	ND	ND
WARNING NOTICES:						

***TTHM = Regulated as Total Trihalomethanes with the total not to exceed 1(**

****XYLENES= Regulated as Total Xylenes with the total not to exceed 10,000**

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).
NA = Data Not Available, Parameter failed to meet acceptable QC criteria.

H2ojun02
7/1/02

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL#1	WELL#2
Sample Date:			6/11/01	6/11/01	6/11/01	6/11/01
Sampled by:			TW	TW	TW	TW
Analysis Date:			6/14/01	6/14/01	6/18/01	6/14/01
Analyzed by:			JB	JB	JB	JB
	MDL	MCL				
WARNING NOTICES:						
Dichlorodifluoromethane	0.5		ND	ND	ND	ND
Chloromethane	0.5		ND	ND	ND	ND
Vinyl Chloride	0.5	2	ND	ND	ND	ND
Bromomethane	0.5		ND	ND	ND	ND
Chloroethane	0.5		ND	ND	ND	ND
Trichlorofluoromethane	0.5		ND	ND	ND	ND
Diethyl Ether	0.5		ND	ND	ND	ND
1,1-Dichloroethene	0.5	7	ND	ND	ND	ND
Acetone	0.5		ND	ND	ND	ND
Iodomethane	0.5		ND	ND	ND	ND
Carbon Disulfide	0.8		ND	ND	ND	ND
Allyl Chloride	0.5		ND	ND	ND	ND
Methylene Chloride	0.5	5	ND	ND	ND	ND
Acrylonitrile	0.5		ND	ND	ND	ND
t-1,2-Dichloroethene	0.5	100	ND	ND	ND	ND
Methyl -t-Butyl Ether	0.5		ND	ND	ND	ND
1,1-Dichloroethane	0.5		ND	ND	ND	ND
2,2-Dichloropropane	0.5		ND	ND	ND	ND
c-1,2-Dichloroethene	0.5	70	0.5	1.8	3.0	3.5
Methyl Ethyl Ketone	0.5		ND	ND	ND	ND
Propionitrile	0.5		ND	ND	ND	ND
Methyl Acrylate	0.5		ND	ND	ND	ND
Bromochloromethane	0.5		ND	ND	ND	ND
Methacrylonitrile	0.5		ND	ND	ND	ND
Tetrahydrofuran	0.5		ND	ND	ND	ND
Chloroform	0.5	TTHM*	ND	ND	ND	ND
1,1,1-Trichloroethane	0.5	200	ND	ND	ND	ND
n-Butyl Chloride	0.5		ND	ND	ND	ND
Carbon Tetrachloride	0.5	5	ND	ND	ND	ND
1,1-Dichloropropene	0.5		ND	ND	ND	ND
Benzene	0.5	5	ND	ND	ND	ND
1,2-Dichloroethane	0.5	5	ND	ND	ND	ND
Trichloroethene	0.5	5	ND	1.2	2.0	1.6
1,2-Dichloropropane	0.5	5	ND	ND	ND	ND
Dibromomethane	0.5		ND	ND	ND	ND
Methyl Methacrylate	0.5		ND	ND	ND	ND
Bromodichloromethane	0.5	TTHM*	ND	ND	ND	ND
2-Nitropropane	0.5		ND	ND	ND	ND
Chloroacetonitrile	0.5		ND	ND	ND	ND
c-1,3-Dichloropropene	0.5		ND	ND	ND	ND
4-Methyl 2-Pentanone	0.5		ND	ND	ND	ND
Ethyl Methacrylate	0.5		ND	ND	ND	ND
Dichloroacetone	0.5		ND	ND	ND	ND
Toluene	0.5	1000	ND	ND	ND	ND
t-1,3-Dichloropropene	0.5		ND	ND	ND	ND
1,1,2-Trichloroethane	0.5	5	ND	ND	ND	ND
Tetrachloroethene	0.5	5	ND	3.1	2.2	1.3
1,3-Dichloropropane	0.5		ND	ND	ND	ND
Methyl Butyl Ketone	0.5		ND	ND	ND	ND
Dibromochloromethane	0.5	TTHM*	0.7	ND	ND	ND

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).
NA = Data Not Available, Parameter failed to meet acceptable QC criteria.

H2OMASTERS
7/2/01

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL#1	WELL#2
Sample Date:			6/11/01	6/11/01	6/11/01	6/11/01
Sampled by:			TW	TW	TW	TW
Analysis Date:			6/14/01	6/14/01	6/18/01	6/14/01
Analyzed by:			JB	JB	JB	JB
	MDL	MCL				
1,2-Dibromoethane	0.5		ND	ND	ND	ND
Chlorobenzene	0.5	100	ND	ND	ND	ND
1,1,1,2-Tetrachloroethene	0.5		ND	ND	ND	ND
Ethylbenzene	0.5	700	ND	ND	ND	ND
m&p-Xylene	0.5	XYLENES**	ND	ND	ND	ND
o-Xylene	0.5	XYLENES**	ND	ND	ND	ND
Styrene	0.5	100	ND	ND	ND	ND
Bromoform	0.5	TTHM*	ND	ND	ND	ND
Isopropyl Benzene	0.5		ND	ND	ND	ND
1,1,2,2-Tetrachlorethane	0.5		ND	ND	ND	ND
1,2,3-Trichloropropane	0.5		ND	ND	ND	ND
Bromobenzene	0.5		ND	ND	ND	ND
T-1,4-Dichloro-2-Butene	0.5		ND	ND	ND	ND
n-Propyl Benzene	0.5		ND	ND	ND	ND
2-Chloro Toluene	0.5		ND	ND	ND	ND
1,3,5-Trimethyl Benzene	0.5		ND	ND	ND	ND
4-Chloro Toluene	0.5		ND	ND	ND	ND
t-Butyl Benzene	0.5		ND	ND	ND	ND
1,2,4-Trimethyl Benzene	0.5		ND	ND	ND	ND
Pentachloroethane	0.5		ND	ND	ND	ND
sec-Butyl Benzene	0.5		ND	ND	ND	ND
p-Isopropyl Toluene	0.5		ND	ND	ND	ND
1,4-Dichlorobenzene	0.5	75	ND	ND	ND	ND
1,3-Dichlorobenzene	0.5		ND	ND	ND	ND
n-Butyl Benzene	0.5		ND	ND	ND	ND
1,2-Dichlorobenzene	0.5	600	ND	ND	ND	ND
Hexachloroethane	0.5		ND	ND	ND	ND
1,2-Dibromo-3-Chloro Propane	0.5		ND	ND	ND	ND
Nitrobenzene	0.5		ND	ND	ND	ND
1,2,4-Trichlorobenzene	0.5	70	ND	ND	ND	ND
Hexachlorobutadiene	0.5		ND	ND	ND	ND
Naphthalene	0.5		ND	ND	ND	ND
1,2,3-Trichloro Benzene	0.5		ND	ND	ND	ND
WARNING NOTICES:						

***TTHM = Regulated as Total Trihalomethanes with the total not to exceed 100**
****XYLENES= Regulated as Total Xylenes with the total not to exceed 10,000 u**

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).
NA = Data Not Available, Parameter failed to meet acceptable QC criteria.

H20MASTERS
7/2/01

CENTRAL REPORT

Sample Location:			WELL#3	WELL#4	WELL#5	WELL#6
Sample Date:			6/11/01	OUT	OUT	6/11/01
Sampled by:			TW	OF	OF	TW
Analysis Date:			6/14/01	SERVICE	SERVICE	6/14/01
Analyzed by:			JB	JB	JB	JB
	MDL	MCL				
WARNING NOTICES:						
Dichlorodifluoromethane	0.5		ND	ND	ND	ND
Chloromethane	0.5		ND	ND	ND	ND
Vinyl Chloride	0.5	2	ND	ND	ND	ND
Bromomethane	0.5		ND	ND	ND	ND
Chloroethane	0.5		ND	ND	ND	ND
Trichlorofluoromethane	0.5		ND	ND	ND	ND
Diethyl Ether	0.5		ND	ND	ND	ND
1,1-Dichloroethene	0.5	7	ND	ND	ND	ND
Acetone	0.5		ND	ND	ND	ND
Iodomethane	0.5		ND	ND	ND	ND
Carbon Disulfide	0.8		ND	ND	ND	ND
Allyl Chloride	0.5		ND	ND	ND	ND
Methylene Chloride	0.5	5	ND	ND	ND	ND
Acrylonitrile	0.5		ND	ND	ND	ND
t-1,2-Dichloroethene	0.5	100	ND	ND	ND	ND
Methyl -t-Butyl Ether	0.5		ND	ND	ND	ND
1,1-Dichloroethane	0.5		ND	ND	ND	ND
2,2-Dichloropropane	0.5		ND	ND	ND	ND
c-1,2-Dichloroethene	0.5	70	ND	ND	ND	ND
Methyl Ethyl Ketone	0.5		ND	ND	ND	ND
Propionitrile	0.5		ND	ND	ND	ND
Methyl Acrylate	0.5		ND	ND	ND	ND
Bromochloromethane	0.5		ND	ND	ND	ND
Methacrylonitrile	0.5		ND	ND	ND	ND
Tetrahydrofuran	0.5		ND	ND	ND	ND
Chloroform	0.5	TTHM*	ND	ND	ND	ND
1,1,1-Trichloroethane	0.5	200	0.8	ND	ND	ND
n-Butyl Chloride	0.5		ND	ND	ND	ND
Carbon Tetrachloride	0.5	5	ND	ND	ND	ND
1,1-Dichloropropene	0.5		ND	ND	ND	ND
Benzene	0.5	5	ND	ND	ND	ND
1,2-Dichloroethane	0.5	5	ND	ND	ND	ND
Trichloroethene	0.5	5	0.6	ND	ND	ND
1,2-Dichloropropane	0.5	5	ND	ND	ND	ND
Dibromomethane	0.5		ND	ND	ND	ND
Methyl Methacrylate	0.5		ND	ND	ND	ND
Bromodichloromethane	0.5	TTHM*	ND	ND	ND	ND
2-Nitropropane	0.5		ND	ND	ND	ND
Chloroacetonitrile	0.5		ND	ND	ND	ND
c-1,3-Dichloropropene	0.5		ND	ND	ND	ND
4-Methyl 2-Pentanone	0.5		ND	ND	ND	ND
Ethyl Methacrylate	0.5		ND	ND	ND	ND
Dichloroacetone	0.5		ND	ND	ND	ND
Toluene	0.5	1000	ND	ND	ND	ND
t-1,3-Dichloropropene	0.5		ND	ND	ND	ND
1,1,2-Trichloroethane	0.5	5	ND	ND	ND	ND
Tetrachloroethene	0.5	5	6.1	ND	ND	ND
1,3-Dichloropropane	0.5		ND	ND	ND	ND
Methyl Butyl Ketone	0.5		ND	ND	ND	ND
Dibromochloromethane	0.5	TTHM*	ND	ND	ND	ND

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).
NA = Data Not Available, Parameter failed to meet acceptable QC criteria.

H20MASTERS
7/2/01

CENTRAL REPORT

Sample Location:			WELL#3	WELL#4	WELL#5	WELL#6
Sample Date:			6/11/01	OUT	OUT	6/11/01
Sampled by:			TW	OF	OF	TW
Analysis Date:			6/14/01	SERVICE	SERVICE	6/14/01
Analyzed by:			JB	JB	JB	JB
	MDL	MCL				
1,2-Dibromoethane	0.5		ND	ND	ND	ND
Chlorobenzene	0.5	100	ND	ND	ND	ND
1,1,1,2-Tetrachloroethene	0.5		ND	ND	ND	ND
Ethylbenzene	0.5	700	ND	ND	ND	ND
m&p-Xylene	0.5	XYLENES**	ND	ND	ND	ND
o-Xylene	0.5	XYLENES**	ND	ND	ND	ND
Styrene	0.5	100	ND	ND	ND	ND
Bromoform	0.5	TTHM*	ND	ND	ND	ND
Isopropyl Benzene	0.5		ND	ND	ND	ND
1,1,2,2-Tetrachlorethane	0.5		ND	ND	ND	ND
1,2,3-Trichloropropane	0.5		ND	ND	ND	ND
Bromobenzene	0.5		ND	ND	ND	ND
T-1,4-Dichloro-2-Butene	0.5		ND	ND	ND	ND
n-Propyl Benzene	0.5		ND	ND	ND	ND
2-Chloro Toluene	0.5		ND	ND	ND	ND
1,3,5-Trimethyl Benzene	0.5		ND	ND	ND	ND
4-Chloro Toluene	0.5		ND	ND	ND	ND
t-Butyl Benzene	0.5		ND	ND	ND	ND
1,2,4-Trimethyl Benzene	0.5		ND	ND	ND	ND
Pentachloroethane	0.5		ND	ND	ND	ND
sec-Butyl Benzene	0.5		ND	ND	ND	ND
p-Isopropyl Toluene	0.5		ND	ND	ND	ND
1,4-Dichlorobenzene	0.5	75	ND	ND	ND	ND
1,3-Dichlorobenzene	0.5		ND	ND	ND	ND
n-Butyl Benzene	0.5		ND	ND	ND	ND
1,2-Dichlorobenzene	0.5	600	ND	ND	ND	ND
Hexachloroethane	0.5		ND	ND	ND	ND
1,2-Dibromo-3-Chloro Propane	0.5		ND	ND	ND	ND
Nitrobenzene	0.5		ND	ND	ND	ND
1,2,4-Trichlorobenzene	0.5	70	ND	ND	ND	ND
Hexachlorobutadiene	0.5		ND	ND	ND	ND
Naphthalene	0.5		ND	ND	ND	ND
1,2,3-Trichloro Benzene	0.5		ND	ND	ND	ND
WARNING NOTICES:			OVER MCL			

***TTHM = Regulated as Total Trihalomethanes with the total not to exceed 1(**

****XYLENES= Regulated as Total Xylenes with the total not to exceed 10,000**

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).
NA = Data Not Available, Parameter failed to meet acceptable QC criteria.

H2OMASTERS
7/2/01

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL#1	WELL#2
Sample Date:			6/6/00	6/6/00	6/6/00	6/6/00
Sampled by:			TW	TW	TW	TW
Analysis Date:			6/6/00	6/6/00	6/6/00	6/6/00
Analyzed by:			JB	JB	JB	JB
	MDL	MCL				
WARNING NOTICES:						
Dichlorodifluoromethane	0.4		ND	ND	ND	ND
Chloromethane	0.5		ND	ND	ND	ND
Vinyl Chloride	0.3	2	ND	ND	ND	ND
Bromomethane	0.6		ND	ND	ND	ND
Chloroethane	0.4		ND	ND	ND	ND
Trichlorofluoromethane	0.3		ND	ND	ND	ND
Diethyl Ether	0.5		ND	ND	ND	ND
1,1-Dichloroethene	0.3	7	ND	ND	ND	ND
Acetone	1.9		ND	ND	ND	ND
Iodomethane	0.7		ND	ND	ND	ND
Carbon Disulfide	0.6		ND	ND	ND	ND
Allyl Chloride	0.5		ND	ND	ND	ND
Methylene Chloride	0.3	5	ND	ND	ND	ND
Acrylonitrile	1.0		ND	ND	ND	ND
t-1,2-Dichloroethene	0.3	100	ND	ND	ND	ND
Methyl -t-Butyl Ether	0.3		ND	ND	ND	ND
1,1-Dichloroethane	0.7		ND	ND	ND	ND
2,2-Dichloropropane	0.4		ND	ND	ND	ND
c-1,2-Dichloroethene	0.3	70	0.4	1.1	4.2	3.0
Methyl Ethyl Ketone	0.9		ND	ND	ND	ND
Propionitrile	0.7		ND	ND	ND	ND
Methyl Acrylate	0.8		ND	ND	ND	ND
Bromochloromethane	0.3		ND	ND	ND	ND
Methacrylonitrile	0.5		ND	ND	ND	ND
Tetrahydrofuran	0.4		ND	ND	ND	ND
Chloroform	0.3	TTHM*	ND	0.5	ND	ND
1,1,1-Trichloroethane	0.3	200	ND	ND	ND	ND
n-Butyl Chloride	0.4		ND	ND	ND	ND
Carbon Tetrachloride	0.3	5	ND	ND	ND	ND
1,1-Dichloropropene	0.3		ND	ND	ND	ND
Benzene	0.3	5	ND	ND	ND	ND
1,2-Dichloroethane	0.3	5	ND	ND	ND	ND
Trichloroethene	0.3	5	ND	0.7	2.2	0.9
1,2-Dichloropropane	0.3	5	ND	ND	ND	ND
Dibromomethane	0.3		ND	ND	ND	ND
Methyl Methacrylate	0.3		ND	ND	ND	ND
Bromodichloromethane	0.3	TTHM*	0.8	ND	ND	ND
2-Nitropropane	0.8		ND	ND	ND	ND
Chloroacetonitrile	0.6		ND	ND	ND	ND
c-1,3-Dichloropropene	0.3		ND	ND	ND	ND
4-Methyl 2-Pentanone	0.4		ND	ND	ND	ND
Ethyl Methacrylate	0.7		ND	ND	ND	ND
Dichloroacetone	0.4		ND	ND	ND	ND
Toluene	0.3	1000	ND	ND	ND	ND
t-1,3-Dichloropropene	0.3		ND	ND	ND	ND
1,1,2-Trichloroethane	0.3	5	ND	ND	ND	ND
Tetrachloroethene	0.4	5	ND	1.0	1.3	1.0
1,3-Dichloropropane	0.3		ND	ND	ND	ND
Methyl Butyl Ketone	0.5		ND	ND	ND	ND
Dibromochloromethane	0.3	TTHM*	1.4	ND	ND	ND

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).
NA = Data Not Available, Parameter failed to meet acceptable QC criteria.

Blank
6/27/00

CENTRAL REPORT

Sample Location:			WELL#3	WELL#4	WELL#5	WELL#6
Sample Date:			OUT	6/6/00	6/6/00	6/6/00
Sampled by:			OF	TW	TW	TW
Analysis Date:			SERVICE	6/6/00	6/6/00	6/6/00
Analyzed by:			JB	JB	JB	JB
	MDL	MCL				
WARNING NOTICES:						
Dichlorodifluoromethane	0.4		ND	ND	ND	ND
Chloromethane	0.5		ND	ND	ND	ND
Vinyl Chloride	0.3	2	ND	ND	ND	ND
Bromomethane	0.6		ND	ND	ND	ND
Chloroethane	0.4		ND	ND	ND	ND
Trichlorofluoromethane	0.3		ND	ND	ND	ND
Diethyl Ether	0.5		ND	ND	ND	ND
1,1-Dichloroethene	0.3	7	ND	ND	ND	ND
Acetone	1.9		ND	ND	ND	ND
Iodomethane	0.7		ND	ND	ND	ND
Carbon Disulfide	0.6		ND	ND	ND	ND
Allyl Chloride	0.5		ND	ND	ND	ND
Methylene Chloride	0.3	5	ND	ND	ND	ND
Acrylonitrile	1.0		ND	ND	ND	ND
t-1,2-Dichloroethene	0.3	100	ND	ND	ND	ND
Methyl -t-Butyl Ether	0.3		ND	ND	ND	ND
1,1-Dichloroethane	0.7		ND	ND	ND	ND
2,2-Dichloropropane	0.4		ND	ND	ND	ND
c-1,2-Dichloroethene	0.3	70	ND	0.4	ND	ND
Methyl Ethyl Ketone	0.9		ND	ND	ND	ND
Propionitrile	0.7		ND	ND	ND	ND
Methyl Acrylate	0.8		ND	ND	ND	ND
Bromochloromethane	0.3		ND	ND	ND	ND
Methacrylonitrile	0.5		ND	ND	ND	ND
Tetrahydrofuran	0.4		ND	ND	ND	ND
Chloroform	0.3	TTHM*	ND	ND	ND	ND
1,1,1-Trichloroethane	0.3	200	ND	ND	ND	ND
n-Butyl Chloride	0.4		ND	ND	ND	ND
Carbon Tetrachloride	0.3	5	ND	ND	ND	ND
1,1-Dichloropropene	0.3		ND	ND	ND	ND
Benzene	0.3	5	ND	ND	ND	ND
1,2-Dichloroethane	0.3	5	ND	ND	ND	ND
Trichloroethene	0.3	5	ND	ND	ND	ND
1,2-Dichloropropane	0.3	5	ND	ND	ND	ND
Dibromomethane	0.3		ND	ND	ND	ND
Methyl Methacrylate	0.3		ND	ND	ND	ND
Bromodichloromethane	0.3	TTHM*	ND	ND	ND	ND
2-Nitropropane	0.8		ND	ND	ND	ND
Chloroacetonitrile	0.6		ND	ND	ND	ND
c-1,3-Dichloropropene	0.3		ND	ND	ND	ND
4-Methyl 2-Pentanone	0.4		ND	ND	ND	ND
Ethyl Methacrylate	0.7		ND	ND	ND	ND
Dichloroacetone	0.4		ND	ND	ND	ND
Toluene	0.3	1000	ND	ND	ND	ND
t-1,3-Dichloropropene	0.3		ND	ND	ND	ND
1,1,2-Trichloroethane	0.3	5	ND	ND	ND	ND
Tetrachloroethene	0.4	5	ND	0.8	ND	ND
1,3-Dichloropropane	0.3		ND	ND	ND	ND
Methyl Butyl Ketone	0.5		ND	ND	ND	ND
Dibromochloromethane	0.3	TTHM*	ND	ND	ND	ND

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).
NA = Data Not Available, Parameter failed to meet acceptable QC criteria.

Blank
6/27/00

CENTRAL REPORT

Sample Location:			WELL#3	WELL#4	WELL#5	WELL#6
Sample Date:			OUT	6/6/00	6/6/00	6/6/00
Sampled by:			OF	TW	TW	TW
Analysis Date:			SERVICE	6/6/00	6/6/00	6/6/00
Analyzed by:			JB	JB	JB	JB
	MDL	MCL				
1,2-Dibromoethane	0.2		ND	ND	ND	ND
Chlorobenzene	0.3	100	ND	ND	ND	ND
1,1,1,2-Tetrachloroethene	0.3		ND	ND	ND	ND
Ethylbenzene	0.3	700	ND	ND	ND	ND
m&p-Xylene	0.6	XYLENES**	ND	ND	ND	ND
o-Xylene	0.3	XYLENES**	ND	ND	ND	ND
Styrene	0.5	100	ND	ND	ND	ND
Bromoform	0.4	TTHM*	ND	ND	ND	ND
Isopropyl Benzene	0.3		ND	ND	ND	ND
1,1,2,2-Tetrachlorethane	0.4		ND	ND	ND	ND
1,2,3-Trichloropropane	0.4		ND	ND	ND	ND
Bromobenzene	0.6		ND	ND	ND	ND
T-1,4-Dichloro-2-Butene	2.6		ND	ND	ND	ND
n-Propyl Benzene	0.3		ND	ND	ND	ND
2-Chloro Toluene	0.3		ND	ND	ND	ND
1,3,5-Trimethyl Benzene	0.3		ND	ND	ND	ND
4-Chloro Toluene	0.3		ND	ND	ND	ND
t-Butyl Benzene	0.3		ND	ND	ND	ND
1,2,4-Trimethyl Benzene	0.3		ND	ND	ND	ND
Pentachloroethane	0.6		ND	ND	ND	ND
sec-Butyl Benzene	0.3		ND	ND	ND	ND
p-Isopropyl Toluene	0.3		ND	ND	ND	ND
1,4-Dichlorobenzene	0.4	75	ND	ND	ND	ND
1,3-Dichlorobenzene	0.3		ND	ND	ND	ND
n-Butyl Benzene	0.4		ND	ND	ND	ND
1,2-Dichlorobenzene	0.5	600	ND	ND	ND	ND
Hexachloroethane	0.6		ND	ND	ND	ND
1,2-Dibromo-3-Chloro Propane	0.6		ND	ND	ND	ND
Nitrobenzene	1.2		ND	ND	ND	ND
1,2,4-Trichlorobenzene	0.4	70	ND	ND	ND	ND
Hexachlorobutadiene	0.6		ND	ND	ND	ND
Naphthalene	0.5		ND	ND	ND	ND
1,2,3-Trichloro Benzene	0.5		ND	ND	ND	ND
WARNING NOTICES:						

**TTHM = Regulated as Total Trihalomethanes with the total not to exceed 100 ug/L.*
***XYLENES= Regulated as Total Xylenes with the total not to exceed 10,000 ug/L.*

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).
NA = Data Not Available, Parameter failed to meet acceptable QC criteria.

Blank
6/27/00

SAMPLE	WELL DATE	1-1 5/10/1999	1-2 5/10/1999	1-4 5/10/1999	1-5 5/10/1999	1-3 5/11/1999	1-6 5/11/1999
pH	pH units	7.3	7.3	7.3	7.3	7.3	7.3
Temperature	C°	12.8	13.1	13.9	12.1	13	11.6
Temperature	F°	55.0	55.6	57.0	53.8	55.4	52.9
Ammonia Nitrogen	MG/l	0.009	0.030	0.195	0.018	0.017	0.021
Ortho Phosphorus	mg/L	0.01	0.00	0.00	0.00	0.04	0.02
Chloride	mg/L	92.67	111.24	92.11	57.08	66.15	52.81
Fluoride	mg/L	0.123	0.129	0.123	0.117	0.129	0.136
Total Hardness	grains/gal	24	25	23	23	22	22
Total Hardness	mg/L CaCO3	411	429	394	394	377	377
Alkalinity	mg CaCO3/L	293	293	286	260	278	284
Conductivity	umhos/cm	918	1006	932	774	815	769
Dissolved Oxygen	mg/L	0.85	0.9	0.9	0.8	0.6	0.65
Nitrate Nitrogen	mg/L	0	0.6	0.76	0.32	0.44	0.16
Nitrite Nitrogen	mg/L	0	0.01	0.01	0.01	0.01	0
Sulfate	mg/L	49	51	49	39	47	37
Cadmium	ug/L	<10	<10	<10	<10	<10	<10
Total Chromium	ug/L	<40	<40	<40	<40	<40	<40
Copper	ug/L	<40	<40	<40	<40	<40	<40
Lead	ug/L	<2	<2	<2	<2	<2	<2
Nickel	ug/L	<40	<40	<40	<40	<40	<40
Zinc	ug/L	<10	<10	<10	<10	<10	<10
Silver	ug/L	<10	<10	<10	<10	<10	<10
Mercury	ug/L	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
Selenium	ug/L	<5	<5	<5	<5	<5	<5
Cobalt	mgL	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05
Arsenic	ug/L	<2	<2	<2	<0.5	<2	<0.5
Iron	ug/L	430	890	980	330	<300	230
Sodium	mg/L	45.9	56.9	26.1	29.7	35	27.9
Calcium	mg/L	101	108	116	93.8	100	94.7
Magnesium	mg/L	31.7	31.5	31.0	27.9	25.8	28.2
Potassium	mg/L	2.0	2.7	1.9	1.7	2.7	1.7
Manganese	mg/L	0.125	0.116	0.205	0.083	0.07	0.061
Turbidity	NTU	1.74	2.05	0.44	0.53	0.20	1.15

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL#1	WELL#2
Sample Date:			6/21/99	6/21/99	6/21/99	6/21/99
Sampled by:			GT	GT	GT	GT
Analysis Date:			6/21/99	6/21/99	6/21/99	6/21/99
Analyzed by:			JB	JB	JB	JB
	MDL	MCL				
WARNING NOTICES:						
Dichlorodifluoromethane	0.4		ND	ND	ND	ND
Chloromethane	0.5		ND	ND	ND	ND
Vinyl Chloride	0.3	2	ND	ND	ND	ND
Bromomethane	0.6		ND	ND	ND	ND
Chloroethane	0.4		ND	ND	ND	ND
Trichlorofluoromethane	0.3		ND	ND	ND	ND
Diethyl Ether	0.5		ND	ND	ND	ND
1,1-Dichloroethene	0.3	7	ND	ND	ND	ND
Acetone	1.9		ND	ND	ND	ND
Iodomethane	0.7		ND	ND	ND	ND
Carbon Disulfide	0.6		ND	ND	ND	ND
Allyl Chloride	0.5		ND	ND	ND	ND
Methylene Chloride	0.3	5	ND	ND	ND	ND
Acrylonitrile	1.0		ND	ND	ND	ND
t-1,2-Dichloroethene	0.3	100	ND	ND	ND	ND
Methyl -t-Butyl Ether	0.3		ND	ND	ND	ND
1,1-Dichloroethane	0.7		ND	ND	ND	ND
2,2-Dichloropropane	0.4		ND	ND	ND	ND
c-1,2-Dichloroethene	0.3	70	0.4	0.8	2.8	3.4
Methyl Ethyl Ketone	0.9		ND	ND	ND	ND
Propionitrile	0.7		ND	ND	ND	ND
Methyl Acrylate	0.8		ND	ND	ND	ND
Bromochloromethane	0.3		ND	ND	ND	ND
Methacrylonitrile	0.5		ND	ND	ND	ND
Tetrahydrofuran	0.4		ND	ND	ND	ND
Chloroform	0.3	TTHM*	ND	ND	ND	ND
1,1,1-Trichloroethane	0.3	200	ND	ND	ND	ND
n-Butyl Chloride	0.4		ND	ND	ND	ND
Carbon Tetrachloride	0.3	5	ND	ND	ND	ND
1,1-Dichloropropene	0.3		ND	ND	ND	ND
Benzene	0.3	5	ND	ND	ND	ND
1,2-Dichloroethane	0.3	5	ND	ND	ND	ND
Trichloroethene	0.3	5	ND	0.5	1.6	1.1
1,2-Dichloropropane	0.3	5	ND	ND	ND	ND
Dibromomethane	0.3		ND	ND	ND	ND
Methyl Methacrylate	0.3		ND	ND	ND	ND
Bromodichloromethane	0.3	TTHM*	0.6	ND	ND	ND
2-Nitropropane	0.8		ND	ND	ND	ND
Chloroacetonitrile	0.6		ND	ND	ND	ND
c-1,3-Dichloropropene	0.3		ND	ND	ND	ND
4-Methyl 2-Pentanone	0.4		ND	ND	ND	ND
Ethyl Methacrylate	0.7		ND	ND	ND	ND
Dichloroacetone	0.4		ND	ND	ND	ND
Toluene	0.3	1000	ND	ND	ND	ND
t-1,3-Dichloropropene	0.3		ND	ND	ND	ND
1,1,2-Trichloroethane	0.3	5	ND	ND	ND	ND
Tetrachloroethene	0.4	5	ND	0.8	0.8	0.5
1,3-Dichloropropane	0.3		ND	ND	ND	ND
Methyl Butyl Ketone	0.5		ND	ND	ND	ND
Dibromochloromethane	0.3	TTHM*	1.2	ND	ND	ND

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).
NA = Data Not Available, Parameter failed to meet acceptable QC criteria.

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL#1	WELL#2
Sample Date:			6/21/99	6/21/99	6/21/99	6/21/99
Sampled by:			GT	GT	GT	GT
Analysis Date:			6/21/99	6/21/99	6/21/99	6/21/99
Analyzed by:			JB	JB	JB	JB
	MDL	MCL				
1,2-Dibromoethane	0.2		ND	ND	ND	ND
Chlorobenzene	0.3	100	ND	ND	ND	ND
1,1,1,2-Tetrachloroethene	0.3		ND	ND	ND	ND
Ethylbenzene	0.3	700	ND	ND	ND	ND
m&p-Xylene	0.6	XYLENES**	ND	ND	ND	ND
o-Xylene	0.3	XYLENES**	ND	ND	ND	ND
Styrene	0.5	100	ND	ND	ND	ND
Bromoform	0.4	TTHM*	0.8	ND	ND	ND
Isopropyl Benzene	0.3		ND	ND	ND	ND
1,1,2,2-Tetrachlorethane	0.4		ND	ND	ND	ND
1,2,3-Trichloropropane	0.4		ND	ND	ND	ND
Bromobenzene	0.6		ND	ND	ND	ND
T-1,4-Dichloro-2-Butene	2.6		ND	ND	ND	ND
n-Propyl Benzene	0.3		ND	ND	ND	ND
2-Chloro Toluene	0.3		ND	ND	ND	ND
1,3,5-Trimethyl Benzene	0.3		ND	ND	ND	ND
4-Chloro Toluene	0.3		ND	ND	ND	ND
t-Butyl Benzene	0.3		ND	ND	ND	ND
1,2,4-Trimethyl Benzene	0.3		ND	ND	ND	ND
Pentachloroethane	0.6		ND	ND	ND	ND
sec-Butyl Benzene	0.3		ND	ND	ND	ND
p-Isopropyl Toluene	0.3		ND	ND	ND	ND
1,4-Dichlorobenzene	0.4	75	ND	ND	ND	ND
1,3-Dichlorobenzene	0.3		ND	ND	ND	ND
n-Butyl Benzene	0.4		ND	ND	ND	ND
1,2-Dichlorobenzene	0.5	600	ND	ND	ND	ND
Hexachloroethane	0.6		ND	ND	ND	ND
1,2-Dibromo-3-Chloro Propane	0.6		ND	ND	ND	ND
Nitrobenzene	1.2		ND	ND	ND	ND
1,2,4-Trichlorobenzene	0.4	70	ND	ND	ND	ND
Hexachlorobutadiene	0.6		ND	ND	ND	ND
Naphthalene	0.5		ND	ND	ND	ND
1,2,3-Trichloro Benzene	0.5		ND	ND	ND	ND
WARNING NOTICES:						

**TTHM = Regulated as Total Trihalomethanes with the total not to exceed 100 ug/L.*
***XYLENES= Regulated as Total Xylenes with the total not to exceed 10,000 ug/L.*

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).
NA = Data Not Available, Parameter failed to meet acceptable QC criteria.

CENTRAL REPORT

Sample Location:			WELL#3	WELL#4	WELL#5	WELL#6
Sample Date:			6/21/99	6/25/99	6/21/99	6/21/99
Sampled by:			GT	TC	GT	GT
Analysis Date:			6/21/99	6/25/99	6/21/99	6/21/99
Analyzed by:			JB	JB	JB	JB
	MDL	MCL				
WARNING NOTICES:			OVER MCL			
Dichlorodifluoromethane	0.4		ND	ND	ND	ND
Chloromethane	0.5		ND	ND	ND	ND
Vinyl Chloride	0.3	2	ND	ND	ND	ND
Bromomethane	0.6		ND	ND	ND	ND
Chloroethane	0.4		ND	ND	ND	ND
Trichlorofluoromethane	0.3		ND	ND	ND	ND
Diethyl Ether	0.5		ND	ND	ND	ND
1,1-Dichloroethene	0.3	7	ND	ND	ND	ND
Acetone	1.9		ND	ND	ND	ND
Iodomethane	0.7		ND	ND	ND	ND
Carbon Disulfide	0.6		ND	ND	ND	ND
Allyl Chloride	0.5		ND	ND	ND	ND
Methylene Chloride	0.3	5	ND	ND	ND	ND
Acrylonitrile	1.0		ND	ND	ND	ND
t-1,2-Dichloroethene	0.3	100	ND	ND	ND	ND
Methyl -t-Butyl Ether	0.3		ND	ND	ND	ND
1,1-Dichloroethane	0.7		0.7	ND	ND	ND
2,2-Dichloropropane	0.4		ND	ND	ND	ND
c-1,2-Dichloroethene	0.3	70	ND	0.3	ND	ND
Methyl Ethyl Ketone	0.9		ND	ND	ND	ND
Propionitrile	0.7		ND	ND	ND	ND
Methyl Acrylate	0.8		ND	ND	ND	ND
Bromochloromethane	0.3		ND	ND	ND	ND
Methacrylonitrile	0.5		ND	ND	ND	ND
Tetrahydrofuran	0.4		ND	ND	ND	ND
Chloroform	0.3	TTHM*	ND	ND	ND	ND
1,1,1-Trichloroethane	0.3	200	1.6	ND	ND	ND
n-Butyl Chloride	0.4		ND	ND	ND	ND
Carbon Tetrachloride	0.3	5	ND	ND	ND	ND
1,1-Dichloropropene	0.3		ND	ND	ND	ND
Benzene	0.3	5	ND	ND	ND	ND
1,2-Dichloroethane	0.3	5	ND	ND	ND	ND
Trichloroethene	0.3	5	0.7	ND	ND	ND
1,2-Dichloropropane	0.3	5	ND	ND	ND	ND
Dibromomethane	0.3		ND	ND	ND	ND
Methyl Methacrylate	0.3		ND	ND	ND	ND
Bromodichloromethane	0.3	TTHM*	ND	ND	ND	ND
2-Nitropropane	0.8		ND	ND	ND	ND
Chloroacetonitrile	0.6		ND	ND	ND	ND
c-1,3-Dichloropropene	0.3		ND	ND	ND	ND
4-Methyl 2-Pentanone	0.4		ND	ND	ND	ND
Ethyl Methacrylate	0.7		ND	ND	ND	ND
Dichloroacetone	0.4		ND	ND	ND	ND
Toluene	0.3	1000	ND	ND	ND	ND
t-1,3-Dichloropropene	0.3		ND	ND	ND	ND
1,1,2-Trichloroethane	0.3	5	ND	ND	ND	ND
Tetrachloroethene	0.4	5	5.2	0.9	ND	ND
1,3-Dichloropropane	0.3		ND	ND	ND	ND
Methyl Butyl Ketone	0.5		ND	ND	ND	ND
Dibromochloromethane	0.3	TTHM*	ND	ND	ND	ND

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).
NA = Data Not Available, Parameter failed to meet acceptable QC criteria.

CENTRAL REPORT

Sample Location:			WELL#3	WELL#4	WELL#5	WELL#6
Sample Date:			6/21/99	6/25/99	6/21/99	6/21/99
Sampled by:			GT	TC	GT	GT
Analysis Date:			6/21/99	6/25/99	6/21/99	6/21/99
Analyzed by:			JB	JB	JB	JB
	MDL	MCL				
1,2-Dibromoethane	0.2		ND	ND	ND	ND
Chlorobenzene	0.3	100	ND	ND	ND	ND
1,1,1,2-Tetrachloroethene	0.3		ND	ND	ND	ND
Ethylbenzene	0.3	700	ND	ND	ND	ND
m&p-Xylene	0.6	XYLENES**	ND	ND	ND	ND
o-Xylene	0.3	XYLENES**	ND	ND	ND	ND
Styrene	0.5	100	ND	ND	ND	ND
Bromoform	0.4	TTHM*	ND	ND	ND	ND
Isopropyl Benzene	0.3		ND	ND	ND	ND
1,1,2,2-Tetrachlorethane	0.4		ND	ND	ND	ND
1,2,3-Trichloropropane	0.4		ND	ND	ND	ND
Bromobenzene	0.6		ND	ND	ND	ND
T-1,4-Dichloro-2-Butene	2.6		ND	ND	ND	ND
n-Propyl Benzene	0.3		ND	ND	ND	ND
2-Chloro Toluene	0.3		ND	ND	ND	ND
1,3,5-Trimethyl Benzene	0.3		ND	ND	ND	ND
4-Chloro Toluene	0.3		ND	ND	ND	ND
t-Butyl Benzene	0.3		ND	ND	ND	ND
1,2,4-Trimethyl Benzene	0.3		ND	ND	ND	ND
Pentachloroethane	0.6		ND	ND	ND	ND
sec-Butyl Benzene	0.3		ND	ND	ND	ND
p-Isopropyl Toluene	0.3		ND	ND	ND	ND
1,4-Dichlorobenzene	0.4	75	ND	ND	ND	ND
1,3-Dichlorobenzene	0.3		ND	ND	ND	ND
n-Butyl Benzene	0.4		ND	ND	ND	ND
1,2-Dichlorobenzene	0.5	600	ND	ND	ND	ND
Hexachloroethane	0.6		ND	ND	ND	ND
1,2-Dibromo-3-Chloro Propane	0.6		ND	ND	ND	ND
Nitrobenzene	1.2		ND	ND	ND	ND
1,2,4-Trichlorobenzene	0.4	70	ND	ND	ND	ND
Hexachlorobutadiene	0.6		ND	ND	ND	ND
Naphthalene	0.5		ND	ND	ND	ND
1,2,3-Trichloro Benzene	0.5		ND	ND	ND	ND
WARNING NOTICES:			OVER MCL			

**TTHM = Regulated as Total Trihalomethanes with the total not to exceed 100 ug/L.*
***XYLENES= Regulated as Total Xylenes with the total not to exceed 10,000 ug/L.*

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).
NA = Data Not Available, Parameter failed to meet acceptable QC criteria.

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #2
Sample Date:			6/9/98	6/9/98	6/22/98	6/9/98
Sampled by:			PM	PM	PM	PM
Analysis Date:			6/9/98	6/9/98	6/26/98	6/9/98
Analyzed by:			KL	KL	KL	KL
	MDL	MCL				
WARNING NOTICES:						
Dichlorodifluoromethane	0.4		ND	ND	ND	ND
Chloromethane	0.5		ND	ND	ND	ND
Vinyl Chloride	0.3	2	ND	ND	ND	ND
Bromomethane	0.6		ND	ND	ND	ND
Chloroethane	0.4		ND	ND	0.9	ND
Trichlorofluoromethane	0.3		ND	ND	ND	ND
Diethyl Ether	0.5		ND	ND	ND	ND
1,1-Dichloroethene	0.3	7	ND	ND	ND	ND
Acetone	1.9		ND	ND	ND	ND
Iodomethane	0.7		ND	ND	ND	ND
Carbon Disulfide	0.6		ND	ND	ND	ND
Allyl Chloride	0.5		ND	ND	ND	ND
Methylene Chloride	0.3	5	ND	ND	ND	ND
Acrylonitrile	1.0		ND	ND	ND	ND
t-1,2-Dichloroethene	0.3	100	ND	ND	ND	ND
Methyl -t-Butyl Ether	0.3		ND	ND	ND	ND
1,1-Dichloroethane	0.7		ND	ND	ND	ND
2,2-Dichloropropane	0.4		ND	ND	ND	ND
c-1,2-Dichloroethene	0.3	70	0.4	1.2	4.0	4.6
Methyl Ethyl Ketone	0.9		ND	ND	ND	ND
Propionitrile	0.7		ND	ND	ND	ND
Methyl Acrylate	0.8		ND	ND	ND	ND
Bromochloromethane	0.3		ND	ND	ND	ND
Methacrylonitrile	0.5		ND	ND	ND	ND
Tetrahydrofuran	0.4		ND	ND	ND	0.5
Chloroform	0.3	TTHM*	ND	ND	ND	ND
1,1,1-Trichloroethane	0.3	200	ND	0.9	ND	ND
n-Butyl Chloride	0.4		ND	ND	ND	ND
Carbon Tetrachloride	0.3	5	ND	ND	ND	ND
1,1-Dichloropropene	0.3		ND	ND	ND	ND
Benzene	0.3	5	ND	ND	ND	ND
1,2-Dichloroethane	0.3	5	ND	ND	ND	ND
Trichloroethene	0.3	5	ND	0.9	2.0	1.9
1,2-Dichloropropane	0.3	5	ND	ND	ND	ND
Dibromomethane	0.3		ND	ND	ND	ND
Methyl Methacrylate	0.3		ND	ND	ND	ND
Bromodichloromethane	0.3	TTHM*	0.9	ND	ND	ND
2-Nitropropane	0.8		ND	ND	ND	ND
Chloroacetonitrile	0.6		ND	ND	ND	ND
c-1,3-Dichloropropene	0.3		ND	ND	ND	ND
4-Methyl 2-Pentanone	0.4		ND	ND	ND	ND
Ethyl Methacrylate	0.7		ND	ND	ND	ND
Dichloroacetone	0.4		ND	ND	ND	ND
Toluene	0.3	1000	ND	ND	ND	ND
t-1,3-Dichloropropene	0.3		ND	ND	ND	ND
1,1,2-Trichloroethane	0.3	5	ND	ND	ND	ND
Tetrachloroethene	0.4	5	ND	1.6	1.2	0.8
1,3-Dichloropropane	0.3		ND	ND	ND	ND

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).
NA = Data Not Available, Parameter failed to meet acceptable QC criteria.

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #2
Sample Date:			6/9/98	6/9/98	6/22/98	6/9/98
Sampled by:			PM	PM	PM	PM
Analysis Date:			6/9/98	6/9/98	6/26/98	6/9/98
Analyzed by:			KL	KL	KL	KL
	MDL	MCL				
Methyl Butyl Ketone	0.5		ND	ND	ND	ND
Dibromochloromethane	0.3	TTHM*	1.2	ND	ND	ND
1,2-Dibromoethane	0.2		ND	ND	ND	ND
Chlorobenzene	0.3	100	ND	ND	ND	ND
1,1,1,2-Tetrachloroethene	0.3		ND	ND	ND	ND
Ethylbenzene	0.3	700	ND	ND	ND	ND
m&p-Xylene	0.6	XYLENES**	ND	ND	ND	ND
o-Xylene	0.3	XYLENES**	ND	ND	ND	ND
Styrene	0.5	100	ND	ND	ND	ND
Bromoform	0.4	TTHM*	ND	ND	ND	ND
Isopropyl Benzene	0.3		ND	ND	ND	ND
1,1,2,2-Tetrachlorethane	0.4		ND	ND	ND	ND
1,2,3-Trichloropropane	0.4		ND	ND	ND	ND
Bromobenzene	0.6		ND	ND	ND	ND
T-1,4-Dichloro-2-Butene	2.6		ND	ND	ND	ND
n-Propyl Benzene	0.3		ND	ND	ND	ND
2-Chloro Toluene	0.3		ND	ND	ND	ND
1,3,5-Trimethyl Benzene	0.3		ND	ND	ND	ND
4-Chloro Toluene	0.3		ND	ND	ND	ND
t-Butyl Benzene	0.3		ND	ND	ND	ND
1,2,4-Trimethyl Benzene	0.3		ND	ND	ND	ND
Pentachloroethane	0.6		ND	ND	ND	ND
sec-Butyl Benzene	0.3		ND	ND	ND	ND
p-Isopropyl Toluene	0.3		ND	ND	ND	ND
1,4-Dichlorobenzene	0.4	75	ND	ND	ND	ND
1,3-Dichlorobenzene	0.3		ND	ND	ND	ND
n-Butyl Benzene	0.4		ND	ND	ND	ND
1,2-Dichlorobenzene	0.5	600	ND	ND	ND	ND
Hexachloroethane	0.6		ND	ND	ND	ND
1,2-Dibromo-3-Chloro Propane	0.6		ND	ND	ND	ND
Nitrobenzene	1.2		ND	ND	ND	ND
1,2,4-Trichlorobenzene	0.4	70	ND	ND	ND	ND
Hexachlorobutadiene	0.6		ND	ND	ND	ND
Naphthalene	0.5		ND	ND	ND	ND
1,2,3-Trichloro Benzene	0.5		ND	ND	ND	ND
WARNING NOTICES:						

**TTHM = Regulated as Total Trihalomethanes with the total not to exceed 100 ug/L.*
***XYLENES = Regulated as Total Xylenes with the total not to exceed 10,000 ug/L.*

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).
NA = Data Not Available, Parameter failed to meet acceptable QC criteria.

CENTRAL REPORT

Sample Location:			WELL #3	WELL #4	WELL #5	WELL #6
Sample Date:			6/9/98	6/9/98	6/22/98	6/9/98
Sampled by:			PM	PM	PM	PM
Analysis Date:			6/9/98	6/9/98	6/26/98	6/9/98
Analyzed by:			KL	KL	KL	KL
	MDL	MCL				
WARNING NOTICES:			OVER MCL			
Dichlorodifluoromethane	0.4		ND	ND	ND	ND
Chloromethane	0.5		ND	ND	ND	ND
Vinyl Chloride	0.3	2	ND	ND	ND	ND
Bromomethane	0.6		ND	ND	ND	ND
Chloroethane	0.4		ND	ND	ND	ND
Trichlorofluoromethane	0.3		ND	ND	ND	ND
Diethyl Ether	0.5		ND	ND	ND	ND
1,1-Dichloroethene	0.3	7	ND	ND	ND	ND
Acetone	1.9		ND	ND	ND	ND
Iodomethane	0.7		ND	ND	ND	ND
Carbon Disulfide	0.6		ND	ND	ND	ND
Allyl Chloride	0.5		ND	ND	ND	ND
Methylene Chloride	0.3	5	ND	ND	ND	ND
Acrylonitrile	1.0		ND	ND	ND	ND
t-1,2-Dichloroethene	0.3	100	ND	ND	ND	ND
Methyl -t-Butyl Ether	0.3		ND	ND	ND	ND
1,1-Dichloroethane	0.7		1.1	ND	ND	ND
2,2-Dichloropropane	0.4		ND	ND	ND	ND
c-1,2-Dichloroethene	0.3	70	ND	ND	ND	ND
Methyl Ethyl Ketone	0.9		ND	ND	ND	ND
Propionitrile	0.7		ND	ND	ND	ND
Methyl Acrylate	0.8		ND	ND	ND	ND
Bromochloromethane	0.3		ND	ND	ND	ND
Methacrylonitrile	0.5		ND	ND	ND	ND
Tetrahydrofuran	0.4		ND	ND	ND	ND
Chloroform	0.3	TTHM*	ND	ND	ND	ND
1,1,1-Trichloroethane	0.3	200	3.4	ND	ND	ND
n-Butyl Chloride	0.4		ND	ND	ND	ND
Carbon Tetrachloride	0.3	5	ND	ND	ND	ND
1,1-Dichloropropene	0.3		ND	ND	ND	ND
Benzene	0.3	5	ND	ND	ND	ND
1,2-Dichloroethane	0.3	5	ND	ND	ND	ND
Trichloroethene	0.3	5	1.4	ND	ND	ND
1,2-Dichloropropane	0.3	5	ND	ND	ND	ND
Dibromomethane	0.3		ND	ND	ND	ND
Methyl Methacrylate	0.3		ND	ND	ND	ND
Bromodichloromethane	0.3	TTHM*	ND	ND	ND	ND
2-Nitropropane	0.8		ND	ND	ND	ND
Chloroacetonitrile	0.6		ND	ND	ND	ND
c-1,3-Dichloropropene	0.3		ND	ND	ND	ND
4-Methyl 2-Pentanone	0.4		ND	ND	ND	ND
Ethyl Methacrylate	0.7		ND	ND	ND	ND
Dichloroacetone	0.4		ND	ND	ND	ND
Toluene	0.3	1000	ND	ND	ND	ND
t-1,3-Dichloropropene	0.3		ND	ND	ND	ND
1,1,2-Trichloroethane	0.3	5	ND	ND	ND	ND
Tetrachloroethene	0.4	5	5.7	0.8	ND	ND
1,3-Dichloropropane	0.3		ND	ND	ND	ND

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).
NA = Data Not Available, Parameter failed to meet acceptable QC criteria.

CENTRAL REPORT

Sample Location:			WELL #3	WELL #4	WELL #5	WELL #6
Sample Date:			6/9/98	6/9/98	6/22/98	6/9/98
Sampled by:			PM	PM	PM	PM
Analysis Date:			6/9/98	6/9/98	6/26/98	6/9/98
Analyzed by:			KL	KL	KL	KL
	MDL	MCL				
Methyl Butyl Ketone	0.5		ND	ND	ND	ND
Dibromochloromethane	0.3	TTHM*	ND	ND	ND	ND
1,2-Dibromoethane	0.2		ND	ND	ND	ND
Chlorobenzene	0.3	100	ND	ND	ND	ND
1,1,1,2-Tetrachloroethene	0.3		ND	ND	ND	ND
Ethylbenzene	0.3	700	ND	ND	ND	ND
m&p-Xylene	0.6	XYLENES**	ND	ND	ND	ND
o-Xylene	0.3	XYLENES**	ND	ND	ND	ND
Styrene	0.5	100	ND	ND	ND	ND
Bromoform	0.4	TTHM*	ND	ND	ND	ND
Isopropyl Benzene	0.3		ND	ND	ND	ND
1,1,2,2-Tetrachlorethane	0.4		ND	ND	ND	ND
1,2,3-Trichloropropane	0.4		ND	ND	ND	ND
Bromobenzene	0.6		ND	ND	ND	ND
T-1,4-Dichloro-2-Butene	2.6		ND	ND	ND	ND
n-Propyl Benzene	0.3		ND	ND	ND	ND
2-Chloro Toluene	0.3		ND	ND	ND	ND
1,3,5-Trimethyl Benzene	0.3		ND	ND	ND	ND
4-Chloro Toluene	0.3		ND	ND	ND	ND
t-Butyl Benzene	0.3		ND	ND	ND	ND
1,2,4-Trimethyl Benzene	0.3		ND	ND	ND	ND
Pentachloroethane	0.6		ND	ND	ND	ND
sec-Butyl Benzene	0.3		ND	ND	ND	ND
p-Isopropyl Toluene	0.3		ND	ND	ND	ND
1,4-Dichlorobenzene	0.4	75	ND	ND	ND	ND
1,3-Dichlorobenzene	0.3		ND	ND	ND	ND
n-Butyl Benzene	0.4		ND	ND	ND	ND
1,2-Dichlorobenzene	0.5	600	ND	ND	ND	ND
Hexachloroethane	0.6		ND	ND	ND	ND
1,2-Dibromo-3-Chloro Propane	0.6		ND	ND	ND	ND
Nitrobenzene	1.2		ND	ND	ND	ND
1,2,4-Trichlorobenzene	0.4	70	ND	ND	ND	ND
Hexachlorobutadiene	0.6		ND	ND	ND	ND
Naphthalene	0.5		ND	ND	ND	ND
1,2,3-Trichloro Benzene	0.5		ND	ND	ND	ND
WARNING NOTICES:			OVER MCL			

**TTHM = Regulated as Total Trihalomethanes with the total not to exceed 100 ug/L.*
***XYLENES = Regulated as Total Xylenes with the total not to exceed 10,000 ug/L.*

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).
NA = Data Not Available, Parameter failed to meet acceptable QC criteria.

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #2	WELL #4	WELL #6
Sample Date:			6/2/97	6/2/97	6/2/97	6/2/97	6/2/97	6/2/97
Sampled by:			GT	GT	GT	GT	GT	GT
Analysis Date:			6/4/97	6/4/97	6/4/97	6/4/97	6/4/97	6/4/97
Analyzed by:			KL	KL	KL	KL	KL	KL
	MDL	MCL						
WARNING NOTICES:								
Dichlorodifluoromethane	0.3		ND	ND	ND	ND	ND	ND
Chloromethane	0.6		ND	ND	ND	ND	ND	ND
Vinyl Chloride	0.2	2	ND	ND	ND	ND	ND	ND
Bromomethane	0.4		ND	ND	ND	ND	ND	ND
Chloroethane	0.4		ND	ND	ND	ND	ND	ND
Trichlorofluoromethane	0.2		ND	ND	ND	ND	ND	ND
Diethyl Ether	0.5		ND	ND	ND	ND	ND	ND
1,1-Dichloroethene	0.3	7	ND	ND	ND	ND	ND	ND
Acetone	0.8		ND	ND	ND	ND	ND	ND
Iodomethane	0.6		NA	NA	NA	NA	NA	NA
Carbon Disulfide	1.1		NA	NA	NA	NA	NA	NA
Allyl Chloride	0.3		ND	ND	ND	ND	ND	ND
Methylene Chloride	0.4	5	ND	ND	ND	ND	ND	ND
Acrylonitrile	1.0		ND	ND	ND	ND	ND	ND
t-1,2-Dichloroethene	0.3	100	ND	ND	ND	ND	ND	ND
Methyl -t-Butyl Ether	0.4		ND	ND	ND	ND	ND	ND
1,1-Dichloroethane	**0.2**		**ND**	**ND**	**ND**	**0.4**	**0.4**	**ND**
2,2-Dichloropropane	1.0		ND	ND	ND	ND	ND	ND
c-1,2-Dichloroethene	**0.2**	**70**	**0.5**	**2.1**	**5.9**	**2.7**	**0.3**	**ND**
Methyl Ethyl Ketone	0.8		ND	ND	ND	ND	ND	ND
Propionitrile	0.3		ND	ND	ND	ND	ND	ND
Methyl Acrylate	0.3		ND	ND	ND	ND	ND	ND
Bromochloromethane	0.3		ND	ND	ND	ND	ND	ND
Methacrylonitrile	0.3		ND	ND	ND	ND	ND	ND
Tetrahydrofuran	0.5		ND	ND	ND	ND	ND	ND
Chloroform	0.2	TTHM*	ND	ND	ND	ND	ND	ND
1,1,1-Trichloroethane	**0.3**	**200**	**ND**	**ND**	**ND**	**0.4**	**0.6**	**ND**
n-Butyl Chloride	0.3		ND	ND	ND	ND	ND	ND
Carbon Tetrachloride	0.1	5	ND	ND	ND	ND	ND	ND
1,1-Dichloropropene	0.2		ND	ND	ND	ND	ND	ND
Benzene	0.2	5	ND	ND	ND	ND	ND	ND
1,2-Dichloroethane	0.3	5	ND	ND	ND	ND	ND	ND
Trichloroethene	**0.1**	**5**	**ND**	**0.8**	**2.0**	**0.8**	**0.2**	**ND**
1,2-Dichloropropane	0.4	5	ND	ND	ND	ND	ND	ND
Dibromomethane	0.3		ND	ND	ND	ND	ND	ND
Methyl Methacrylate	0.2		ND	ND	ND	ND	ND	ND
Bromodichloromethane	0.3	TTHM*	ND	ND	ND	ND	ND	ND
2-Nitropropane	0.3		ND	ND	ND	ND	ND	ND
Chloroacetonitrile	0.4		ND	ND	ND	ND	ND	ND
c-1,3-Dichloropropene	0.2		ND	ND	ND	ND	ND	ND
4-Methyl 2-Pentanone	0.3		ND	ND	ND	ND	ND	ND
Ethyl Methacrylate	0.3		ND	ND	ND	ND	ND	ND
Dichloroacetone	0.3		ND	ND	ND	ND	ND	ND
Toluene	0.2	1000	ND	ND	ND	ND	ND	ND
t-1,3-Dichloropropene	0.2		ND	ND	ND	ND	ND	ND
1,1,2-Trichloroethane	0.3	5	ND	ND	ND	ND	ND	ND
Tetrachloroethene	**0.4**	**5**	**ND**	**0.6**	**0.9**	**0.8**	**0.7**	**ND**
1,3-Dichloropropane	0.2		ND	ND	ND	ND	ND	ND
Methyl Butyl Ketone	0.4		ND	ND	ND	ND	ND	ND
Dibromochloromethane	0.3	TTHM*	ND	ND	ND	ND	ND	ND

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).
NA = Data Not Available, Parameter failed to meet acceptable QC criteria.

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #2	WELL #4	WELL #6
Sample Date:			6/2/97	6/2/97	6/2/97	6/2/97	6/2/97	6/2/97
Sampled by:			GT	GT	GT	GT	GT	GT
Analysis Date:			6/4/97	6/4/97	6/4/97	6/4/97	6/4/97	6/4/97
Analyzed by:			KL	KL	KL	KL	KL	KL
	MDL	MCL						
1,2-Dibromoethane	0.1		ND	ND	ND	ND	ND	ND
Chlorobenzene	0.3	100	ND	ND	ND	ND	ND	ND
1,1,1,2-Tetrachloroethene	0.3		ND	ND	ND	ND	ND	ND
Ethylbenzene	0.1	700	ND	ND	ND	ND	ND	ND
m&p-Xylene	0.3	XYLENES**	ND	ND	ND	ND	ND	ND
o-Xylene	0.1	XYLENES**	ND	ND	ND	ND	ND	ND
Styrene	0.2	100	ND	ND	ND	ND	ND	ND
Bromoform	0.2	TTHM*	ND	ND	ND	ND	ND	ND
Isopropyl Benzene	0.2		ND	ND	ND	ND	ND	ND
1,1,2,2-Tetrachlorethane	0.2		ND	ND	ND	ND	ND	ND
1,2,3-Trichloropropane	0.2		ND	ND	ND	ND	ND	ND
Bromobenzene	0.2		ND	ND	ND	ND	ND	ND
T-1,4-Dichloro-2-Butene	0.7		ND	ND	ND	ND	ND	ND
n-Propyl Benzene	0.1		ND	ND	ND	ND	ND	ND
2-Chloro Toluene	0.2		ND	ND	ND	ND	ND	ND
1,3,5-Trimethyl Benzene	0.2		ND	ND	ND	ND	ND	ND
4-Chloro Toluene	0.2		ND	ND	ND	ND	ND	ND
t-Butyl Benzene	0.2		ND	ND	ND	ND	ND	ND
1,2,4-Trimethyl Benzene	0.3		ND	ND	ND	ND	ND	ND
Pentachloroethane	1.0		ND	ND	ND	ND	ND	ND
sec-Butyl Benzene	0.1		ND	ND	ND	ND	ND	ND
p-Isopropyl Toluene	0.1		ND	ND	ND	ND	ND	ND
1,4-Dichlorobenzene	0.2	75	ND	ND	ND	ND	ND	ND
1,3-Dichlorobenzene	0.2		ND	ND	ND	ND	ND	ND
n-Butyl Benzene	0.3		ND	ND	ND	ND	ND	ND
1,2-Dichlorobenzene	0.2	600	ND	ND	ND	ND	ND	ND
Hexachloroethane	0.3		ND	ND	ND	ND	ND	ND
1,2-Dibromo-3-Chloro Propane	0.3		ND	ND	ND	ND	ND	ND
Nitrobenzene	1.0		ND	ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	0.1	70	ND	ND	ND	ND	ND	ND
Hexachlorobutadiene	0.3		ND	ND	ND	ND	ND	ND
Naphthalene	0.3		ND	ND	ND	ND	ND	ND
1,2,3-Trichloro Benzene	0.1		ND	ND	ND	ND	ND	ND
WARNING NOTICES:								

**TTHM = Regulated as Total Trihalomethanes with the total not to exceed 100 ug/L.*
***XYLENES= Regulated as Total Xylenes with the total not to exceed 10,000 ug/L.*

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).
NA = Data Not Available, Parameter failed to meet acceptable QC criteria.

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #2	WELL #4	WELL #6
Sample Date:			6/9/97	6/9/97	6/9/97	6/9/97	6/9/97	6/9/97
Sampled by:			GT	GT	GT	GT	GT	GT
Analysis Date:			6/9/97	6/9/97	6/9/97	6/9/97	6/9/97	6/9/97
Analyzed by			KL	KL	KL	KL	KL	KL
	MDL	MCL						
WARNING NOTICES:								
Dichlorodifluoromethane	0.3		ND	ND	ND	ND	ND	ND
Chloromethane	0.6		ND	ND	ND	ND	ND	ND
Vinyl Chloride	0.2	2	ND	ND	ND	ND	ND	ND
Bromomethane	0.4		ND	ND	ND	ND	ND	ND
Chloroethane	**0.4**		**ND**	**ND**	**2.0**	**ND**	**ND**	**2.6**
Trichlorofluoromethane	0.2		ND	ND	ND	ND	ND	ND
Diethyl Ether	0.5		ND	ND	ND	ND	ND	ND
1,1-Dichloroethene	0.3	7	ND	ND	ND	ND	ND	ND
Acetone	0.8		ND	ND	ND	ND	ND	ND
Iodomethane	0.6		ND	ND	ND	ND	ND	ND
Carbon Disulfide	1.1		ND	ND	ND	ND	ND	ND
Ally Chloride	0.3		ND	ND	ND	ND	ND	ND
Methylene Chloride	0.4	5	ND	ND	ND	ND	ND	ND
Acrylonitrile	1.0		ND	ND	ND	ND	ND	ND
t-1,2-Dichloroethene	0.3	100	ND	ND	ND	ND	ND	ND
Methyl -t-Butyl Ether	0.4		ND	ND	ND	ND	ND	ND
1,1-Dichloroethane	**0.2**		**ND**	**ND**	**ND**	**0.3**	**0.3**	**ND**
2,2-Dichloropropane	1.0		ND	ND	ND	ND	ND	ND
c-1,2-Dichloroethene	**0.2**	**70**	**0.4**	**1.9**	**4.6**	**3.2**	**0.4**	**ND**
Methyl Ethyl Ketone	0.8		ND	ND	ND	ND	ND	ND
Propionitrile	0.3		ND	ND	ND	ND	ND	ND
Methyl Acrylate	0.3		ND	ND	ND	ND	ND	ND
Bromochloromethane	0.3		ND	ND	ND	ND	ND	ND
Methacrylonitrile	0.3		ND	ND	ND	ND	ND	ND
Tetrahydrofuran	0.5		ND	ND	ND	ND	ND	ND
Chloroform	**0.2**	**TTHM***	**1.0**	**ND**	**ND**	**ND**	**ND**	**ND**
1,1,1-Trichloroethane	**0.3**	**200**	**ND**	**ND**	**ND**	**0.4**	**0.6**	**ND**
n-Butyl Chloride	0.3		ND	ND	ND	ND	ND	ND
Carbon Tetrachloride	0.1	5	ND	ND	ND	ND	ND	ND
1,1-Dichloropropene	0.2		ND	ND	ND	ND	ND	ND
Benzene	0.2	5	ND	ND	ND	ND	ND	ND
1,2-Dichloroethane	0.3	5	ND	ND	ND	ND	ND	ND
Trichloroethene	**0.1**	**5**	**ND**	**0.7**	**1.6**	**0.9**	**0.2**	**ND**
1,2-Dichloropropane	0.4	5	ND	ND	ND	ND	ND	ND
Dibromomethane	0.3		ND	ND	ND	ND	ND	ND
Methyl Methacrylate	0.2		ND	ND	ND	ND	ND	ND
Bromodichloromethane	**0.3**	**TTHM***	**2.3**	**ND**	**ND**	**ND**	**ND**	**ND**
2-Nitropropane	0.3		ND	ND	ND	ND	ND	ND
Chloroacetonitrile	**0.4**		**0.6**	**ND**	**ND**	**ND**	**ND**	**ND**
c-1,3-Dichloropropene	0.2		ND	ND	ND	ND	ND	ND
4-Methyl 2-Pentanone	0.3		ND	ND	ND	ND	ND	ND
Ethyl Methacrylate	0.3		ND	ND	ND	ND	ND	ND
Dichloroacetone	0.3		ND	ND	ND	ND	ND	ND
Toluene	0.2	1000	ND	ND	ND	ND	ND	ND
t-1,3-Dichloropropene	0.2		ND	ND	ND	ND	ND	ND
1,1,2-Trichloroethane	0.3	5	ND	ND	ND	ND	ND	ND
Tetrachloroethene	**0.4**	**5**	**ND**	**0.7**	**0.9**	**0.9**	**0.8**	**ND**
1,3-Dichloropropane	0.2		ND	ND	ND	ND	ND	ND
Methyl Butyl Ketone	0.4		ND	ND	ND	ND	ND	ND
Dibromochloromethane	**0.3**	**TTHM***	**2.9**	**ND**	**ND**	**ND**	**ND**	**ND**

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).
NA = Data Not Available, Parameter failed to meet acceptable QC criteria.

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #2	WELL #4	WELL #6
Sample Date:			6/9/97	6/9/97	6/9/97	6/9/97	6/9/97	6/9/97
Sampled by:			GT	GT	GT	GT	GT	GT
Analysis Date:			6/9/97	6/9/97	6/9/97	6/9/97	6/9/97	6/9/97
Analyzed by:			KL	KL	KL	KL	KL	KL
	MDL	MCL						
1,2-Dibromoethane	0.1		ND	ND	ND	ND	ND	ND
Chlorobenzene	0.3	100	ND	ND	ND	ND	ND	ND
1,1,1,2-Tetrachloroethene	0.3		ND	ND	ND	ND	ND	ND
Ethylbenzene	0.1	700	ND	ND	ND	ND	ND	ND
m&p-Xylene	0.3	XYLENES**	ND	ND	ND	ND	ND	ND
o-Xylene	0.1	XYLENES**	ND	ND	ND	ND	ND	ND
Styrene	0.2	100	ND	ND	ND	ND	ND	ND
Bromoform	**0.2**	**TTHM***	**1.3**	**ND**	**ND**	**ND**	**ND**	**ND**
Isopropyl Benzene	0.2		ND	ND	ND	ND	ND	ND
1,1,2,2-Tetrachlorethane	0.2		ND	ND	ND	ND	ND	ND
1,2,3-Trichloropropane	0.2		ND	ND	ND	ND	ND	ND
Bromobenzene	0.2		ND	ND	ND	ND	ND	ND
T-1,4-Dichloro-2-Butene	0.7		ND	ND	ND	ND	ND	ND
n-Propyl Benzene	0.1		ND	ND	ND	ND	ND	ND
2-Chloro Toluene	0.2		ND	ND	ND	ND	ND	ND
1,3,5-Trimethyl Benzene	0.2		ND	ND	ND	ND	ND	ND
4-Chloro Toluene	0.2		ND	ND	ND	ND	ND	ND
t-Butyl Benzene	0.2		ND	ND	ND	ND	ND	ND
1,2,4-Trimethyl Benzene	0.3		ND	ND	ND	ND	ND	ND
Pentachloroethane	1.0		ND	ND	ND	ND	ND	ND
sec-Butyl Benzene	0.1		ND	ND	ND	ND	ND	ND
p-Isopropyl Toluene	0.1		ND	ND	ND	ND	ND	ND
1,4-Dichlorobenzene	0.2	75	ND	ND	ND	ND	ND	ND
1,3-Dichlorobenzene	0.2		ND	ND	ND	ND	ND	ND
n-Butyl Benzene	0.3		ND	ND	ND	ND	ND	ND
1,2-Dichlorobenzene	0.2	600	ND	ND	ND	ND	ND	ND
Hexachloroethane	0.3		ND	ND	ND	ND	ND	ND
1,2-Dibromo-3-Chloro Propane	0.3		ND	ND	ND	ND	ND	ND
Nitrobenzene	1.0		ND	ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	0.1	70	ND	ND	ND	ND	ND	ND
Hexachlorobutadiene	0.3		ND	ND	ND	ND	ND	ND
Naphthalene	0.3		ND	ND	ND	ND	ND	ND
1,2,3-Trichloro Benzene	0.1		ND	ND	ND	ND	ND	ND
WARNING NOTICES:								

**TTHM = Regulated as Total Trihalomethanes with the total not to exceed 100 ug/L*
***XYLENES= Regulated as Total Xylenes with the total not to exceed 10,000 ug/L*

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).
NA = Data Not Available, Parameter failed to meet acceptable QC criteria.

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #4	WELL #6
Sample Date:			6/16/97	6/16/97	6/16/97	6/16/97	6/16/97
Sampled by:			GT	GT	GT	GT	GT
Analysis Date:			6/18/97	6/18/97	6/18/97	6/18/97	6/18/97
Analyzed by:			KL	KL	KL	KL	KL
	MDL	MCL					
MCL WARNING NOTICES:							
Dichlorodifluoromethane	0.3		ND	ND	ND	ND	ND
Chloromethane	0.6		ND	ND	ND	ND	ND
Vinyl Chloride	0.2	2	ND	ND	ND	ND	ND
Bromomethane	0.4		ND	ND	ND	ND	ND
Chloroethane	0.4		ND	ND	ND	ND	ND
Trichlorofluoromethane	0.2		ND	ND	ND	ND	ND
Diethyl Ether	0.5		ND	ND	ND	ND	ND
1,1-Dichloroethene	0.3	7	ND	ND	ND	ND	ND
Acetone	0.8		ND	ND	ND	ND	ND
Iodomethane	0.6		ND	ND	ND	ND	ND
Carbon Disulfide	1.1		ND	ND	ND	ND	ND
Allyl Chloride	0.3		ND	ND	ND	ND	ND
Methylene Chloride	0.4	5	ND	ND	ND	ND	ND
Acrylonitrile	1.0		ND	ND	ND	ND	ND
t-1,2-Dichloroethene	0.3	100	ND	ND	ND	ND	ND
Methyl -t-Butyl Ether	0.4		ND	ND	ND	ND	ND
1,1-Dichloroethane	**0.2**		**ND**	**0.5**	**ND**	**0.4**	**ND**
2,2-Dichloropropane	1.0		ND	ND	ND	ND	ND
c-1,2-Dichloroethene	**0.2**	**70**	**0.4**	**1.7**	**6.5**	**0.4**	**ND**
Methyl Ethyl Ketone	0.8		ND	ND	ND	ND	ND
Propionitrile	0.3		NA	ND	ND	ND	ND
Methyl Acrylate	0.3		ND	ND	ND	ND	ND
Bromochloromethane	0.3		ND	ND	ND	ND	ND
Methacrylonitrile	0.3		ND	ND	ND	ND	ND
Tetrahydrofuran	0.5		ND	ND	ND	ND	ND
Chloroform	**0.2**	**TTHM***	**0.7**	**ND**	**ND**	**ND**	**ND**
1,1,1-Trichloroethane	**0.3**	**200**	**ND**	**1.0**	**ND**	**0.5**	**ND**
n-Butyl Chloride	0.3		ND	ND	ND	ND	ND
Carbon Tetrachloride	0.1	5	ND	ND	ND	ND	ND
1,1-Dichloropropene	0.2		ND	ND	ND	ND	ND
Benzene	0.2	5	ND	ND	ND	ND	ND
1,2-Dichloroethane	0.3	5	ND	ND	ND	ND	ND
Trichloroethene	**0.1**	**5**	**ND**	**1.0**	**2.3**	**0.3**	**ND**
1,2-Dichloropropane	0.4	5	ND	ND	ND	ND	ND
Dibromomethane	0.3		ND	ND	ND	ND	ND
Methyl Methacrylate	0.2		ND	ND	ND	ND	ND
Bromodichloromethane	**0.3**	**TTHM***	**1.7**	**ND**	**ND**	**ND**	**ND**
2-Nitropropane	0.3		ND	ND	ND	ND	ND
Chloroacetonitrile	0.4		ND	ND	ND	ND	ND
c-1,3-Dichloropropene	0.2		ND	ND	ND	ND	ND
4-Methyl 2-Pentanone	0.3		ND	ND	ND	ND	ND
Ethyl Methacrylate	0.3		ND	ND	ND	ND	ND
Dichloroacetone	0.3		ND	ND	ND	ND	ND
Toluene	0.2	1000	ND	ND	ND	ND	ND
t-1,3-Dichloropropene	0.2		ND	ND	ND	ND	ND
1,1,2-Trichloroethane	0.3	5	ND	ND	ND	ND	ND
Tetrachloroethene	**0.4**	**5**	**ND**	**2.0**	**1.1**	**0.9**	**ND**
1,3-Dichloropropane	0.2		ND	ND	ND	ND	ND
Methyl Butyl Ketone	0.4		ND	ND	ND	ND	ND
Dibromochloromethane	**0.3**	**TTHM***	**2.7**	**ND**	**ND**	**ND**	**ND**

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).
NA = Data Not Available, Parameter failed to meet acceptable QC criteria.

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #4	WELL #6
Sample Date:			6/16/97	6/16/97	6/16/97	6/16/97	6/16/97
Sampled by:			GT	GT	GT	GT	GT
Analysis Date:			6/18/97	6/18/97	6/18/97	6/18/97	6/18/97
Analyzed by:			KL	KL	KL	KL	KL
	MDL	MCL					
1,2-Dibromoethane	0.1		ND	ND	ND	ND	ND
Chlorobenzene	0.3	100	ND	ND	ND	ND	ND
1,1,1,2-Tetrachloroethene	0.3		ND	ND	ND	ND	ND
Ethylbenzene	0.1	700	ND	ND	ND	ND	ND
m&p-Xylene	0.3	XYLENES**	ND	ND	ND	ND	ND
o-Xylene	0.1	XYLENES**	ND	ND	ND	ND	ND
Styrene	0.2	100	ND	ND	ND	ND	ND
Bromoform	**0.2**	**TTHM***	**1.4**	**ND**	**ND**	**ND**	**ND**
Isopropyl Benzene	0.2		ND	ND	ND	ND	ND
1,1,2,2-Tetrachlorethane	0.2		ND	ND	ND	ND	ND
1,2,3-Trichloropropane	0.2		ND	ND	ND	ND	ND
Bromobenzene	0.2		ND	ND	ND	ND	ND
T-1,4-Dichloro-2-Butene	0.7		ND	ND	ND	ND	ND
n-Propyl Benzene	0.1		ND	ND	ND	ND	ND
2-Chloro Toluene	0.2		ND	ND	ND	ND	ND
1,3,5-Trimethyl Benzene	0.2		ND	ND	ND	ND	ND
4-Chloro Toluene	0.2		ND	ND	ND	ND	ND
t-Butyl Benzene	0.2		ND	ND	ND	ND	ND
1,2,4-Trimethyl Benzene	0.3		ND	ND	ND	ND	ND
Pentachloroethane	1.0		ND	ND	ND	ND	ND
sec-Butyl Benzene	0.1		ND	ND	ND	ND	ND
p-Isopropyl Toluene	0.1		ND	ND	ND	ND	ND
1,4-Dichlorobenzene	0.2	75	ND	ND	ND	ND	ND
1,3-Dichlorobenzene	0.2		ND	ND	ND	ND	ND
n-Butyl Benzene	0.3		ND	ND	ND	ND	ND
1,2-Dichlorobenzene	0.2	600	ND	ND	ND	ND	ND
Hexachloroethane	0.3		ND	ND	ND	ND	ND
1,2-Dibromo-3-Chloro Propane	0.3		ND	ND	ND	ND	ND
Nitrobenzene	1.0		ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	0.1	70	ND	ND	ND	ND	ND
Hexachlorobutadiene	0.3		ND	ND	ND	ND	ND
Naphthalene	0.3		NA	NA	NA	NA	NA
1,2,3-Trichloro Benzene	0.1		ND	ND	ND	ND	ND
MCL WARNING NOTICES:							

**TTHM = Regulated as Total Trihalomethanes with the total not to exceed 100 ug/L*
***XYLENES= Regulated as Total Xylenes with the total not to exceed 10,000 ug/L*

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).
NA = Data Not Available, Parameter failed to meet acceptable QC criteria.

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #3	WELL #4	WELL #5
Sample Date:			6/23/97	6/23/97	6/23/97	6/23/97	6/23/97	6/23/97
Sampled by:			GT	GT	GT	GT	GT	GT
Analysis Date:			6/24/97	6/24/97	6/24/97	6/24/97	6/24/97	6/24/97
Analyzed by:			KL	KL	KL	KL	KL	KL
	MDL	MCL						
WARNING NOTICES:						OVER MCL		
Dichlorodifluoromethane	0.3		ND	ND	ND	ND	ND	ND
Chloromethane	0.6		ND	ND	ND	ND	ND	ND
Vinyl Chloride	0.2	2	ND	ND	ND	ND	ND	ND
Bromomethane	0.4		ND	ND	ND	ND	ND	ND
Chloroethane	0.4		ND	ND	ND	ND	ND	ND
Trichlorofluoromethane	0.2		ND	ND	ND	ND	ND	ND
Diethyl Ether	0.5		ND	ND	ND	ND	ND	ND
1,1-Dichloroethene	0.3	7	ND	ND	ND	ND	ND	ND
Acetone	0.8		ND	ND	ND	ND	ND	ND
Iodomethane	0.6		ND	ND	ND	ND	ND	ND
Carbon Disulfide	1.1		ND	ND	ND	ND	ND	ND
Allyl Chloride	0.3		ND	ND	ND	ND	ND	ND
Methylene Chloride	0.4	5	ND	ND	ND	ND	ND	ND
Acrylonitrile	1.0		ND	ND	ND	ND	ND	ND
t-1,2-Dichloroethene	0.3	100	ND	ND	ND	ND	ND	ND
Methyl -t-Butyl Ether	0.4		ND	ND	ND	ND	ND	ND
1,1-Dichloroethane	**0.2**		**ND**	**0.5**	**ND**	**1.4**	**ND**	**ND**
2,2-Dichloropropane	1.0		ND	ND	ND	ND	ND	ND
c-1,2-Dichloroethene	**0.2**	**70**	**0.4**	**1.6**	**6.3**	**ND**	**0.5**	**ND**
Methyl Ethyl Ketone	0.8		ND	ND	ND	ND	ND	ND
Propionitrile	0.3		ND	ND	ND	ND	ND	ND
Methyl Acrylate	0.3		ND	ND	ND	ND	ND	ND
Bromochloromethane	0.3		ND	ND	ND	ND	ND	ND
Methacrylonitrile	0.3		ND	ND	ND	ND	ND	ND
Tetrahydrofuran	0.5		ND	ND	ND	ND	ND	ND
Chloroform	**0.2**	**TTHM***	**0.5**	**ND**	**ND**	**ND**	**ND**	**ND**
1,1,1-Trichloroethane	**0.3**	**200**	**ND**	**0.9**	**ND**	**3.3**	**0.5**	**ND**
n-Butyl Chloride	0.3		ND	ND	ND	ND	ND	ND
Carbon Tetrachloride	0.1	5	ND	ND	ND	ND	ND	ND
1,1-Dichloropropene	0.2		ND	ND	ND	ND	ND	ND
Benzene	0.2	5	ND	ND	ND	ND	ND	ND
1,2-Dichloroethane	0.3	5	ND	ND	ND	ND	ND	ND
Trichloroethene	**0.1**	**5**	**ND**	**1.0**	**2.5**	**1.4**	**0.3**	**ND**
1,2-Dichloropropane	0.4	5	ND	ND	ND	ND	ND	ND
Dibromomethane	0.3		ND	ND	ND	ND	ND	ND
Methyl Methacrylate	0.2		ND	ND	ND	ND	ND	ND
Bromodichloromethane	**0.3**	**TTHM***	**1.1**	**ND**	**ND**	**ND**	**ND**	**ND**
2-Nitropropane	0.3		ND	ND	ND	ND	ND	ND
Chloroacetonitrile	**0.4**		**0.5**	**ND**	**ND**	**ND**	**ND**	**ND**
c-1,3-Dichloropropene	0.2		ND	ND	ND	ND	ND	ND
4-Methyl 2-Pentanone	0.3		ND	ND	ND	ND	ND	ND
Ethyl Methacrylate	0.3		ND	ND	ND	ND	ND	ND
Dichloroacetone	0.3		ND	ND	ND	ND	ND	ND
Toluene	0.2	1000	ND	ND	ND	ND	ND	ND
t-1,3-Dichloropropene	0.2		ND	ND	ND	ND	ND	ND
1,1,2-Trichloroethane	0.3	5	ND	ND	ND	ND	ND	ND
Tetrachloroethene	**0.4**	**5**	**ND**	**2.3**	**1.1**	**7.5**	**1.0**	**ND**
1,3-Dichloropropane	0.2		ND	ND	ND	ND	ND	ND
Methyl Butyl Ketone	0.4		ND	ND	ND	ND	ND	ND
Dibromochloromethane	**0.3**	**TTHM***	**1.7**	**ND**	**ND**	**ND**	**ND**	**ND**

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).
NA = Data Not Available, Parameter failed to meet acceptable QC criteria.

JUN97DW.XLS
6/25/97

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #3	WELL #4	WELL #5
Sample Date:			6/23/97	6/23/97	6/23/97	6/23/97	6/23/97	6/23/97
Sampled by:			GT	GT	GT	GT	GT	GT
Analysis Date:			6/24/97	6/24/97	6/24/97	6/24/97	6/24/97	6/24/97
Analyzed by:			KL	KL	KL	KL	KL	KL
	MDL	MCL						
1,2-Dibromoethane	0.1		ND	ND	ND	ND	ND	ND
Chlorobenzene	0.3	100	ND	ND	ND	ND	ND	ND
1,1,1,2-Tetrachloroethene	0.3		ND	ND	ND	ND	ND	ND
Ethylbenzene	0.1	700	ND	ND	ND	ND	ND	ND
m&p-Xylene	0.3	XYLENES**	ND	ND	ND	ND	ND	ND
o-Xylene	0.1	XYLENES**	ND	ND	ND	ND	ND	ND
Styrene	0.2	100	ND	ND	ND	ND	ND	ND
Bromoform	**0.2**	**TTHM***	**1.2**	**ND**	**ND**	**ND**	**ND**	**ND**
Isopropyl Benzene	0.2		ND	ND	ND	ND	ND	ND
1,1,2,2-Tetrachlorethane	0.2		ND	ND	ND	ND	ND	ND
1,2,3-Trichloropropane	0.2		ND	ND	ND	ND	ND	ND
Bromobenzene	0.2		ND	ND	ND	ND	ND	ND
T-1,4-Dichloro-2-Butene	0.7		ND	ND	ND	ND	ND	ND
n-Propyl Benzene	0.1		ND	ND	ND	ND	ND	ND
2-Chloro Toluene	0.2		ND	ND	ND	ND	ND	ND
1,3,5-Trimethyl Benzene	0.2		ND	ND	ND	ND	ND	ND
4-Chloro Toluene	0.2		ND	ND	ND	ND	ND	ND
t-Butyl Benzene	0.2		ND	ND	ND	ND	ND	ND
1,2,4-Trimethyl Benzene	0.3		ND	ND	ND	ND	ND	ND
Pentachloroethane	1.0		ND	ND	ND	ND	ND	ND
sec-Butyl Benzene	0.1		ND	ND	ND	ND	ND	ND
p-Isopropyl Toluene	0.1		ND	ND	ND	ND	ND	ND
1,4-Dichlorobenzene	0.2	75	ND	ND	ND	ND	ND	ND
1,3-Dichlorobenzene	0.2		ND	ND	ND	ND	ND	ND
n-Butyl Benzene	0.3		ND	ND	ND	ND	ND	ND
1,2-Dichlorobenzene	0.2	600	ND	ND	ND	ND	ND	ND
Hexachloroethane	0.3		ND	ND	ND	ND	ND	ND
1,2-Dibromo-3-Chloro Propane	0.3		ND	ND	ND	ND	ND	ND
Nitrobenzene	1.0		ND	ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	0.1	70	ND	ND	ND	ND	ND	ND
Hexachlorobutadiene	0.3		ND	ND	ND	ND	ND	ND
Naphthalene	0.3		ND	ND	ND	ND	ND	ND
1,2,3-Trichloro Benzene	0.1		ND	ND	ND	ND	ND	ND
WARNING NOTICES:						OVER MCL		

**TTHM = Regulated as Total Trihalomethanes with the total not to exceed 100 ug/L*
***XYLENES= Regulated as Total Xylenes with the total not to exceed 10,000 ug/L*

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).
NA = Data Not Available, Parameter failed to meet acceptable QC criteria.

CITY OF KALAMAZOO
SWS_1996.DBF

SUMMER WELL SAMPLING RESULTS

(Results in mg/L, Cond. IN uMOS)

IDENT	DATE	ALKA-LINITY	AMMONIA	CHLORIDE	CONDVTY	FLUORIDE	HDNESS	NITRATE	D_OXY	PH	O- PHOS	SILICATE	SULFATE	TEMP(C)	TDS	COMMENT
S1-RAW	05/17/1996	353	0.060	85.49	0.900	0.129	361	0.38	0.60	7.22	ND	6.66	60.40	13.1		O-PHOS BELOW DETECT
S1-1	05/17/1996	356	0.012	109.35	0.972	0.123	344	0.32	0.60	7.29	ND	6.53	61.29	14.6		ORTHO-P BELOW DETECT
S1-2	05/17/1996	364	0.926	108.31	0.925	0.132	413	ND	0.85	7.22	ND	6.78	61.16	13.9		BELOW DETECT NO3 & O-PHOS
S1-3	05/17/1996	337	0.022	68.89	0.851	0.129	344	0.51	0.85	7.25	0.09	6.83	61.65	13.5		
S1-5	05/17/1996	317	0.012	55.61	0.728	0.127	344	0.49	1.05	7.34	0.05	6.55	52.94	12.0		
S2-1	06/05/1996	316	0.085	13.83	1.142	0.136	423	ND	2.15	7.74	0.08	6.92	44.21	13.9		NON-DETECT FOR NO3
S3-7	05/20/1996	306	0.021	117.65	1.010	0.110	378	1.44	1.90	7.08	0.06	5.97	53.80	12.5		
S3-8	05/20/1996	308	0.039	ND	0.304	0.117	327	1.60	2.10	7.22	0.05	6.42	53.68	12.7		NON-DETECT FOR Cl
S4-3	05/28/1996	268	0.112	20.13	0.580	0.180	310	ND	0.35	7.25	0.05	7.27	30.16	10.9		NON-DETECT NO3
S4-7	05/28/1996	248	0.056	27.94	0.730	0.150	361	"	0.25	7.01	0.04	7.08	47.99	10.8		NON-DETECT NO3
S4-9	05/28/1996	230	0.091	4.79	0.554	0.201	258	"	0.60	7.22	0.30	7.34	19.40	11.0		NON-DETECT NO3
S4-10	05/28/1996	236	0.105	26.97	0.582	0.212	275	"	1.25	7.19	0.05	7.22	26.52	12.0		NON-DETECT NO3
S5-3	05/28/1996	300	0.121	54.78	0.902	0.154	430	"	0.30	6.99	0.05	6.52	97.57	12.4		NON-DETECT NO3
S5-4	05/28/1996	292	0.081	55.82	0.850	0.134	361	"	1.60	7.03	0.05	6.71	83.14	11.5		NON-DETECT NO3
S7-2	05/20/1996	300	0.092	57.06	0.793	0.145	361	"	8.35	7.39	0.05	6.86	56.78	17.8		NON-DETECT NO3
S8-1A	05/23/1996	266	0.279	22.62	0.626	0.148	327	"	0.55	7.31	0.08	8.06	34.24	12.3		NON-DETECT NO3
S8-2	05/23/1996	234	0.194	31.95	0.598	0.151	275	"	1.05	7.41	0.07	7.62	27.10	11.7		NON-DETECT NO3
S8-3	05/23/1996	252	0.194	43.78	0.632	0.141	310	"	0.20	7.23	0.04	7.46	27.89	11.9		NON-DETECT NO3
S8-4	05/24/1996	278	0.213	46.27	0.176	0.147	327	"	0.35	7.32	0.04	7.46	34.64	12.1		NON-DETECT NO3
S8-5	05/23/1996	284	0.108	93.16	0.768	0.314	344	"	0.30	7.29	0.04	7.25	44.18	12.0		NON-DETECT NO3
S8-6	05/23/1996	240	0.183	42.33	0.588	0.140	327	"	0.30	7.35	0.04	7.41	35.88	11.7		NON-DETECT NO3
S9-7	06/05/1996	220	0.120	19.85	0.497	0.139	292	0.77	0.40	7.81	0.05	5.99	22.62	12.4		
S9-8	06/05/1996	228	0.219	10.16	0.502	0.144	258	0.65	0.65	7.37	0.04	5.92	30.23	13.3		
S9-9	05/22/1996	246	0.114	40.25	0.420	0.142	241	0.19	0.90	7.38	0.07	6.39	18.38	17.0		
S9-12	06/05/1996	200	0.040	38.80	0.565	0.141	241	ND	0.10	7.42	0.07	5.04	22.26	13.1		NON-DETECT NO3
S14-3	05/24/1996	238	0.088	76.77	0.714	0.122	292	1.22	2.70	7.25	0.03	5.43	25.87	11.9		
S17-1	05/29/1996	252	0.121	15.98	0.173	0.202	275	ND	0.45	7.27	0.07	7.75	18.32	13.6		NON-DETECT NO3
S18-1	06/05/1996	292	0.046	1.14	0.617	0.150	327	ND	0.35	7.44	0.61	7.02	23.68	12.3		NON-DETECT NO3
S18-2	06/05/1996	242	0.218	1.56	0.148	0.247	224	ND	0.30	7.76	0.06	7.60	4.53	11.6		NON-DETECT NO3
S22-4	05/20/1996	271	0.025	7.05	0.508	0.159	275	1.34	0.70	7.39	0.04	6.43	53.85	11.9		
S24-8	06/03/1996	206	0.321	12.84	0.486	0.118	241	ND	0.40	7.39	0.07	6.70	26.91	11.3		NON-DETECT NO3
S24-9	06/03/1996	200	0.308	6.57	0.476	0.119	241	ND	0.25	7.57	0.07	6.62	23.40	12.1		
S24-10	06/03/1996	204	0.358	4.20	0.435	0.130	241	ND	0.50	7.59	0.06	6.85	14.85	11.2		NON-DETECT FOR NO3
S24-12	06/03/1996	194	0.158	1.49	0.426	0.149	224	ND	0.65	7.59	0.06	6.87	21.86	11.1		NON-DETECT FOR NO3
S24-16	06/03/1996	142	0.304	4.82	0.418	0.114	224	ND	0.20	7.62	0.05	6.15	22.40	12.8		NON-DETECT FOR NO3
S25-2	06/12/1996	224	0.032	9.96	0.120	0.121	275	0.36	0.40	6.92	0.04	6.04	32.50	9.8		WELL RUN ONLY 10 MIN BEFORE TEST
S25-4	05/30/1996	232	0.043	6.85	0.158	0.114	292	3.71	7.35	7.20	0.05	6.59	38.47	12.7		SULFATE RESULTS FROM U16496R1
S25-7	05/29/1996	220	0.035	10.58	0.569	0.117	258	0.25	0.85	6.98	0.03	6.24	40.76	10.7		
S25-9	05/29/1996	282	0.028	10.17	0.169	0.113	310	6.98	7.45	7.14	0.05	6.59	27.87	14.3		
S39-1	05/31/1996	236	0.339	15.85	0.642	0.140	310	1.48	2.05	7.25	0.06	5.97	8.06	10.6		
FS1	06/04/1996	294	0.019	9.54	0.945	0.950	378	0.27	8.65	7.36	0.16	6.84	49.25	15.7	505	
FS3	06/05/1996	238	0.185	2.88	0.650	0.950	327	1.23	2.15	7.76	0.41	6.38	30.36	15.0	328	
FS6	06/04/1996	52	0.016	2.92	0.650	0.913	292	ND	1.30	7.04	0.15	7.33	32.88	16.6	322	NON-DETECT FOR NO3
CAN	06/06/1996	274	0.070	4.44	0.644	0.640	310	ND	0.90	7.39	0.10	7.57	36.53	14.0	352	NON-DETECT FOR NO3
PKR	06/04/1996	48	0.026	1.48	0.578	0.851	292	1.32	1.95	7.16	0.18	6.68	32.12	13.2	301	
KVC	06/04/1996	202	0.071	1.41	0.438	1.220	241	ND	0.65	7.19	0.10	7.03	15.12	13.3	216	NON-DETECT FOR NO3
AVERAGE		251	0.137	31.21	0.590	0.248	306	1.29	1.47	7.32	0.09	6.76	36.69	12.7	337	
HIGHEST		365	0.926	117.65	1.142	1.220	430	6.98	8.65	7.81	0.61	8.06	97.57	17.8	505	
LOWEST		48	0.012	1.14	0.120	0.110	224	0.19	0.10	6.92	0.03	5.04	4.53	9.8	216	

CITY OF KALAMAZOO TRACE ORGANICS LABORATORY REPORT
SUMMER WELL STUDY 1996

SUMMER WELL SAMPLES 1996

Analyzed by EPA Method 524.2

Sample Location:			CPS RAW	WELL #1	WELL #2	WELL #3	WELL #4	WELL #5	WELL #6
Sample Date:			5/17/1996	5/17/1996	5/17/1996	5/17/1996	5/13/1996	5/15/1996	5/13/1996
Sampled by:			JB	JB	JB	JB	PM	PM	PM
Analysis Date:			5/17/1996	5/17/1996	5/17/1996	5/17/1996	5/15/1996	5/15/1996	5/15/1996
Analyzed by:			JB	JB	JB	JB	JB	JB	JB
	MDL	*MCL*							
Dichlorodifluoromethane	*0.3*		ND	ND	ND	ND	ND	ND	ND
Chloromethane	*0.6*		ND	ND	ND	ND	ND	ND	ND
Vinyl Chloride	*0.2*	*2*	ND	ND	ND	ND	ND	ND	ND
Bromomethane	*0.4*		ND	ND	ND	ND	ND	ND	ND
Chloroethane	*0.4*		ND	ND	ND	ND	ND	ND	ND
Trichlorofluoromethane	*0.2*		ND	ND	ND	ND	ND	ND	ND
Diethyl Ether	*0.5*		ND	ND	ND	ND	ND	ND	ND
1,1-Dichloroethene	*0.3*	*7*	**ND**	**ND**	**ND**	**0.5**	**ND**	**ND**	**ND**
Acetone	*0.8*		ND	ND	ND	ND	ND	ND	ND
Iodomethane	*0.6*		ND	ND	ND	ND	ND	ND	ND
Carbon Disulfide	*1.1*		ND	ND	ND	ND	ND	ND	ND
Allyl Chloride	*0.3*		ND	ND	ND	ND	ND	ND	ND
Methylene Chloride	*0.4*	*5*	ND	ND	ND	ND	ND	ND	ND
Acrylonitrile	*1.0*		ND	ND	ND	ND	ND	ND	ND
t-1,2-Dichloroethene	*0.3*	*100*	ND	ND	ND	ND	ND	ND	ND
Methyl -t-Butyl Ether	***0.4***		ND	ND	ND	ND	ND	ND	ND
1,1-Dichloroethane	*0.2*		**ND**	**ND**	**ND**	**1.8**	**ND**	**ND**	**ND**
2,2-Dichloropropane	*1.0*		ND	ND	ND	ND	ND	ND	ND
c-1,2-Dichloroethene	***0.2***	***70***	**1.2**	**2.0**	**4.9**	**ND**	**ND**	**ND**	**ND**
Methyl Ethyl Ketone	*0.8*		ND	ND	ND	ND	ND	ND	ND
Propionitrile	*0.3*		ND	ND	ND	ND	ND	ND	ND
Methyl Acrylate	*0.3*		ND	ND	ND	ND	ND	ND	ND
Bromochloromethane	*0.3*		ND	ND	ND	ND	ND	ND	ND
Methacrylonitrile	*0.3*		ND	ND	ND	ND	ND	ND	ND
Tetrahydrofuran	*0.5*		ND	ND	ND	ND	ND	ND	ND
Chloroform	***0.2***	***TTHM****	**ND**	**ND**	**ND**	**ND**	**ND**	**ND**	**ND**
1,1,1-Trichloroethane	*0.3*	*200*	**ND**	**ND**	**ND**	**4.6**	**ND**	**ND**	**ND**
n-Butyl Chloride	*0.3*		ND	ND	ND	ND	ND	ND	ND
Carbon Tetrachloride	*0.1*	*5*	ND	ND	ND	ND	ND	ND	ND
1,1-Dichloropropene	*0.2*		ND	ND	ND	ND	ND	ND	ND
Benzene	*0.2*	*5*	ND	ND	ND	ND	ND	ND	ND
1,2-Dichloroethane	*0.3*	*5*	ND	ND	ND	ND	ND	ND	ND
Trichloroethene	*0.1*	*5*	**0.4**	**0.9**	**0.9**	**1.0**	**ND**	**ND**	**ND**
1,2-Dichloropropane	*0.4*	*5*	ND	ND	ND	ND	ND	ND	ND
Dibromomethane	*0.3*		ND	ND	ND	ND	ND	ND	ND
Methyl Methacrylate	*0.2*		ND	ND	ND	ND	ND	ND	ND
Bromodichloromethane	***0.3***	***TTHM****	**ND**	**ND**	**ND**	**ND**	**ND**	**ND**	**ND**
2-Nitropropane	*0.3*		ND	ND	ND	ND	ND	ND	ND
Chloroacetonitrile	*0.4*		ND	ND	ND	ND	ND	ND	ND
c-1,3-Dichloropropene	*0.2*		ND	ND	ND	ND	ND	ND	ND
4-Methyl 2-Pentanone	*0.3*		ND	ND	ND	ND	ND	ND	ND
Ethyl Methacrylate	*0.3*		ND	ND	ND	ND	ND	ND	ND
Dichloroacetone	*0.3*		ND	ND	ND	ND	ND	ND	ND
Toluene	*0.2*	*1000*	ND	ND	ND	ND	ND	ND	ND
t-1,3-Dichloropropene	*0.2*		ND	ND	ND	ND	ND	ND	ND
1,1,2-Trichloroethane	*0.3*	*5*	ND	ND	ND	ND	ND	ND	ND
Tetrachloroethene	*0.4*	*5*	**0.8**	**ND**	**0.8**	**10.2**	**ND**	**ND**	**ND**
1,3-Dichloropropane	*0.2*		ND	ND	ND	ND	ND	ND	ND
Methyl Butyl Ketone	*0.4*		ND	ND	ND	ND	ND	ND	ND

ND = Not Detected at MDL (Method Detection Limit)
Units are ppb (ug/L)
MCL = Maximum Contaminant Level (Set by EPA)

SUMMER WELL SAMPLES 1996

Analyzed by EPA Method 524.2

Sample Location:			CPS RAW	WELL #1	WELL #2	WELL #3	WELL #4	WELL #5	WELL #6
Sample Date:			5/17/1996	5/17/1996	5/17/1996	5/17/1996	5/13/1996	5/15/1996	5/13/1996
Sampled by:			JB	JB	JB	JB	PM	PM	PM
Analysis Date:			5/17/1996	5/17/1996	5/17/1996	5/17/1996	5/15/1996	5/15/1996	5/15/1996
Analyzed by:			JB	JB	JB	JB	JB	JB	JB
	MDL	*MCL*							
Dibromochloromethane	***0.3***	***TTHM****	**ND**	**ND**	**ND**	**ND**	**ND**	**ND**	**ND**
1,2-Dibromoethane	*0.1*		ND	ND	ND	ND	ND	ND	ND
Chlorobenzene	*0.3*	***100***	ND	ND	ND	ND	ND	ND	ND
1,1,1,2-Tetrachloroethene	*0.3*		ND	ND	ND	ND	ND	ND	ND
Ethylbenzene	*0.1*	***700***	ND	ND	ND	ND	ND	ND	ND
m&p-Xylene	*0.3*	***XYLENES*****	ND	ND	ND	ND	ND	ND	ND
o-Xylene	*0.1*	***XYLENES*****	ND	ND	ND	ND	ND	ND	ND
Styrene	*0.2*	***100***	ND	ND	ND	ND	ND	ND	ND
Bromoform	***0.2***	***TTHM****	**ND**	**ND**	**ND**	**ND**	**ND**	**ND**	**ND**
Isopropyl Benzene	*0.2*		ND	ND	ND	ND	ND	ND	ND
1,1,2,2-Tetrachlorethane	*0.2*		ND	ND	ND	ND	ND	ND	ND
1,2,3-Trichloropropane	*0.2*		ND	ND	ND	ND	ND	ND	ND
Bromobenzene	*0.2*		ND	ND	ND	ND	ND	ND	ND
T-1,4-Dichloro-2-Butene	*0.7*		ND	ND	ND	ND	ND	ND	ND
n-Propyl Benzene	*0.1*		ND	ND	ND	ND	ND	ND	ND
2-Chloro Toluene	*0.2*		ND	ND	ND	ND	ND	ND	ND
1,3,5-Trimethyl Benzene	*0.2*		ND	ND	ND	ND	ND	ND	ND
4-Chloro Toluene	*0.2*		ND	ND	ND	ND	ND	ND	ND
t-Butyl Benzene	*0.2*		ND	ND	ND	ND	ND	ND	ND
1,2,4-Trimethyl Benzene	*0.3*		ND	ND	ND	ND	ND	ND	ND
Pentachloroethane	*1.0*		ND	ND	ND	ND	ND	ND	ND
sec-Butyl Benzene	*0.1*		ND	ND	ND	ND	ND	ND	ND
p-Isopropyl Toluene	*0.1*		ND	ND	ND	ND	ND	ND	ND
1,4-Dichlorobenzene	*0.2*	***75***	ND	ND	ND	ND	ND	ND	ND
1,3-Dichlorobenzene	*0.2*		ND	ND	ND	ND	ND	ND	ND
n-Butyl Benzene	*0.3*		ND	ND	ND	ND	ND	ND	ND
1,2-Dichlorobenzene	*0.2*	***600***	ND	ND	ND	ND	ND	ND	ND
Hexachloroethane	*0.3*		ND	ND	ND	ND	ND	ND	ND
1,2-Dibromo-3-Chloro Propane	*0.3*		ND	ND	ND	ND	ND	ND	ND
Nitrobenzene	*1.0*		ND	ND	ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	*0.1*	***70***	ND	ND	ND	ND	ND	ND	ND
Hexachlorobutadiene	*0.3*		ND	ND	ND	ND	ND	ND	ND
Naphthalene	*0.3*		ND	ND	ND	ND	ND	ND	ND
1,2,3-Trichloro Benzene	*0.1*		ND	ND	ND	ND	ND	ND	ND

**TTHM = Regulated as Total Trihalomethanes with the total not to exceed 100 ug/L.*
***XYLENES= Regulated as Total Xylenes with the total not to exceed 10,000 ug/L.*

ND = Not Detected at MDL (Method Detection Limit)
Units are ppb (ug/L)
MCL = Maximum Contaminant Level (Set by EPA)

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #4	WELL #5
Sample Date:			6/3/96	6/3/96	6/3/96	6/3/96	6/3/96
Sampled by:			PM	PM	PM	PM	PM
Analysis Date:			6/4/96	6/4/96	6/4/96	6/4/96	6/4/96
Analyzed by:			KL	KL	KL	KL	KL
	MDL	MCL					
WARNING NOTICES:							
Dichlorodifluoromethane	0.3		ND	ND	ND	ND	ND
Chloromethane	0.6		ND	ND	ND	ND	ND
Vinyl Chloride	0.2	2	ND	ND	ND	ND	ND
Bromomethane	0.4		ND	ND	ND	ND	ND
Chloroethane	0.4		ND	ND	ND	ND	ND
Trichlorofluoromethane	0.2		ND	ND	ND	ND	ND
Diethyl Ether	0.5		ND	ND	ND	ND	ND
1,1-Dichloroethene	0.3	7	ND	ND	ND	ND	ND
Acetone	0.8		ND	ND	ND	ND	ND
Iodomethane	0.6		ND	ND	ND	ND	ND
Carbon Disulfide	1.1		ND	ND	ND	ND	ND
Allyl Chloride	0.3		ND	ND	ND	ND	ND
Methylene Chloride	0.4	5	ND	ND	ND	ND	ND
Acrylonitrile	1.0		ND	ND	ND	ND	ND
t-1,2-Dichloroethene	0.3	100	ND	ND	ND	ND	ND
Methyl -t-Butyl Ether	0.4		ND	ND	ND	ND	ND
1,1-Dichloroethane	**0.2**		**ND**	**ND**	**ND**	**ND**	**ND**
2,2-Dichloropropane	1.0		ND	ND	ND	ND	ND
c-1,2-Dichloroethene	**0.2**	70	**ND**	**1.3**	**4.4**	**ND**	**ND**
Methyl Ethyl Ketone	0.8		ND	ND	ND	ND	ND
Propionitrile	0.3		ND	ND	ND	ND	ND
Methyl Acrylate	0.3		ND	ND	ND	ND	ND
Bromochloromethane	0.3		ND	ND	ND	ND	ND
Methacrylonitrile	0.3		ND	ND	ND	ND	ND
Tetrahydrofuran	0.5		ND	ND	ND	ND	ND
Chloroform	**0.2**	TTHM*	**0.5**	**ND**	**ND**	**ND**	**ND**
1,1,1-Trichloroethane	0.3	200	ND	ND	ND	ND	ND
n-Butyl Chloride	0.3		ND	ND	ND	ND	ND
Carbon Tetrachloride	0.1	5	ND	ND	ND	ND	ND
1,1-Dichloropropene	0.2		ND	ND	ND	ND	ND
Benzene	0.2	5	ND	ND	ND	ND	ND
1,2-Dichloroethane	0.3	5	ND	ND	ND	ND	ND
Trichloroethene	**0.1**	5	**ND**	**0.5**	**1.6**	**ND**	**ND**
1,2-Dichloropropane	0.4	5	ND	ND	ND	ND	ND
Dibromomethane	0.3		ND	ND	ND	ND	ND
Methyl Methacrylate	0.2		ND	ND	ND	ND	ND
Bromodichloromethane	**0.3**	TTHM*	**1.3**	**ND**	**ND**	**ND**	**ND**
2-Nitropropane	0.3		ND	ND	ND	ND	ND
Chloroacetonitrile	**0.4**		**ND**	**ND**	**ND**	**ND**	**ND**
c-1,3-Dichloropropene	0.2		ND	ND	ND	ND	ND
4-Methyl 2-Pentanone	0.3		ND	ND	ND	ND	ND
Ethyl Methacrylate	0.3		ND	ND	ND	ND	ND
Dichloroacetone	0.3		ND	ND	ND	ND	ND
Toluene	0.2	1000	ND	ND	ND	ND	ND
t-1,3-Dichloropropene	0.2		ND	ND	ND	ND	ND
1,1,2-Trichloroethane	0.3	5	ND	ND	ND	ND	ND
Tetrachloroethene	**0.4**	5	**ND**	**ND**	**0.5**	**ND**	**ND**
1,3-Dichloropropane	0.2		ND	ND	ND	ND	ND
Methyl Butyl Ketone	0.4		ND	ND	ND	ND	ND
Dibromochloromethane	**0.3**	TTHM*	**2.1**	**ND**	**ND**	**ND**	**ND**
1,2-Dibromoethane	0.1		ND	ND	ND	ND	ND

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).

JUN96DW.XLS

REPORT SUBMITTED 6/10/96 BY _____

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #4	WELL #5
Sample Date:			6/3/96	6/3/96	6/3/96	6/3/96	6/3/96
Sampled by:			PM	PM	PM	PM	PM
Analysis Date:			6/4/96	6/4/96	6/4/96	6/4/96	6/4/96
Analyzed by:			KL	KL	KL	KL	KL
	MDL	*MCL*					
Chlorobenzene	*0.3*	*100*	ND	ND	ND	ND	ND
1,1,1,2-Tetrachloroethene	*0.3*		ND	ND	ND	ND	ND
Ethylbenzene	*0.1*	*700*	ND	ND	ND	ND	ND
m&p-Xylene	*0.3*	*XYLENES***	ND	ND	ND	ND	ND
o-Xylene	*0.1*	*XYLENES***	ND	ND	ND	ND	ND
Styrene	*0.2*	*100*	ND	ND	ND	ND	ND
Bromoform	***0.2***	*TTHM**	**0.9**	**ND**	**ND**	**ND**	**ND**
Isopropyl Benzene	*0.2*		ND	ND	ND	ND	ND
1,1,2,2-Tetrachlorethane	*0.2*		ND	ND	ND	ND	ND
1,2,3-Trichloropropane	*0.2*		ND	ND	ND	ND	ND
Bromobenzene	*0.2*		ND	ND	ND	ND	ND
T-1,4-Dichloro-2-Butene	*0.7*		ND	ND	ND	ND	ND
n-Propyl Benzene	*0.1*		ND	ND	ND	ND	ND
2-Chloro Toluene	*0.2*		ND	ND	ND	ND	ND
1,3,5-Trimethyl Benzene	*0.2*		ND	ND	ND	ND	ND
4-Chloro Toluene	*0.2*		ND	ND	ND	ND	ND
t-Butyl Benzene	*0.2*		ND	ND	ND	ND	ND
1,2,4-Trimethyl Benzene	*0.3*		ND	ND	ND	ND	ND
Pentachloroethane	*1.0*		ND	ND	ND	ND	ND
sec-Butyl Benzene	*0.1*		ND	ND	ND	ND	ND
p-Isopropyl Toluene	*0.1*		ND	ND	ND	ND	ND
1,4-Dichlorobenzene	*0.2*	*75*	ND	ND	ND	ND	ND
1,3-Dichlorobenzene	*0.2*		ND	ND	ND	ND	ND
n-Butyl Benzene	*0.3*		ND	ND	ND	ND	ND
1,2-Dichlorobenzene	*0.2*	*600*	ND	ND	ND	ND	ND
Hexachloroethane	*0.3*		ND	ND	ND	ND	ND
1,2-Dibromo-3-Chloro Propane	*0.3*		ND	ND	ND	ND	ND
Nitrobenzene	*1.0*		ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	*0.1*	*70*	ND	ND	ND	ND	ND
Hexachlorobutadiene	*0.3*		ND	ND	ND	ND	ND
Naphthalene	*0.3*		ND	ND	ND	ND	ND
1,2,3-Trichloro Benzene	*0.1*		ND	ND	ND	ND	ND
WARNING NOTICES:							

**TTHM = Regulated as Total Trihalomethanes with the total not to exceed 100 ug/L.*
***XYLENES= Regulated as Total Xylenes with the total not to exceed 10,000 ug/L.*

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).

JUN96DW.XLS

REPORT SUBMITTED 6/10/96 BY _____

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #4	WELL #5
Sample Date:			6/5/96	6/5/96	6/5/96	6/5/96	6/5/96
Sampled by:			PM	PM	PM	PM	PM
Analysis Date:			6/7/96	6/7/96	6/7/96	6/7/96	6/7/96
Analyzed by:			KL	KL	KL	KL	KL
	MDL	*MCL*					
WARNING NOTICES:							
Dichlorodifluoromethane	*0.3*		ND	ND	ND	ND	ND
Chloromethane	*0.6*		ND	ND	ND	ND	ND
Vinyl Chloride	*0.2*	*2*	ND	ND	ND	ND	ND
Bromomethane	*0.4*		ND	ND	ND	ND	ND
Chloroethane	*0.4*		ND	ND	ND	ND	ND
Trichlorofluoromethane	*0.2*		ND	ND	ND	ND	ND
Diethyl Ether	*0.5*		ND	ND	ND	ND	ND
1,1-Dichloroethene	*0.3*	*7*	ND	ND	ND	ND	ND
Acetone	*0.8*		ND	ND	ND	ND	ND
Iodomethane	*0.6*		ND	ND	ND	ND	ND
Carbon Disulfide	*1.1*		ND	ND	ND	ND	ND
Allyl Chloride	*0.3*		ND	ND	ND	ND	ND
Methylene Chloride	*0.4*	*5*	ND	ND	ND	ND	ND
Acrylonitrile	*1.0*		ND	ND	ND	ND	ND
t-1,2-Dichloroethene	*0.3*	*100*	ND	ND	ND	ND	ND
Methyl -t-Butyl Ether	*0.4*		ND	ND	ND	ND	ND
1,1-Dichloroethane	***0.2***		**ND**	**ND**	**ND**	**ND**	**ND**
2,2-Dichloropropane	*1.0*		ND	ND	ND	ND	ND
c-1,2-Dichloroethene	***0.2***	*70*	**0.4**	**1.9**	**3.3**	**ND**	**ND**
Methyl Ethyl Ketone	*0.8*		ND	ND	ND	ND	ND
Propionitrile	*0.3*		ND	ND	ND	ND	ND
Methyl Acrylate	*0.3*		ND	ND	ND	ND	ND
Bromochloromethane	*0.3*		ND	ND	ND	ND	ND
Methacrylonitrile	*0.3*		ND	ND	ND	ND	ND
Tetrahydrofuran	*0.5*		ND	ND	ND	ND	ND
Chloroform	***0.2***	*TTHM**	**0.5**	**ND**	**ND**	**ND**	**ND**
1,1,1-Trichloroethane	*0.3*	*200*	ND	ND	ND	ND	ND
n-Butyl Chloride	*0.3*		ND	ND	ND	ND	ND
Carbon Tetrachloride	*0.1*	*5*	ND	ND	ND	ND	ND
1,1-Dichloropropene	*0.2*		ND	ND	ND	ND	ND
Benzene	*0.2*	*5*	ND	ND	ND	ND	ND
1,2-Dichloroethane	*0.3*	*5*	ND	ND	ND	ND	ND
Trichloroethene	***0.1***	*5*	**ND**	**0.6**	**1.4**	**ND**	**ND**
1,2-Dichloropropane	*0.4*	*5*	ND	ND	ND	ND	ND
Dibromomethane	*0.3*		ND	ND	ND	ND	ND
Methyl Methacrylate	*0.2*		ND	ND	ND	ND	ND
Bromodichloromethane	***0.3***	*TTHM**	**1.2**	**ND**	**ND**	**ND**	**ND**
2-Nitropropane	*0.3*		ND	ND	ND	ND	ND
Chloroacetonitrile	***0.4***		**ND**	**ND**	**ND**	**ND**	**ND**
c-1,3-Dichloropropene	*0.2*		ND	ND	ND	ND	ND
4-Methyl 2-Pentanone	*0.3*		ND	ND	ND	ND	ND
Ethyl Methacrylate	*0.3*		ND	ND	ND	ND	ND
Dichloroacetone	*0.3*		ND	ND	ND	ND	ND
Toluene	*0.2*	*1000*	ND	ND	ND	ND	ND
t-1,3-Dichloropropene	*0.2*		ND	ND	ND	ND	ND
1,1,2-Trichloroethane	*0.3*	*5*	ND	ND	ND	ND	ND
Tetrachloroethene	***0.4***	*5*	**ND**	**ND**	**0.5**	**ND**	**ND**
1,3-Dichloropropane	*0.2*		ND	ND	ND	ND	ND
Methyl Butyl Ketone	*0.4*		ND	ND	ND	ND	ND
Dibromochloromethane	***0.3***	*TTHM**	**1.9**	**ND**	**ND**	**ND**	**ND**
1,2-Dibromoethane	*0.1*		ND	ND	ND	ND	ND

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).

JUN96DW.XLS

REPORT SUBMITTED 6/10/96 BY _____

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #4	WELL #5
Sample Date:			6/5/96	6/5/96	6/5/96	6/5/96	6/5/96
Sampled by:			PM	PM	PM	PM	PM
Analysis Date:			6/7/96	6/7/96	6/7/96	6/7/96	6/7/96
Analyzed by:			KL	KL	KL	KL	KL
	MDL	*MCL*					
Chlorobenzene	*0.3*	*100*	ND	ND	ND	ND	ND
1,1,1,2-Tetrachloroethene	*0.3*		ND	ND	ND	ND	ND
Ethylbenzene	*0.1*	*700*	ND	ND	ND	ND	ND
m&p-Xylene	*0.3*	*XYLENES***	ND	ND	ND	ND	ND
o-Xylene	*0.1*	*XYLENES***	ND	ND	ND	ND	ND
Styrene	*0.2*	*100*	ND	ND	ND	ND	ND
Bromoform	***0.2***	*TTHM**	**0.9**	**ND**	**ND**	**ND**	**ND**
Isopropyl Benzene	*0.2*		ND	ND	ND	ND	ND
1,1,2,2-Tetrachlorethane	*0.2*		ND	ND	ND	ND	ND
1,2,3-Trichloropropane	*0.2*		ND	ND	ND	ND	ND
Bromobenzene	*0.2*		ND	ND	ND	ND	ND
T-1,4-Dichloro-2-Butene	*0.7*		ND	ND	ND	ND	ND
n-Propyl Benzene	*0.1*		ND	ND	ND	ND	ND
2-Chloro Toluene	*0.2*		ND	ND	ND	ND	ND
1,3,5-Trimethyl Benzene	*0.2*		ND	ND	ND	ND	ND
4-Chloro Toluene	*0.2*		ND	ND	ND	ND	ND
t-Butyl Benzene	*0.2*		ND	ND	ND	ND	ND
1,2,4-Trimethyl Benzene	*0.3*		ND	ND	ND	ND	ND
Pentachloroethane	*1.0*		ND	ND	ND	ND	ND
sec-Butyl Benzene	*0.1*		ND	ND	ND	ND	ND
p-Isopropyl Toluene	*0.1*		ND	ND	ND	ND	ND
1,4-Dichlorobenzene	*0.2*	*75*	ND	ND	ND	ND	ND
1,3-Dichlorobenzene	*0.2*		ND	ND	ND	ND	ND
n-Butyl Benzene	*0.3*		ND	ND	ND	ND	ND
1,2-Dichlorobenzene	*0.2*	*600*	ND	ND	ND	ND	ND
Hexachloroethane	*0.3*		ND	ND	ND	ND	ND
1,2-Dibromo-3-Chloro Propane	*0.3*		ND	ND	ND	ND	ND
Nitrobenzene	*1.0*		ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	*0.1*	*70*	ND	ND	ND	ND	ND
Hexachlorobutadiene	*0.3*		ND	ND	ND	ND	ND
Naphthalene	*0.3*		ND	ND	ND	ND	ND
1,2,3-Trichloro Benzene	*0.1*		ND	ND	ND	ND	ND
WARNING NOTICES:							

**TTHM = Regulated as Total Trihalomethanes with the total not to exceed 100 ug/L.*
***XYLENES= Regulated as Total Xylenes with the total not to exceed 10,000 ug/L.*

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).

JUN96DW.XLS

REPORT SUBMITTED 6/10/96 BY _____

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #2	WELL #4
Sample Date:			6/7/96	6/7/96	6/7/96	6/7/96	6/7/96
Sampled by:			JB	JB	JB	JB	JB
Analysis Date:			6/7/96	6/7/96	6/7/96	6/7/96	6/7/96
Analyzed by:			KL	KL	KL	KL	KL
	MDL	*MCL*					
WARNING NOTICES:							
Dichlorodifluoromethane	*0.3*		ND	ND	ND	ND	ND
Chloromethane	*0.6*		ND	ND	ND	ND	ND
Vinyl Chloride	*0.2*	*2*	ND	ND	ND	ND	ND
Bromomethane	*0.4*		ND	ND	ND	ND	ND
Chloroethane	*0.4*		ND	ND	ND	ND	ND
Trichlorofluoromethane	*0.2*		ND	ND	ND	ND	ND
Diethyl Ether	*0.5*		ND	ND	ND	ND	ND
1,1-Dichloroethene	*0.3*	*7*	ND	ND	ND	ND	ND
Acetone	*0.8*		ND	ND	ND	ND	ND
Iodomethane	*0.6*		ND	ND	ND	ND	ND
Carbon Disulfide	*1.1*		ND	ND	ND	ND	ND
Allyl Chloride	*0.3*		ND	ND	ND	ND	ND
Methylene Chloride	*0.4*	*5*	ND	ND	ND	ND	ND
Acrylonitrile	*1.0*		ND	ND	ND	ND	ND
t-1,2-Dichloroethene	*0.3*	*100*	ND	ND	ND	ND	ND
Methyl -t-Butyl Ether	*0.4*		ND	ND	ND	ND	ND
1,1-Dichloroethane	***0.2***		**ND**	**ND**	**ND**	**0.3**	**ND**
2,2-Dichloropropane	*1.0*		ND	ND	ND	ND	ND
c-1,2-Dichloroethene	***0.2***	*70*	**0.4**	**1.6**	**3.4**	**4.7**	**ND**
Methyl Ethyl Ketone	*0.8*		ND	ND	ND	ND	ND
Propionitrile	*0.3*		ND	ND	ND	ND	ND
Methyl Acrylate	*0.3*		ND	ND	ND	ND	ND
Bromochloromethane	*0.3*		ND	ND	ND	ND	ND
Methacrylonitrile	*0.3*		ND	ND	ND	ND	ND
Tetrahydrofuran	*0.5*		ND	ND	ND	ND	ND
Chloroform	***0.2***	*TTHM**	**3.1**	**ND**	**ND**	**ND**	**ND**
1,1,1-Trichloroethane	*0.3*	*200*	ND	ND	ND	ND	ND
n-Butyl Chloride	*0.3*		ND	ND	ND	ND	ND
Carbon Tetrachloride	*0.1*	*5*	ND	ND	ND	ND	ND
1,1-Dichloropropene	*0.2*		ND	ND	ND	ND	ND
Benzene	*0.2*	*5*	ND	ND	ND	ND	ND
1,2-Dichloroethane	*0.3*	*5*	ND	ND	ND	ND	ND
Trichloroethene	***0.1***	*5*	**ND**	**0.6**	**1.4**	**1.0**	**ND**
1,2-Dichloropropane	*0.4*	*5*	ND	ND	ND	ND	ND
Dibromomethane	*0.3*		ND	ND	ND	ND	ND
Methyl Methacrylate	*0.2*		ND	ND	ND	ND	ND
Bromodichloromethane	***0.3***	*TTHM**	**5.5**	**ND**	**ND**	**ND**	**ND**
2-Nitropropane	*0.3*		ND	ND	ND	ND	ND
Chloroacetonitrile	***0.4***		**0.5**	**ND**	**ND**	**ND**	**ND**
c-1,3-Dichloropropene	*0.2*		ND	ND	ND	ND	ND
4-Methyl 2-Pentanone	*0.3*		ND	ND	ND	ND	ND
Ethyl Methacrylate	*0.3*		ND	ND	ND	ND	ND
Dichloroacetone	*0.3*		ND	ND	ND	ND	ND
Toluene	*0.2*	*1000*	ND	ND	ND	ND	ND
t-1,3-Dichloropropene	*0.2*		ND	ND	ND	ND	ND
1,1,2-Trichloroethane	*0.3*	*5*	ND	ND	ND	ND	ND
Tetrachloroethene	***0.4***	*5*	**ND**	**ND**	**0.5**	**0.8**	**ND**
1,3-Dichloropropane	*0.2*		ND	ND	ND	ND	ND
Methyl Butyl Ketone	*0.4*		ND	ND	ND	ND	ND
Dibromochloromethane	***0.3***	*TTHM**	**6.4**	**ND**	**ND**	**ND**	**ND**
1,2-Dibromoethane	*0.1*		ND	ND	ND	ND	ND

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).

JUN96DW.XLS

REPORT SUBMITTED 6/10/96 BY _____

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #2	WELL #4
Sample Date:			6/7/96	6/7/96	6/7/96	6/7/96	6/7/96
Sampled by:			JB	JB	JB	JB	JB
Analysis Date:			6/7/96	6/7/96	6/7/96	6/7/96	6/7/96
Analyzed by:			KL	KL	KL	KL	KL
	MDL	*MCL*					
Chlorobenzene	*0.3*	*100*	ND	ND	ND	ND	ND
1,1,1,2-Tetrachloroethene	*0.3*		ND	ND	ND	ND	ND
Ethylbenzene	*0.1*	*700*	ND	ND	ND	ND	ND
m&p-Xylene	*0.3*	*XYLENES***	ND	ND	ND	ND	ND
o-Xylene	*0.1*	*XYLENES***	ND	ND	ND	ND	ND
Styrene	*0.2*	*100*	ND	ND	ND	ND	ND
Bromoform	***0.2***	*TTHM**	**2.4**	**ND**	**ND**	**ND**	**ND**
Isopropyl Benzene	*0.2*		ND	ND	ND	ND	ND
1,1,2,2-Tetrachlorethane	*0.2*		ND	ND	ND	ND	ND
1,2,3-Trichloropropane	*0.2*		ND	ND	ND	ND	ND
Bromobenzene	*0.2*		ND	ND	ND	ND	ND
T-1,4-Dichloro-2-Butene	*0.7*		ND	ND	ND	ND	ND
n-Propyl Benzene	*0.1*		ND	ND	ND	ND	ND
2-Chloro Toluene	*0.2*		ND	ND	ND	ND	ND
1,3,5-Trimethyl Benzene	*0.2*		ND	ND	ND	ND	ND
4-Chloro Toluene	*0.2*		ND	ND	ND	ND	ND
t-Butyl Benzene	*0.2*		ND	ND	ND	ND	ND
1,2,4-Trimethyl Benzene	*0.3*		ND	ND	ND	ND	ND
Pentachloroethane	*1.0*		ND	ND	ND	ND	ND
sec-Butyl Benzene	*0.1*		ND	ND	ND	ND	ND
p-Isopropyl Toluene	*0.1*		ND	ND	ND	ND	ND
1,4-Dichlorobenzene	*0.2*	*75*	ND	ND	ND	ND	ND
1,3-Dichlorobenzene	*0.2*		ND	ND	ND	ND	ND
n-Butyl Benzene	*0.3*		ND	ND	ND	ND	ND
1,2-Dichlorobenzene	*0.2*	*600*	ND	ND	ND	ND	ND
Hexachloroethane	*0.3*		ND	ND	ND	ND	ND
1,2-Dibromo-3-Chloro Propane	*0.3*		ND	ND	ND	ND	ND
Nitrobenzene	*1.0*		ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	*0.1*	*70*	ND	ND	ND	ND	ND
Hexachlorobutadiene	*0.3*		ND	ND	ND	ND	ND
Naphthalene	*0.3*		ND	ND	ND	ND	ND
1,2,3-Trichloro Benzene	*0.1*		ND	ND	ND	ND	ND
WARNING NOTICES:							

**TTHM = Regulated as Total Trihalomethanes with the total not to exceed 100 ug/L.*
***XYLENES= Regulated as Total Xylenes with the total not to exceed 10,000 ug/L.*

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).

JUN96DW.XLS

REPORT SUBMITTED 6/10/96 BY _____

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #2	WELL #4	WELL #5
Sample Date			6/10/96	6/10/96	6/10/96	6/10/96	6/10/96	6/10/96
Sampled by:			PM	PM	PM	PM	PM	PM
Analysis Date:			6/12/96	6/12/96	6/12/96	6/12/96	6/12/96	6/12/96
Analyzed by:			KL	KL	KL	KL	KL	KL
	MDL	*MCL*						
WARNING NOTICES:								
Dichlorodifluoromethane	*0.3*		ND	ND	ND	ND	ND	ND
Chloromethane	*0.6*		ND	ND	ND	ND	ND	ND
Vinyl Chloride	*0.2*	*2*	ND	ND	ND	ND	ND	ND
Bromomethane	*0.4*		ND	ND	ND	ND	ND	ND
Chloroethane	*0.4*		ND	ND	ND	ND	ND	ND
Trichlorofluoromethane	*0.2*		ND	ND	ND	ND	ND	ND
Diethyl Ether	*0.5*		ND	ND	ND	ND	ND	ND
1,1-Dichloroethene	*0.3*	*7*	ND	ND	ND	ND	ND	ND
Acetone	*0.8*		ND	ND	ND	ND	ND	ND
Iodomethane	*0.6*		ND	ND	ND	ND	ND	ND
Carbon Disulfide	*1.1*		ND	ND	ND	ND	ND	ND
Allyl Chloride	*0.3*		ND	ND	ND	ND	ND	ND
Methylene Chloride	*0.4*	*5*	ND	ND	ND	ND	ND	ND
Acrylonitrile	*1.0*		ND	ND	ND	ND	ND	ND
t-1,2-Dichloroethene	*0.3*	*100*	ND	ND	ND	ND	ND	ND
Methyl -t-Butyl Ether	***0.4***		**ND**	**ND**	**ND**	**0.5**	**ND**	**ND**
1,1-Dichloroethane	*0.2*		ND	ND	ND	ND	ND	ND
2,2-Dichloropropane	*1.0*		ND	ND	ND	ND	ND	ND
c-1,2-Dichloroethene	***0.2***	*70*	**0.5**	**1.9**	**3.4**	**4.8**	**ND**	**ND**
Methyl Ethyl Ketone	*0.8*		ND	ND	ND	ND	ND	ND
Propionitrile	*0.3*		ND	ND	ND	ND	ND	ND
Methyl Acrylate	*0.3*		ND	ND	ND	ND	ND	ND
Bromochloromethane	*0.3*		ND	ND	ND	ND	ND	ND
Methacrylonitrile	*0.3*		ND	ND	ND	ND	ND	ND
Tetrahydrofuran	*0.5*		ND	ND	ND	ND	ND	ND
Chloroform	***0.2***	*TTHM**	**0.5**	**ND**	**ND**	**ND**	**ND**	**ND**
1,1,1-Trichloroethane	*0.3*	*200*	ND	ND	ND	ND	ND	ND
n-Butyl Chloride	*0.3*		ND	ND	ND	ND	ND	ND
Carbon Tetrachloride	*0.1*	*5*	ND	ND	ND	ND	ND	ND
1,1-Dichloropropene	*0.2*		ND	ND	ND	ND	ND	ND
Benzene	*0.2*	*5*	ND	ND	ND	ND	ND	ND
1,2-Dichloroethane	*0.3*	*5*	ND	ND	ND	ND	ND	ND
Trichloroethene	***0.1***	*5*	**ND**	**0.6**	**1.4**	**1.0**	**ND**	**ND**
1,2-Dichloropropane	*0.4*	*5*	ND	ND	ND	ND	ND	ND
Dibromomethane	*0.3*		ND	ND	ND	ND	ND	ND
Methyl Methacrylate	*0.2*		ND	ND	ND	ND	ND	ND
Bromodichloromethane	***0.3***	*TTHM**	**1.2**	**ND**	**ND**	**ND**	**ND**	**ND**
2-Nitropropane	*0.3*		ND	ND	ND	ND	ND	ND
Chloroacetonitrile	*0.4*		ND	ND	ND	ND	ND	ND
c-1,3-Dichloropropene	*0.2*		ND	ND	ND	ND	ND	ND
4-Methyl 2-Pentanone	*0.3*		ND	ND	ND	ND	ND	ND
Ethyl Methacrylate	*0.3*		ND	ND	ND	ND	ND	ND
Dichloroacetone	*0.3*		ND	ND	ND	ND	ND	ND
Toluene	*0.2*	*1000*	ND	ND	ND	ND	ND	ND
t-1,3-Dichloropropene	*0.2*		ND	ND	ND	ND	ND	ND
1,1,2-Trichloroethane	*0.3*	*5*	ND	ND	ND	ND	ND	ND
Tetrachloroethene	***0.4***	*5*	**ND**	**ND**	**0.5**	**0.8**	**ND**	**ND**
1,3-Dichloropropane	*0.2*		ND	ND	ND	ND	ND	ND
Methyl Butyl Ketone	*0.4*		ND	ND	ND	ND	ND	ND
Dibromochloromethane	***0.3***	*TTHM**	**2.0**	**ND**	**ND**	**ND**	**ND**	**ND**
1,2-Dibromoethane	*0.1*		ND	ND	ND	ND	ND	ND

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).

JUN96DW.XLS

REPORT SUBMITTED 6/13/96 BY _____

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #2	WELL #4	WELL #5
Sample Date:			6/10/96	6/10/96	6/10/96	6/10/96	6/10/96	6/10/96
Sampled by:			PM	PM	PM	PM	PM	PM
Analysis Date:			6/12/96	6/12/96	6/12/96	6/12/96	6/12/96	6/12/96
Analyzed by:			KL	KL	KL	KL	KL	KL
	MDL	*MCL*						
Chlorobenzene	*0.3*	*100*	ND	ND	ND	ND	ND	ND
1,1,1,2-Tetrachloroethene	*0.3*		ND	ND	ND	ND	ND	ND
Ethylbenzene	*0.1*	*700*	ND	ND	ND	ND	ND	ND
m&p-Xylene	*0.3*	*XYLENES***	ND	ND	ND	ND	ND	ND
o-Xylene	*0.1*	*XYLENES***	ND	ND	ND	ND	ND	ND
Styrene	*0.2*	*100*	ND	ND	ND	ND	ND	ND
Bromoform	***0.2***	*TTHM**	**1.0**	**ND**	**ND**	**ND**	**ND**	**ND**
Isopropyl Benzene	*0.2*		ND	ND	ND	ND	ND	ND
1,1,2,2-Tetrachlorethane	*0.2*		ND	ND	ND	ND	ND	ND
1,2,3-Trichloropropane	*0.2*		ND	ND	ND	ND	ND	ND
Bromobenzene	*0.2*		ND	ND	ND	ND	ND	ND
T-1,4-Dichloro-2-Butene	*0.7*		ND	ND	ND	ND	ND	ND
n-Propyl Benzene	*0.1*		ND	ND	ND	ND	ND	ND
2-Chloro Toluene	*0.2*		ND	ND	ND	ND	ND	ND
1,3,5-Trimethyl Benzene	*0.2*		ND	ND	ND	ND	ND	ND
4-Chloro Toluene	*0.2*		ND	ND	ND	ND	ND	ND
t-Butyl Benzene	*0.2*		ND	ND	ND	ND	ND	ND
1,2,4-Trimethyl Benzene	*0.3*		ND	ND	ND	ND	ND	ND
Pentachloroethane	*1.0*		ND	ND	ND	ND	ND	ND
sec-Butyl Benzene	*0.1*		ND	ND	ND	ND	ND	ND
p-Isopropyl Toluene	*0.1*		ND	ND	ND	ND	ND	ND
1,4-Dichlorobenzene	*0.2*	*75*	ND	ND	ND	ND	ND	ND
1,3-Dichlorobenzene	*0.2*		ND	ND	ND	ND	ND	ND
n-Butyl Benzene	*0.3*		ND	ND	ND	ND	ND	ND
1,2-Dichlorobenzene	*0.2*	*600*	ND	ND	ND	ND	ND	ND
Hexachloroethane	*0.3*		ND	ND	ND	ND	ND	ND
1,2-Dibromo-3-Chloro Propane	*0.3*		ND	ND	ND	ND	ND	ND
Nitrobenzene	*1.0*		ND	ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	*0.1*	*70*	ND	ND	ND	ND	ND	ND
Hexachlorobutadiene	*0.3*		ND	ND	ND	ND	ND	ND
Naphthalene	*0.3*		ND	ND	ND	ND	ND	ND
1,2,3-Trichloro Benzene	*0.1*		ND	ND	ND	ND	ND	ND
WARNING NOTICES:								

**TTHM = Regulated as Total Trihalomethanes with the total not to exceed 100 ug/L.*
***XYLENES= Regulated as Total Xylenes with the total not to exceed 10,000 ug/L.*

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).

JUN96DW.XLS

REPORT SUBMITTED 6/13/96 BY _____

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #2	WELL #4	WELL #5
Sample Date:			6/12/96	6/12/96	6/12/96	6/12/96	6/12/96	6/12/96
Sampled by:			PM	PM	PM	PM	PM	PM
Analysis Date:			6/12/96	6/12/96	6/12/96	6/12/96	6/12/96	6/12/96
Analyzed by:			KL	KL	KL	KL	KL	KL
	MDL	MCL						
WARNING NOTICES:								
Dichlorodifluoromethane	0.3		ND	ND	ND	ND	ND	ND
Chloromethane	0.6		ND	ND	ND	ND	ND	ND
Vinyl Chloride	0.2	2	ND	ND	ND	ND	ND	ND
Bromomethane	0.4		ND	ND	ND	ND	ND	ND
Chloroethane	0.4		ND	ND	ND	ND	ND	ND
Trichlorofluoromethane	0.2		ND	ND	ND	ND	ND	ND
Diethyl Ether	0.5		ND	ND	ND	ND	ND	ND
1,1-Dichloroethene	0.3	7	ND	ND	ND	ND	ND	ND
Acetone	0.8		ND	ND	ND	ND	ND	ND
Iodomethane	0.6		ND	ND	ND	ND	ND	ND
Carbon Disulfide	1.1		ND	ND	ND	ND	ND	ND
Allyl Chloride	0.3		ND	ND	ND	ND	ND	ND
Methylene Chloride	0.4	5	ND	ND	ND	ND	ND	ND
Acrylonitrile	1.0		ND	ND	ND	ND	ND	ND
t-1,2-Dichloroethene	0.3	100	ND	ND	ND	ND	ND	ND
Methyl -t-Butyl Ether	**0.4**		**ND**	**ND**	**ND**	**ND**	**ND**	**ND**
1,1-Dichloroethane	**0.2**		**ND**	**ND**	**ND**	**0.3**	**ND**	**ND**
2,2-Dichloropropane	1.0		ND	ND	ND	ND	ND	ND
c-1,2-Dichloroethene	**0.2**	70	**0.4**	**1.8**	**3.2**	**4.7**	**ND**	**ND**
Methyl Ethyl Ketone	0.8		ND	ND	ND	ND	ND	ND
Propionitrile	0.3		ND	ND	ND	ND	ND	ND
Methyl Acrylate	0.3		ND	ND	ND	ND	ND	ND
Bromochloromethane	0.3		ND	ND	ND	ND	ND	ND
Methacrylonitrile	0.3		ND	ND	ND	ND	ND	ND
Tetrahydrofuran	0.5		ND	ND	ND	ND	ND	ND
Chloroform	**0.2**	TTHM*	**0.5**	**ND**	**ND**	**ND**	**ND**	**ND**
1,1,1-Trichloroethane	0.3	200	ND	ND	ND	ND	ND	ND
n-Butyl Chloride	0.3		ND	ND	ND	ND	ND	ND
Carbon Tetrachloride	0.1	5	ND	ND	ND	ND	ND	ND
1,1-Dichloropropene	0.2		ND	ND	ND	ND	ND	ND
Benzene	0.2	5	ND	ND	ND	ND	ND	ND
1,2-Dichloroethane	0.3	5	ND	ND	ND	ND	ND	ND
Trichloroethene	**0.1**	5	**ND**	**0.6**	**1.3**	**1.1**	**ND**	**ND**
1,2-Dichloropropane	0.4	5	ND	ND	ND	ND	ND	ND
Dibromomethane	0.3		ND	ND	ND	ND	ND	ND
Methyl Methacrylate	0.2		ND	ND	ND	ND	ND	ND
Bromodichloromethane	**0.3**	TTHM*	**1.2**	**ND**	**ND**	**ND**	**ND**	**ND**
2-Nitropropane	0.3		ND	ND	ND	ND	ND	ND
Chloroacetonitrile	0.4		ND	ND	ND	ND	ND	ND
c-1,3-Dichloropropene	0.2		ND	ND	ND	ND	ND	ND
4-Methyl 2-Pentanone	0.3		ND	ND	ND	ND	ND	ND
Ethyl Methacrylate	0.3		ND	ND	ND	ND	ND	ND
Dichloroacetone	0.3		ND	ND	ND	ND	ND	ND
Toluene	0.2	1000	ND	ND	ND	ND	ND	ND
t-1,3-Dichloropropene	0.2		ND	ND	ND	ND	ND	ND
1,1,2-Trichloroethane	0.3	5	ND	ND	ND	ND	ND	ND
Tetrachloroethene	**0.4**	5	**ND**	**ND**	**0.5**	**0.8**	**ND**	**ND**
1,3-Dichloropropane	0.2		ND	ND	ND	ND	ND	ND
Methyl Butyl Ketone	0.4		ND	ND	ND	ND	ND	ND
Dibromochloromethane	**0.3**	TTHM*	**1.9**	**ND**	**ND**	**ND**	**ND**	**ND**
1,2-Dibromoethane	0.1		ND	ND	ND	ND	ND	ND

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).

JUN96DW.XLS

REPORT SUBMITTED 6/14/96 BY _____

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #2	WELL #4	WELL #5
Sample Date:			6/12/96	6/12/96	6/12/96	6/12/96	6/12/96	6/12/96
Sampled by:			PM	PM	PM	PM	PM	PM
Analysis Date:			6/12/96	6/12/96	6/12/96	6/12/96	6/12/96	6/12/96
Analyzed by:			KL	KL	KL	KL	KL	KL
	MDL	*MCL*						
Chlorobenzene	*0.3*	*100*	ND	ND	ND	ND	ND	ND
1,1,1,2-Tetrachloroethene	*0.3*		ND	ND	ND	ND	ND	ND
Ethylbenzene	*0.1*	*700*	ND	ND	ND	ND	ND	ND
m&p-Xylene	*0.3*	*XYLENES***	ND	ND	ND	ND	ND	ND
o-Xylene	*0.1*	*XYLENES***	ND	ND	ND	ND	ND	ND
Styrene	*0.2*	*100*	ND	ND	ND	ND	ND	ND
Bromoform	***0.2***	*TTHM**	**0.9**	**ND**	**ND**	**ND**	**ND**	**ND**
Isopropyl Benzene	*0.2*		ND	ND	ND	ND	ND	ND
1,1,2,2-Tetrachlorethane	*0.2*		ND	ND	ND	ND	ND	ND
1,2,3-Trichloropropane	*0.2*		ND	ND	ND	ND	ND	ND
Bromobenzene	*0.2*		ND	ND	ND	ND	ND	ND
T-1,4-Dichloro-2-Butene	*0.7*		ND	ND	ND	ND	ND	ND
n-Propyl Benzene	*0.1*		ND	ND	ND	ND	ND	ND
2-Chloro Toluene	*0.2*		ND	ND	ND	ND	ND	ND
1,3,5-Trimethyl Benzene	*0.2*		ND	ND	ND	ND	ND	ND
4-Chloro Toluene	*0.2*		ND	ND	ND	ND	ND	ND
t-Butyl Benzene	*0.2*		ND	ND	ND	ND	ND	ND
1,2,4-Trimethyl Benzene	*0.3*		ND	ND	ND	ND	ND	ND
Pentachloroethane	*1.0*		ND	ND	ND	ND	ND	ND
sec-Butyl Benzene	*0.1*		ND	ND	ND	ND	ND	ND
p-Isopropyl Toluene	*0.1*		ND	ND	ND	ND	ND	ND
1,4-Dichlorobenzene	*0.2*	*75*	ND	ND	ND	ND	ND	ND
1,3-Dichlorobenzene	*0.2*		ND	ND	ND	ND	ND	ND
n-Butyl Benzene	*0.3*		ND	ND	ND	ND	ND	ND
1,2-Dichlorobenzene	*0.2*	*600*	ND	ND	ND	ND	ND	ND
Hexachloroethane	*0.3*		ND	ND	ND	ND	ND	ND
1,2-Dibromo-3-Chloro Propane	*0.3*		ND	ND	ND	ND	ND	ND
Nitrobenzene	*1.0*		ND	ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	*0.1*	*70*	ND	ND	ND	ND	ND	ND
Hexachlorobutadiene	*0.3*		ND	ND	ND	ND	ND	ND
Naphthalene	*0.3*		ND	ND	ND	ND	ND	ND
1,2,3-Trichloro Benzene	*0.1*		ND	ND	ND	ND	ND	ND
WARNING NOTICES:								

**TTHM = Regulated as Total Trihalomethanes with the total not to exceed 100 ug/L.*
***XYLENES= Regulated as Total Xylenes with the total not to exceed 10,000 ug/L.*

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).

JUN96DW.XLS

REPORT SUBMITTED 6/14/96 BY _____

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #2	WELL #4	WELL #5
Sample Date:			6/14/96	6/14/96	6/14/96	6/14/96	6/14/96	6/14/96
Sampled by:			PM	PM	PM	PM	PM	PM
Analysis Date:			6/14/96	6/14/96	6/14/96	6/14/96	6/14/96	6/14/96
Analyzed by:			KL	KL	KL	KL	KL	KL
	MDL	MCL						
WARNING NOTICES:								
Dichlorodifluoromethane	0.3		ND	ND	ND	ND	ND	ND
Chloromethane	0.6		ND	ND	ND	ND	ND	ND
Vinyl Chloride	0.2	2	ND	ND	ND	ND	ND	ND
Bromomethane	0.4		ND	ND	ND	ND	ND	ND
Chloroethane	0.4		ND	ND	ND	ND	ND	ND
Trichlorofluoromethane	0.2		ND	ND	ND	ND	ND	ND
Diethyl Ether	0.5		ND	ND	ND	ND	ND	ND
1,1-Dichloroethene	0.3	7	ND	ND	ND	ND	ND	ND
Acetone	0.8		ND	ND	ND	ND	ND	ND
Iodomethane	0.6		ND	ND	ND	ND	ND	ND
Carbon Disulfide	1.1		ND	ND	ND	ND	ND	ND
Allyl Chloride	0.3		ND	ND	ND	ND	ND	ND
Methylene Chloride	0.4	5	ND	ND	ND	ND	ND	ND
Acrylonitrile	1.0		ND	ND	ND	ND	ND	ND
t-1,2-Dichloroethene	0.3	100	ND	ND	ND	ND	ND	ND
Methyl -t-Butyl Ether	**0.4**		**ND**	**ND**	**ND**	**ND**	**ND**	**ND**
1,1-Dichloroethane	**0.2**		**ND**	**ND**	**ND**	**ND**	**ND**	**ND**
2,2-Dichloropropane	1.0		ND	ND	ND	ND	ND	ND
c-1,2-Dichloroethene	**0.2**	70	**0.5**	**2.0**	**3.3**	**4.6**	**ND**	**ND**
Methyl Ethyl Ketone	0.8		ND	ND	ND	ND	ND	ND
Propionitrile	0.3		ND	ND	ND	ND	ND	ND
Methyl Acrylate	0.3		ND	ND	ND	ND	ND	ND
Bromochloromethane	0.3		ND	ND	ND	ND	ND	ND
Methacrylonitrile	0.3		ND	ND	ND	ND	ND	ND
Tetrahydrofuran	0.5		ND	ND	ND	ND	ND	ND
Chloroform	**0.2**	TTHM*	**ND**	**ND**	**ND**	**ND**	**ND**	**ND**
1,1,1-Trichloroethane	0.3	200	ND	ND	ND	ND	ND	ND
n-Butyl Chloride	0.3		ND	ND	ND	ND	ND	ND
Carbon Tetrachloride	0.1	5	ND	ND	ND	ND	ND	ND
1,1-Dichloropropene	0.2		ND	ND	ND	ND	ND	ND
Benzene	0.2	5	ND	ND	ND	ND	ND	ND
1,2-Dichloroethane	0.3	5	ND	ND	ND	ND	ND	ND
Trichloroethene	**0.1**	5	**ND**	**0.6**	**1.4**	**1.0**	**ND**	**ND**
1,2-Dichloropropane	0.4	5	ND	ND	ND	ND	ND	ND
Dibromomethane	0.3		ND	ND	ND	ND	ND	ND
Methyl Methacrylate	0.2		ND	ND	ND	ND	ND	ND
Bromodichloromethane	**0.3**	TTHM*	**0.9**	**ND**	**ND**	**ND**	**ND**	**ND**
2-Nitropropane	0.3		ND	ND	ND	ND	ND	ND
Chloroacetonitrile	0.4		ND	ND	ND	ND	ND	ND
c-1,3-Dichloropropene	0.2		ND	ND	ND	ND	ND	ND
4-Methyl 2-Pentanone	0.3		ND	ND	ND	ND	ND	ND
Ethyl Methacrylate	0.3		ND	ND	ND	ND	ND	ND
Dichloroacetone	0.3		ND	ND	ND	ND	ND	ND
Toluene	0.2	1000	ND	ND	ND	ND	ND	ND
t-1,3-Dichloropropene	0.2		ND	ND	ND	ND	ND	ND
1,1,2-Trichloroethane	0.3	5	ND	ND	ND	ND	ND	ND
Tetrachloroethene	**0.4**	5	**ND**	**ND**	**0.5**	**0.8**	**ND**	**ND**
1,3-Dichloropropane	0.2		ND	ND	ND	ND	ND	ND
Methyl Butyl Ketone	0.4		ND	ND	ND	ND	ND	ND
Dibromochloromethane	**0.3**	TTHM*	**1.7**	**ND**	**ND**	**ND**	**ND**	**ND**
1,2-Dibromoethane	0.1		ND	ND	ND	ND	ND	ND

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).

JUN96DW.XLS

REPORT SUBMITTED 6/17/96 BY _____

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #2	WELL #4	WELL #5
Sample Date:			6/14/96	6/14/96	6/14/96	6/14/96	6/14/96	6/14/96
Sampled by:			PM	PM	PM	PM	PM	PM
Analysis Date:			6/14/96	6/14/96	6/14/96	6/14/96	6/14/96	6/14/96
Analyzed by:			KL	KL	KL	KL	KL	KL
	MDL	*MCL*						
Chlorobenzene	*0.3*	*100*	ND	ND	ND	ND	ND	ND
1,1,1,2-Tetrachloroethene	*0.3*		ND	ND	ND	ND	ND	ND
Ethylbenzene	*0.1*	*700*	ND	ND	ND	ND	ND	ND
m&p-Xylene	*0.3*	*XYLENES***	ND	ND	ND	ND	ND	ND
o-Xylene	*0.1*	*XYLENES***	ND	ND	ND	ND	ND	ND
Styrene	*0.2*	*100*	ND	ND	ND	ND	ND	ND
Bromoform	***0.2***	***TTHM****	**0.6**	**ND**	**ND**	**ND**	**ND**	**ND**
Isopropyl Benzene	*0.2*		ND	ND	ND	ND	ND	ND
1,1,2,2-Tetrachlorethane	*0.2*		ND	ND	ND	ND	ND	ND
1,2,3-Trichloropropane	*0.2*		ND	ND	ND	ND	ND	ND
Bromobenzene	*0.2*		ND	ND	ND	ND	ND	ND
T-1,4-Dichloro-2-Butene	*0.7*		ND	ND	ND	ND	ND	ND
n-Propyl Benzene	*0.1*		ND	ND	ND	ND	ND	ND
2-Chloro Toluene	*0.2*		ND	ND	ND	ND	ND	ND
1,3,5-Trimethyl Benzene	*0.2*		ND	ND	ND	ND	ND	ND
4-Chloro Toluene	*0.2*		ND	ND	ND	ND	ND	ND
t-Butyl Benzene	*0.2*		ND	ND	ND	ND	ND	ND
1,2,4-Trimethyl Benzene	*0.3*		ND	ND	ND	ND	ND	ND
Pentachloroethane	*1.0*		ND	ND	ND	ND	ND	ND
sec-Butyl Benzene	*0.1*		ND	ND	ND	ND	ND	ND
p-Isopropyl Toluene	*0.1*		ND	ND	ND	ND	ND	ND
1,4-Dichlorobenzene	*0.2*	*75*	ND	ND	ND	ND	ND	ND
1,3-Dichlorobenzene	*0.2*		ND	ND	ND	ND	ND	ND
n-Butyl Benzene	*0.3*		ND	ND	ND	ND	ND	ND
1,2-Dichlorobenzene	*0.2*	*600*	ND	ND	ND	ND	ND	ND
Hexachloroethane	*0.3*		ND	ND	ND	ND	ND	ND
1,2-Dibromo-3-Chloro Propane	*0.3*		ND	ND	ND	ND	ND	ND
Nitrobenzene	*1.0*		ND	ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	*0.1*	*70*	ND	ND	ND	ND	ND	ND
Hexachlorobutadiene	*0.3*		ND	ND	ND	ND	ND	ND
Naphthalene	*0.3*		ND	ND	ND	ND	ND	ND
1,2,3-Trichloro Benzene	*0.1*		ND	ND	ND	ND	ND	ND
WARNING NOTICES:								

**TTHM = Regulated as Total Trihalomethanes with the total not to exceed 100 ug/L.*
***XYLENES= Regulated as Total Xylenes with the total not to exceed 10,000 ug/L.*

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).

JUN96DW.XLS

REPORT SUBMITTED 6/17/96 BY _____

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #2	WELL #4	WELL #5
Sample Date:			6/17/96	6/17/96	6/17/96	6/17/96	6/17/96	6/17/96
Sampled by:			JB	JB	JB	JB	JB	JB
Analysis Date:			6/18/96	6/18/96	6/18/96	6/18/96	6/18/96	6/18/96
Analyzed by:			KL	KL	KL	KL	KL	KL
	MDL	*MCL*						
MCL WARNING NOTICES:								
Dichlorodifluoromethane	*0.3*		ND	ND	ND	ND	ND	ND
Chloromethane	*0.6*		ND	ND	ND	ND	ND	ND
Vinyl Chloride	*0.2*	*2*	ND	ND	ND	ND	ND	ND
Bromomethane	*0.4*		ND	ND	ND	ND	ND	ND
Chloroethane	*0.4*		ND	ND	ND	ND	ND	ND
Trichlorofluoromethane	*0.2*		ND	ND	ND	ND	ND	ND
Diethyl Ether	*0.5*		ND	ND	ND	ND	ND	ND
1,1-Dichloroethene	*0.3*	*7*	ND	ND	ND	ND	ND	ND
Acetone	*0.8*		ND	ND	ND	ND	ND	ND
Iodomethane	*0.6*		ND	ND	ND	ND	ND	ND
Carbon Disulfide	*1.1*		ND	ND	ND	ND	ND	ND
Allyl Chloride	*0.3*		ND	ND	ND	ND	ND	ND
Methylene Chloride	*0.4*	*5*	ND	ND	ND	ND	ND	ND
Acrylonitrile	*1.0*		ND	ND	ND	ND	ND	ND
t-1,2-Dichloroethene	*0.3*	*100*	ND	ND	ND	ND	ND	ND
Methyl -t-Butyl Ether	*0.4*		ND	ND	ND	ND	ND	ND
1,1-Dichloroethane	***0.2***		**ND**	**ND**	**ND**	**0.3**	**ND**	**ND**
2,2-Dichloropropane	*1.0*		ND	ND	ND	ND	ND	ND
c-1,2-Dichloroethene	***0.2***	*70*	**0.4**	**2.0**	**3.4**	**4.7**	**ND**	**ND**
Methyl Ethyl Ketone	*0.8*		ND	ND	ND	ND	ND	ND
Propionitrile	*0.3*		ND	ND	ND	ND	ND	ND
Methyl Acrylate	*0.3*		ND	ND	ND	ND	ND	ND
Bromochloromethane	*0.3*		ND	ND	ND	ND	ND	ND
Methacrylonitrile	*0.3*		ND	ND	ND	ND	ND	ND
Tetrahydrofuran	*0.5*		ND	ND	ND	ND	ND	ND
Chloroform	***0.2***	*TTHM**	**2.4**	**ND**	**ND**	**ND**	**ND**	**ND**
1,1,1-Trichloroethane	*0.3*	*200*	ND	ND	ND	ND	ND	ND
n-Butyl Chloride	*0.3*		ND	ND	ND	ND	ND	ND
Carbon Tetrachloride	*0.1*	*5*	ND	ND	ND	ND	ND	ND
1,1-Dichloropropene	*0.2*		ND	ND	ND	ND	ND	ND
Benzene	*0.2*	*5*	ND	ND	ND	ND	ND	ND
1,2-Dichloroethane	*0.3*	*5*	ND	ND	ND	ND	ND	ND
Trichloroethene	***0.1***	*5*	**ND**	**0.6**	**1.4**	**1.1**	**ND**	**ND**
1,2-Dichloropropane	*0.4*	*5*	ND	ND	ND	ND	ND	ND
Dibromomethane	*0.3*		ND	ND	ND	ND	ND	ND
Methyl Methacrylate	*0.2*		ND	ND	ND	ND	ND	ND
Bromodichloromethane	***0.3***	*TTHM**	**4.1**	**ND**	**ND**	**ND**	**ND**	**ND**
2-Nitropropane	*0.3*		ND	ND	ND	ND	ND	ND
Chloroacetonitrile	*0.4*		ND	ND	ND	ND	ND	ND
c-1,3-Dichloropropene	*0.2*		ND	ND	ND	ND	ND	ND
4-Methyl 2-Pentanone	*0.3*		ND	ND	ND	ND	ND	ND
Ethyl Methacrylate	*0.3*		ND	ND	ND	ND	ND	ND
Dichloroacetone	*0.3*		ND	ND	ND	ND	ND	ND
Toluene	*0.2*	*1000*	ND	ND	ND	ND	ND	ND
t-1,3-Dichloropropene	*0.2*		ND	ND	ND	ND	ND	ND
1,1,2-Trichloroethane	*0.3*	*5*	ND	ND	ND	ND	ND	ND
Tetrachloroethene	***0.4***	*5*	**ND**	**ND**	**0.6**	**0.8**	**ND**	**ND**
1,3-Dichloropropane	*0.2*		ND	ND	ND	ND	ND	ND
Methyl Butyl Ketone	*0.4*		ND	ND	ND	ND	ND	ND
Dibromochloromethane	***0.3***	*TTHM**	**5.9**	**ND**	**ND**	**ND**	**ND**	**ND**
1,2-Dibromoethane	*0.1*		ND	ND	ND	ND	ND	ND

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).

JUN96DW.XLS

REPORT SUBMITTED 6/20/96 BY _____

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #2	WELL #4	WELL #5
Sample Date:			6/17/96	6/17/96	6/17/96	6/17/96	6/17/96	6/17/96
Sampled by:			JB	JB	JB	JB	JB	JB
Analysis Date:			6/18/96	6/18/96	6/18/96	6/18/96	6/18/96	6/18/96
Analyzed by:			KL	KL	KL	KL	KL	KL
	MDL	MCL						
Chlorobenzene	0.3	100	ND	ND	ND	ND	ND	ND
1,1,1,2-Tetrachloroethene	0.3		ND	ND	ND	ND	ND	ND
Ethylbenzene	0.1	700	ND	ND	ND	ND	ND	ND
m&p-Xylene	0.3	XYLENES**	ND	ND	ND	ND	ND	ND
o-Xylene	0.1	XYLENES**	ND	ND	ND	ND	ND	ND
Styrene	0.2	100	ND	ND	ND	ND	ND	ND
Bromoform	**0.2**	TTHM*	**2.5**	**ND**	**ND**	**ND**	**ND**	**ND**
Isopropyl Benzene	0.2		ND	ND	ND	ND	ND	ND
1,1,2,2-Tetrachlorethane	0.2		ND	ND	ND	ND	ND	ND
1,2,3-Trichloropropane	0.2		ND	ND	ND	ND	ND	ND
Bromobenzene	0.2		ND	ND	ND	ND	ND	ND
T-1,4-Dichloro-2-Butene	0.7		ND	ND	ND	ND	ND	ND
n-Propyl Benzene	0.1		ND	ND	ND	ND	ND	ND
2-Chloro Toluene	0.2		ND	ND	ND	ND	ND	ND
1,3,5-Trimethyl Benzene	0.2		ND	ND	ND	ND	ND	ND
4-Chloro Toluene	0.2		ND	ND	ND	ND	ND	ND
t-Butyl Benzene	0.2		ND	ND	ND	ND	ND	ND
1,2,4-Trimethyl Benzene	0.3		ND	ND	ND	ND	ND	ND
Pentachloroethane	1.0		ND	ND	ND	ND	ND	ND
sec-Butyl Benzene	0.1		ND	ND	ND	ND	ND	ND
p-Isopropyl Toluene	0.1		ND	ND	ND	ND	ND	ND
1,4-Dichlorobenzene	0.2	75	ND	ND	ND	ND	ND	ND
1,3-Dichlorobenzene	0.2		ND	ND	ND	ND	ND	ND
n-Butyl Benzene	0.3		ND	ND	ND	ND	ND	ND
1,2-Dichlorobenzene	0.2	600	ND	ND	ND	ND	ND	ND
Hexachloroethane	0.3		ND	ND	ND	ND	ND	ND
1,2-Dibromo-3-Chloro Propane	0.3		ND	ND	ND	ND	ND	ND
Nitrobenzene	1.0		ND	ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	0.1	70	ND	ND	ND	ND	ND	ND
Hexachlorobutadiene	0.3		ND	ND	ND	ND	ND	ND
Naphthalene	0.3		ND	ND	ND	ND	ND	ND
1,2,3-Trichloro Benzene	0.1		ND	ND	ND	ND	ND	ND
MCL WARNING NOTICES:								

**TTHM = Regulated as Total Trihalomethanes with the total not to exceed 100 ug/L.*
***XYLENES= Regulated as Total Xylenes with the total not to exceed 10,000 ug/L.*

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).

JUN96DW.XLS

REPORT SUBMITTED 6/20/96 BY _____

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #2	WELL #4	WELL #5
Sample Date:			6/19/96	6/19/96	6/19/96	6/19/96	6/19/96	6/19/96
Sampled by:			PM	PM	PM	PM	PM	PM
Analysis Date:			6/20/96	6/20/96	6/20/96	6/20/96	6/20/96	6/20/96
Analyzed by:			KL	KL	KL	KL	KL	KL
	MDL	MCL						
VOL WARNING NOTICES:								
Dichlorodifluoromethane	0.3		ND	ND	ND	ND	ND	ND
Chloromethane	0.6		ND	ND	ND	ND	ND	ND
Vinyl Chloride	0.2	2	ND	ND	ND	ND	ND	ND
Bromomethane	0.4		ND	ND	ND	ND	ND	ND
Chloroethane	0.4		ND	ND	ND	ND	ND	ND
Trichlorofluoromethane	0.2		ND	ND	ND	ND	ND	ND
Diethyl Ether	0.5		ND	ND	ND	ND	ND	ND
1,1-Dichloroethene	0.3	7	ND	ND	ND	ND	ND	ND
Acetone	0.8		ND	ND	ND	ND	ND	ND
Iodomethane	0.6		ND	ND	ND	ND	ND	ND
Carbon Disulfide	1.1		ND	ND	ND	ND	ND	ND
Allyl Chloride	0.3		ND	ND	ND	ND	ND	ND
Methylene Chloride	0.4	5	ND	ND	ND	ND	ND	ND
Acrylonitrile	1.0		ND	ND	ND	ND	ND	ND
t-1,2-Dichloroethene	0.3	100	ND	ND	ND	ND	ND	ND
Methyl -t-Butyl Ether	0.4		ND	ND	ND	ND	ND	ND
1,1-Dichloroethane	**0.2**		**ND**	**ND**	**ND**	**0.4**	**ND**	**ND**
2,2-Dichloropropane	1.0		ND	ND	ND	ND	ND	ND
c-1,2-Dichloroethene	**0.2**	70	**0.4**	**1.9**	**3.6**	**4.7**	**ND**	**ND**
Methyl Ethyl Ketone	0.8		ND	ND	ND	ND	ND	ND
Propionitrile	0.3		ND	ND	ND	ND	ND	ND
Methyl Acrylate	0.3		ND	ND	ND	ND	ND	ND
Bromochloromethane	0.3		ND	ND	ND	ND	ND	ND
Methacrylonitrile	0.3		ND	ND	ND	ND	ND	ND
Tetrahydrofuran	0.5		ND	ND	ND	ND	ND	ND
Chloroform	**0.2**	TTHM*	**ND**	**ND**	**ND**	**ND**	**ND**	**ND**
1,1,1-Trichloroethane	0.3	200	ND	ND	ND	ND	ND	ND
n-Butyl Chloride	0.3		ND	ND	ND	ND	ND	ND
Carbon Tetrachloride	0.1	5	ND	ND	ND	ND	ND	ND
1,1-Dichloropropene	0.2		ND	ND	ND	ND	ND	ND
Benzene	0.2	5	ND	ND	ND	ND	ND	ND
1,2-Dichloroethane	0.3	5	ND	ND	ND	ND	ND	ND
Trichloroethene	**0.1**	5	**ND**	**0.6**	**1.4**	**1.0**	**ND**	**ND**
1,2-Dichloropropane	0.4	5	ND	ND	ND	ND	ND	ND
Dibromomethane	0.3		ND	ND	ND	ND	ND	ND
Methyl Methacrylate	0.2		ND	ND	ND	ND	ND	ND
Bromodichloromethane	**0.3**	TTHM*	**1.0**	**ND**	**ND**	**ND**	**ND**	**ND**
2-Nitropropane	0.3		ND	ND	ND	ND	ND	ND
Chloroacetonitrile	0.4		ND	ND	ND	ND	ND	ND
c-1,3-Dichloropropene	0.2		ND	ND	ND	ND	ND	ND
4-Methyl 2-Pentanone	0.3		ND	ND	ND	ND	ND	ND
Ethyl Methacrylate	0.3		ND	ND	ND	ND	ND	ND
Dichloroacetone	0.3		ND	ND	ND	ND	ND	ND
Toluene	0.2	1000	ND	ND	ND	ND	ND	ND
t-1,3-Dichloropropene	0.2		ND	ND	ND	ND	ND	ND
1,1,2-Trichloroethane	0.3	5	ND	ND	ND	ND	ND	ND
Tetrachloroethene	**0.4**	5	**ND**	**ND**	**0.6**	**0.9**	**ND**	**ND**
1,3-Dichloropropane	0.2		ND	ND	ND	ND	ND	ND
Methyl Butyl Ketone	0.4		ND	ND	ND	ND	ND	ND
Dibromochloromethane	**0.3**	TTHM*	**1.9**	**ND**	**ND**	**ND**	**ND**	**ND**
1,2-Dibromoethane	0.1		ND	ND	ND	ND	ND	ND

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).

JUN96DW.XLS

REPORT SUBMITTED 7/2/96 BY _____

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #2	WELL #4	WELL #5
Sample Date:			6/19/96	6/19/96	6/19/96	6/19/96	6/19/96	6/19/96
Sampled by:			PM	PM	PM	PM	PM	PM
Analysis Date:			6/20/96	6/20/96	6/20/96	6/20/96	6/20/96	6/20/96
Analyzed by:			KL	KL	KL	KL	KL	KL
	MDL	MCL						
Chlorobenzene	0.3	100	ND	ND	ND	ND	ND	ND
1,1,1,2-Tetrachloroethene	0.3		ND	ND	ND	ND	ND	ND
Ethylbenzene	0.1	700	ND	ND	ND	ND	ND	ND
m&p-Xylene	0.3	XYLENES**	ND	ND	ND	ND	ND	ND
o-Xylene	0.1	XYLENES**	ND	ND	ND	ND	ND	ND
Styrene	0.2	100	ND	ND	ND	ND	ND	ND
Bromoform	**0.2**	**TTHM***	**0.8**	**ND**	**ND**	**ND**	**ND**	**ND**
Isopropyl Benzene	0.2		ND	ND	ND	ND	ND	ND
1,1,2,2-Tetrachlorethane	0.2		ND	ND	ND	ND	ND	ND
1,2,3-Trichloropropane	0.2		ND	ND	ND	ND	ND	ND
Bromobenzene	0.2		ND	ND	ND	ND	ND	ND
T-1,4-Dichloro-2-Butene	0.7		ND	ND	ND	ND	ND	ND
n-Propyl Benzene	0.1		ND	ND	ND	ND	ND	ND
2-Chloro Toluene	0.2		ND	ND	ND	ND	ND	ND
1,3,5-Trimethyl Benzene	0.2		ND	ND	ND	ND	ND	ND
4-Chloro Toluene	0.2		ND	ND	ND	ND	ND	ND
t-Butyl Benzene	0.2		ND	ND	ND	ND	ND	ND
1,2,4-Trimethyl Benzene	0.3		ND	ND	ND	ND	ND	ND
Pentachloroethane	1.0		ND	ND	ND	ND	ND	ND
sec-Butyl Benzene	0.1		ND	ND	ND	ND	ND	ND
p-Isopropyl Toluene	0.1		ND	ND	ND	ND	ND	ND
1,4-Dichlorobenzene	0.2	75	ND	ND	ND	ND	ND	ND
1,3-Dichlorobenzene	0.2		ND	ND	ND	ND	ND	ND
n-Butyl Benzene	0.3		ND	ND	ND	ND	ND	ND
1,2-Dichlorobenzene	0.2	600	ND	ND	ND	ND	ND	ND
Hexachloroethane	0.3		ND	ND	ND	ND	ND	ND
1,2-Dibromo-3-Chloro Propane	0.3		ND	ND	ND	ND	ND	ND
Nitrobenzene	1.0		ND	ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	0.1	70	ND	ND	ND	ND	ND	ND
Hexachlorobutadiene	0.3		ND	ND	ND	ND	ND	ND
Naphthalene	0.3		ND	ND	ND	ND	ND	ND
1,2,3-Trichloro Benzene	0.1		ND	ND	ND	ND	ND	ND
MCL WARNING NOTICES:								

**TTHM = Regulated as Total Trihalomethanes with the total not to exceed 100 ug/L.*
***XYLENES= Regulated as Total Xylenes with the total not to exceed 10,000 ug/L.*

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).

JUN96DW.XLS

REPORT SUBMITTED 7/2/96 BY _____

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #2	WELL #4	WELL #5
Sample Date:			6/21/96	6/21/96	6/21/96	6/21/96	6/21/96	6/21/96
Sampled by:			JB	JB	JB	JB	JB	JB
Analysis Date:			6/24/96	6/24/96	6/24/96	6/24/96	6/24/96	6/24/96
Analyzed by:			KL	KL	KL	KL	KL	KL
	MDL	MCL						
MCL WARNING NOTICES:								
Dichlorodifluoromethane	0.3		ND	ND	ND	ND	ND	ND
Chloromethane	0.6		ND	ND	ND	ND	ND	ND
Vinyl Chloride	0.2	2	ND	ND	ND	ND	ND	ND
Bromomethane	0.4		ND	ND	ND	ND	ND	ND
Chloroethane	0.4		ND	ND	ND	ND	ND	ND
Trichlorofluoromethane	0.2		ND	ND	ND	ND	ND	ND
Diethyl Ether	0.5		ND	ND	ND	ND	ND	ND
1,1-Dichloroethene	0.3	7	ND	ND	ND	ND	ND	ND
Acetone	0.8		ND	ND	ND	ND	ND	ND
Iodomethane	0.6		ND	ND	ND	ND	ND	ND
Carbon Disulfide	1.1		ND	ND	ND	ND	ND	ND
Allyl Chloride	0.3		ND	ND	ND	ND	ND	ND
Methylene Chloride	0.4	5	ND	ND	ND	ND	ND	ND
Acrylonitrile	1.0		ND	ND	ND	ND	ND	ND
t-1,2-Dichloroethene	0.3	100	ND	ND	ND	ND	ND	ND
Methyl -t-Butyl Ether	0.4		ND	ND	ND	ND	ND	ND
1,1-Dichloroethane	**0.2**		**ND**	**ND**	**ND**	**0.4**	**ND**	**ND**
2,2-Dichloropropane	1.0		ND	ND	ND	ND	ND	ND
c-1,2-Dichloroethene	**0.2**	70	**0.4**	**1.9**	**3.5**	**4.5**	**ND**	**ND**
Methyl Ethyl Ketone	0.8		ND	ND	ND	ND	ND	ND
Propionitrile	0.3		ND	ND	ND	ND	ND	ND
Methyl Acrylate	0.3		ND	ND	ND	ND	ND	ND
Bromochloromethane	0.3		ND	ND	ND	ND	ND	ND
Methacrylonitrile	0.3		ND	ND	ND	ND	ND	ND
Tetrahydrofuran	0.5		ND	ND	ND	ND	ND	ND
Chloroform	**0.2**	TTHM*	**ND**	**ND**	**ND**	**ND**	**ND**	**ND**
1,1,1-Trichloroethane	0.3	200	ND	ND	ND	ND	ND	ND
n-Butyl Chloride	0.3		ND	ND	ND	ND	ND	ND
Carbon Tetrachloride	0.1	5	ND	ND	ND	ND	ND	ND
1,1-Dichloropropene	0.2		ND	ND	ND	ND	ND	ND
Benzene	0.2	5	ND	ND	ND	ND	ND	ND
1,2-Dichloroethane	0.3	5	ND	ND	ND	ND	ND	ND
Trichloroethene	**0.1**	5	**ND**	**0.6**	**1.4**	**1.0**	**ND**	**ND**
1,2-Dichloropropane	0.4	5	ND	ND	ND	ND	ND	ND
Dibromomethane	0.3		ND	ND	ND	ND	ND	ND
Methyl Methacrylate	0.2		ND	ND	ND	ND	ND	ND
Bromodichloromethane	**0.3**	TTHM*	**ND**	**ND**	**ND**	**ND**	**ND**	**ND**
2-Nitropropane	0.3		ND	ND	ND	ND	ND	ND
Chloroacetonitrile	0.4		ND	ND	ND	ND	ND	ND
c-1,3-Dichloropropene	0.2		ND	ND	ND	ND	ND	ND
4-Methyl 2-Pentanone	0.3		ND	ND	ND	ND	ND	ND
Ethyl Methacrylate	0.3		ND	ND	ND	ND	ND	ND
Dichloroacetone	0.3		ND	ND	ND	ND	ND	ND
Toluene	0.2	1000	ND	ND	ND	ND	ND	ND
t-1,3-Dichloropropene	0.2		ND	ND	ND	ND	ND	ND
1,1,2-Trichloroethane	0.3	5	ND	ND	ND	ND	ND	ND
Tetrachloroethene	**0.4**	5	**ND**	**0.5**	**0.6**	**0.8**	**ND**	**ND**
1,3-Dichloropropane	0.2		ND	ND	ND	ND	ND	ND
Methyl Butyl Ketone	0.4		ND	ND	ND	ND	ND	ND
Dibromochloromethane	**0.3**	TTHM*	**ND**	**ND**	**ND**	**ND**	**ND**	**ND**
1,2-Dibromoethane	0.1		ND	ND	ND	ND	ND	ND

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).

JUN96DW.XLS

REPORT SUBMITTED 6/26/96 BY _____

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #2	WELL #4	WELL #5
Sample Date:			6/21/96	6/21/96	6/21/96	6/21/96	6/21/96	6/21/96
Sampled by:			JB	JB	JB	JB	JB	JB
Analysis Date:			6/24/96	6/24/96	6/24/96	6/24/96	6/24/96	6/24/96
Analyzed by:			KL	KL	KL	KL	KL	KL
	MDL	MCL						
Chlorobenzene	0.3	100	ND	ND	ND	ND	ND	ND
1,1,1,2-Tetrachloroethene	0.3		ND	ND	ND	ND	ND	ND
Ethylbenzene	0.1	700	ND	ND	ND	ND	ND	ND
m&p-Xylene	0.3	XYLENES**	ND	ND	ND	ND	ND	ND
o-Xylene	0.1	XYLENES**	ND	ND	ND	ND	ND	ND
Styrene	0.2	100	ND	ND	ND	ND	ND	ND
Bromoform	**0.2**	**TTHM***	**ND**	**ND**	**ND**	**ND**	**ND**	**ND**
Isopropyl Benzene	0.2		ND	ND	ND	ND	ND	ND
1,1,2,2-Tetrachlorethane	0.2		ND	ND	ND	ND	ND	ND
1,2,3-Trichloropropane	0.2		ND	ND	ND	ND	ND	ND
Bromobenzene	0.2		ND	ND	ND	ND	ND	ND
T-1,4-Dichloro-2-Butene	0.7		ND	ND	ND	ND	ND	ND
n-Propyl Benzene	0.1		ND	ND	ND	ND	ND	ND
2-Chloro Toluene	0.2		ND	ND	ND	ND	ND	ND
1,3,5-Trimethyl Benzene	0.2		ND	ND	ND	ND	ND	ND
4-Chloro Toluene	0.2		ND	ND	ND	ND	ND	ND
t-Butyl Benzene	0.2		ND	ND	ND	ND	ND	ND
1,2,4-Trimethyl Benzene	0.3		ND	ND	ND	ND	ND	ND
Pentachloroethane	1.0		ND	ND	ND	ND	ND	ND
sec-Butyl Benzene	0.1		ND	ND	ND	ND	ND	ND
p-Isopropyl Toluene	0.1		ND	ND	ND	ND	ND	ND
1,4-Dichlorobenzene	0.2	75	ND	ND	ND	ND	ND	ND
1,3-Dichlorobenzene	0.2		ND	ND	ND	ND	ND	ND
n-Butyl Benzene	0.3		ND	ND	ND	ND	ND	ND
1,2-Dichlorobenzene	0.2	600	ND	ND	ND	ND	ND	ND
Hexachloroethane	0.3		ND	ND	ND	ND	ND	ND
1,2-Dibromo-3-Chloro Propane	0.3		ND	ND	ND	ND	ND	ND
Nitrobenzene	1.0		ND	ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	0.1	70	ND	ND	ND	ND	ND	ND
Hexachlorobutadiene	0.3		ND	ND	ND	ND	ND	ND
Naphthalene	0.3		ND	ND	ND	ND	ND	ND
1,2,3-Trichloro Benzene	0.1		ND	ND	ND	ND	ND	ND
MCL WARNING NOTICES:								

*TTHM = Regulated as Total Trihalomethanes with the total not to exceed 100 ug/L.
**XYLENES= Regulated as Total Xylenes with the total not to exceed 10,000 ug/L.

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).

JUN96DW.XLS

REPORT SUBMITTED 6/26/96 BY _____

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #2	WELL #4	WELL #5
Sample Date:			6/24/96	6/24/96	6/24/96	6/24/96	6/24/96	6/24/96
Sampled by:			PM	PM	PM	PM	PM	PM
Analysis Date:			6/26/96	6/26/96	6/26/96	6/26/96	6/26/96	6/26/96
Analyzed by:			KL	KL	KL	KL	KL	KL
	MDL	MCL						
WARNING NOTICES:								
Dichlorodifluoromethane	0.3		ND	ND	ND	ND	ND	ND
Chloromethane	0.6		ND	ND	ND	ND	ND	ND
Vinyl Chloride	0.2	2	ND	ND	ND	ND	ND	ND
Bromomethane	0.4		ND	ND	ND	ND	ND	ND
Chloroethane	0.4		ND	ND	ND	ND	ND	ND
Trichlorofluoromethane	0.2		ND	ND	ND	ND	ND	ND
Diethyl Ether	0.5		ND	ND	ND	ND	ND	ND
1,1-Dichloroethene	0.3	7	ND	ND	ND	ND	ND	ND
Acetone	0.8		ND	ND	ND	ND	ND	ND
Iodomethane	0.6		ND	ND	ND	ND	ND	ND
Carbon Disulfide	1.1		ND	ND	ND	ND	ND	ND
Allyl Chloride	0.3		ND	ND	ND	ND	ND	ND
Methylene Chloride	0.4	5	ND	ND	ND	ND	ND	ND
Acrylonitrile	1.0		ND	ND	ND	ND	ND	ND
t-1,2-Dichloroethene	0.3	100	ND	ND	ND	ND	ND	ND
Methyl -t-Butyl Ether	0.4		ND	ND	ND	ND	ND	ND
1,1-Dichloroethane	0.2		ND	ND	ND	ND	ND	ND
2,2-Dichloropropane	1.0		ND	ND	ND	ND	ND	ND
c-1,2-Dichloroethene	**0.2**	70	**0.4**	**2.0**	**3.6**	**4.6**	**ND**	**ND**
Methyl Ethyl Ketone	0.8		ND	ND	ND	ND	ND	ND
Propionitrile	0.3		ND	ND	ND	ND	ND	ND
Methyl Acrylate	0.3		ND	ND	ND	ND	ND	ND
Bromochloromethane	0.3		ND	ND	ND	ND	ND	ND
Methacrylonitrile	0.3		ND	ND	ND	ND	ND	ND
Tetrahydrofuran	0.5		ND	ND	ND	ND	ND	ND
Chloroform	0.2	TTHM*	ND	ND	ND	ND	ND	ND
1,1,1-Trichloroethane	0.3	200	ND	ND	ND	ND	ND	ND
n-Butyl Chloride	0.3		ND	ND	ND	ND	ND	ND
Carbon Tetrachloride	0.1	5	ND	ND	ND	ND	ND	ND
1,1-Dichloropropene	0.2		ND	ND	ND	ND	ND	ND
Benzene	0.2	5	ND	ND	ND	ND	ND	ND
1,2-Dichloroethane	0.3	5	ND	ND	ND	ND	ND	ND
Trichloroethene	**0.1**	5	**ND**	**0.6**	**1.5**	**1.1**	**ND**	**ND**
1,2-Dichloropropane	0.4	5	ND	ND	ND	ND	ND	ND
Dibromomethane	0.3		ND	ND	ND	ND	ND	ND
Methyl Methacrylate	0.2		ND	ND	ND	ND	ND	ND
Bromodichloromethane	**0.3**	TTHM*	**1.0**	**ND**	**ND**	**ND**	**ND**	**ND**
2-Nitropropane	0.3		ND	ND	ND	ND	ND	ND
Chloroacetonitrile	0.4		ND	ND	ND	ND	ND	ND
c-1,3-Dichloropropene	0.2		ND	ND	ND	ND	ND	ND
4-Methyl 2-Pentanone	0.3		ND	ND	ND	ND	ND	ND
Ethyl Methacrylate	0.3		ND	ND	ND	ND	ND	ND
Dichloroacetone	0.3		ND	ND	ND	ND	ND	ND
Toluene	0.2	1000	ND	ND	ND	ND	ND	ND
t-1,3-Dichloropropene	0.2		ND	ND	ND	ND	ND	ND
1,1,2-Trichloroethane	0.3	5	ND	ND	ND	ND	ND	ND
Tetrachloroethene	**0.4**	5	**ND**	**ND**	**0.6**	**0.9**	**ND**	**ND**
1,3-Dichloropropane	0.2		ND	ND	ND	ND	ND	ND
Methyl Butyl Ketone	0.4		ND	ND	ND	ND	ND	ND
Dibromochloromethane	**0.3**	TTHM*	**1.7**	**ND**	**ND**	**ND**	**ND**	**ND**
1,2-Dibromoethane	0.1		ND	ND	ND	ND	ND	ND

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).

JUN96DW.XLS

REPORT SUBMITTED 6/28/96 BY _____

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #2	WELL #4	WELL #5
Sample Date:			6/24/96	6/24/96	6/24/96	6/24/96	6/24/96	6/24/96
Sampled by:			PM	PM	PM	PM	PM	PM
Analysis Date:			6/26/96	6/26/96	6/26/96	6/26/96	6/26/96	6/26/96
Analyzed by:			KL	KL	KL	KL	KL	KL
	MDL	MCL						
Chlorobenzene	0.3	100	ND	ND	ND	ND	ND	ND
1,1,1,2-Tetrachloroethene	0.3		ND	ND	ND	ND	ND	ND
Ethylbenzene	0.1	700	ND	ND	ND	ND	ND	ND
m&p-Xylene	0.3	XYLENES**	ND	ND	ND	ND	ND	ND
o-Xylene	0.1	XYLENES**	ND	ND	ND	ND	ND	ND
Styrene	0.2	100	ND	ND	ND	ND	ND	ND
Bromoform	**0.2**	**TTHM***	**0.6**	**ND**	**ND**	**ND**	**ND**	**ND**
Isopropyl Benzene	0.2		ND	ND	ND	ND	ND	ND
1,1,2,2-Tetrachlorethane	0.2		ND	ND	ND	ND	ND	ND
1,2,3-Trichloropropane	0.2		ND	ND	ND	ND	ND	ND
Bromobenzene	0.2		ND	ND	ND	ND	ND	ND
T-1,4-Dichloro-2-Butene	0.7		ND	ND	ND	ND	ND	ND
n-Propyl Benzene	0.1		ND	ND	ND	ND	ND	ND
2-Chloro Toluene	0.2		ND	ND	ND	ND	ND	ND
1,3,5-Trimethyl Benzene	0.2		ND	ND	ND	ND	ND	ND
4-Chloro Toluene	0.2		ND	ND	ND	ND	ND	ND
t-Butyl Benzene	0.2		ND	ND	ND	ND	ND	ND
1,2,4-Trimethyl Benzene	0.3		ND	ND	ND	ND	ND	ND
Pentachloroethane	1.0		ND	ND	ND	ND	ND	ND
sec-Butyl Benzene	0.1		ND	ND	ND	ND	ND	ND
p-Isopropyl Toluene	0.1		ND	ND	ND	ND	ND	ND
1,4-Dichlorobenzene	0.2	75	ND	ND	ND	ND	ND	ND
1,3-Dichlorobenzene	0.2		ND	ND	ND	ND	ND	ND
n-Butyl Benzene	0.3		ND	ND	ND	ND	ND	ND
1,2-Dichlorobenzene	0.2	600	ND	ND	ND	ND	ND	ND
Hexachloroethane	0.3		ND	ND	ND	ND	ND	ND
1,2-Dibromo-3-Chloro Propane	0.3		ND	ND	ND	ND	ND	ND
Nitrobenzene	1.0		ND	ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	0.1	70	ND	ND	ND	ND	ND	ND
Hexachlorobutadiene	0.3		ND	ND	ND	ND	ND	ND
Naphthalene	0.3		ND	ND	ND	ND	ND	ND
1,2,3-Trichloro Benzene	0.1		ND	ND	ND	ND	ND	ND
WARNING NOTICES:								

**TTHM = Regulated as Total Trihalomethanes with the total not to exceed 100 ug/L.*
***XYLENES= Regulated as Total Xylenes with the total not to exceed 10,000 ug/L.*

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).

JUN96DW.XLS

REPORT SUBMITTED 6/28/96 BY _____

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #4	WELL #6
Sample Date:			6/26/96	6/26/96	6/26/96	6/26/96	6/26/96
Sampled by:			PM	PM	PM	PM	PM
Analysis Date:			6/26/96	6/26/96	6/26/96	6/26/96	6/26/96
Analyzed by:			KL	KL	KL	KL	KL
	MDL	MCL					
WARNING NOTICES:							
Dichlorodifluoromethane	0.3		ND	ND	ND	ND	ND
Chloromethane	0.6		ND	ND	ND	ND	ND
Vinyl Chloride	0.2	2	ND	ND	ND	ND	ND
Bromomethane	0.4		ND	ND	ND	ND	ND
Chloroethane	0.4		ND	ND	ND	ND	ND
Trichlorofluoromethane	0.2		ND	ND	ND	ND	ND
Diethyl Ether	0.5		ND	ND	ND	ND	ND
1,1-Dichloroethene	0.3	7	ND	ND	ND	ND	ND
Acetone	0.8		ND	ND	ND	ND	ND
Iodomethane	0.6		ND	ND	ND	ND	ND
Carbon Disulfide	1.1		ND	ND	ND	ND	ND
Allyl Chloride	0.3		ND	ND	ND	ND	ND
Methylene Chloride	0.4	5	ND	ND	ND	ND	ND
Acrylonitrile	1.0		ND	ND	ND	ND	ND
t-1,2-Dichloroethene	0.3	100	ND	ND	ND	ND	ND
Methyl -t-Butyl Ether	0.4		ND	ND	ND	ND	ND
1,1-Dichloroethane	0.2		ND	ND	ND	ND	ND
2,2-Dichloropropane	1.0		ND	ND	ND	ND	ND
c-1,2-Dichloroethene	**0.2**	**70**	**ND**	**1.4**	**4.6**	**ND**	**ND**
Methyl Ethyl Ketone	0.8		ND	ND	ND	ND	ND
Propionitrile	0.3		ND	ND	ND	ND	ND
Methyl Acrylate	0.3		ND	ND	ND	ND	ND
Bromochloromethane	0.3		ND	ND	ND	ND	ND
Methacrylonitrile	0.3		ND	ND	ND	ND	ND
Tetrahydrofuran	0.5		ND	ND	ND	ND	ND
Chloroform	**0.2**	**TTHM***	**0.5**	**ND**	**ND**	**ND**	**ND**
1,1,1-Trichloroethane	0.3	200	ND	ND	ND	ND	ND
n-Butyl Chloride	0.3		ND	ND	ND	ND	ND
Carbon Tetrachloride	0.1	5	ND	ND	ND	ND	ND
1,1-Dichloropropene	0.2		ND	ND	ND	ND	ND
Benzene	0.2	5	ND	ND	ND	ND	ND
1,2-Dichloroethane	0.3	5	ND	ND	ND	ND	ND
Trichloroethene	**0.1**	**5**	**ND**	**0.5**	**1.7**	**ND**	**ND**
1,2-Dichloropropane	0.4	5	ND	ND	ND	ND	ND
Dibromomethane	0.3		ND	ND	ND	ND	ND
Methyl Methacrylate	0.2		ND	ND	ND	ND	ND
Bromodichloromethane	**0.3**	**TTHM***	**1.7**	**ND**	**ND**	**ND**	**ND**
2-Nitropropane	0.3		ND	ND	ND	ND	ND
Chloroacetonitrile	0.4		ND	ND	ND	ND	ND
c-1,3-Dichloropropene	0.2		ND	ND	ND	ND	ND
4-Methyl 2-Pentanone	0.3		ND	ND	ND	ND	ND
Ethyl Methacrylate	0.3		ND	ND	ND	ND	ND
Dichloroacetone	**0.3**		**ND**	**ND**	**1.0**	**ND**	**ND**
Toluene	0.2	1000	ND	ND	ND	ND	ND
t-1,3-Dichloropropene	0.2		ND	ND	ND	ND	ND
1,1,2-Trichloroethane	0.3	5	ND	ND	ND	ND	ND
Tetrachloroethene	**0.4**	**5**	**ND**	**ND**	**0.6**	**ND**	**ND**
1,3-Dichloropropane	0.2		ND	ND	ND	ND	ND
Methyl Butyl Ketone	0.4		ND	ND	ND	ND	ND
Dibromochloromethane	**0.3**	**TTHM***	**2.9**	**ND**	**ND**	**ND**	**ND**
1,2-Dibromoethane	0.1		ND	ND	ND	ND	ND

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).

JUN96DW.XLS

REPORT SUBMITTED 6/28/96 BY _____

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #4	WELL #6
Sample Date:			6/26/96	6/26/96	6/26/96	6/26/96	6/26/96
Sampled by:			PM	PM	PM	PM	PM
Analysis Date:			6/26/96	6/26/96	6/26/96	6/26/96	6/26/96
Analyzed by:			KL	KL	KL	KL	KL
	MDL	MCL					
Chlorobenzene	0.3	100	ND	ND	ND	ND	ND
1,1,1,2-Tetrachloroethene	0.3		ND	ND	ND	ND	ND
Ethylbenzene	0.1	700	ND	ND	ND	ND	ND
m&p-Xylene	0.3	XYLENES**	ND	ND	ND	ND	ND
o-Xylene	0.1	XYLENES**	ND	ND	ND	ND	ND
Styrene	0.2	100	ND	ND	ND	ND	ND
Bromoform	**0.2**	**TTHM***	**1.2**	**ND**	**ND**	**ND**	**ND**
Isopropyl Benzene	0.2		ND	ND	ND	ND	ND
1,1,2,2-Tetrachlorethane	0.2		ND	ND	ND	ND	ND
1,2,3-Trichloropropane	0.2		ND	ND	ND	ND	ND
Bromobenzene	0.2		ND	ND	ND	ND	ND
T-1,4-Dichloro-2-Butene	0.7		ND	ND	ND	ND	ND
n-Propyl Benzene	0.1		ND	ND	ND	ND	ND
2-Chloro Toluene	0.2		ND	ND	ND	ND	ND
1,3,5-Trimethyl Benzene	0.2		ND	ND	ND	ND	ND
4-Chloro Toluene	0.2		ND	ND	ND	ND	ND
t-Butyl Benzene	0.2		ND	ND	ND	ND	ND
1,2,4-Trimethyl Benzene	0.3		ND	ND	ND	ND	ND
Pentachloroethane	1.0		ND	ND	ND	ND	ND
sec-Butyl Benzene	0.1		ND	ND	ND	ND	ND
p-Isopropyl Toluene	0.1		ND	ND	ND	ND	ND
1,4-Dichlorobenzene	0.2	75	ND	ND	ND	ND	ND
1,3-Dichlorobenzene	0.2		ND	ND	ND	ND	ND
n-Butyl Benzene	0.3		ND	ND	ND	ND	ND
1,2-Dichlorobenzene	0.2	600	ND	ND	ND	ND	ND
Hexachloroethane	0.3		ND	ND	ND	ND	ND
1,2-Dibromo-3-Chloro Propane	0.3		ND	ND	ND	ND	ND
Nitrobenzene	1.0		ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	0.1	70	ND	ND	ND	ND	ND
Hexachlorobutadiene	0.3		ND	ND	ND	ND	ND
Naphthalene	0.3		ND	ND	ND	ND	ND
1,2,3-Trichloro Benzene	0.1		ND	ND	ND	ND	ND
WARNING NOTICES:							

**TTHM = Regulated as Total Trihalomethanes with the total not to exceed 100 ug/L.*
***XYLENES= Regulated as Total Xylenes with the total not to exceed 10,000 ug/L.*

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).

JUN96DW.XLS

REPORT SUBMITTED 6/28/96 BY _____

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #2	WELL #4
Sample Date:			6/28/96	6/28/96	6/28/96	6/28/96	6/28/96
Sampled by:			PM	PM	PM	PM	PM
Analysis Date:			7/1/96	7/1/96	7/1/96	7/1/96	7/1/96
Analyzed by:			KL	KL	KL	KL	KL
	MDL	MCL					
WARNING NOTICES:							
Dichlorodifluoromethane	0.3		ND	ND	ND	ND	ND
Chloromethane	0.6		ND	ND	ND	ND	ND
Vinyl Chloride	0.2	2	ND	ND	ND	ND	ND
Bromomethane	0.4		ND	ND	ND	ND	ND
Chloroethane	0.4		ND	ND	ND	ND	ND
Trichlorofluoromethane	0.2		ND	ND	ND	ND	ND
Diethyl Ether	0.5		ND	ND	ND	ND	ND
1,1-Dichloroethene	0.3	7	ND	ND	ND	ND	ND
Acetone	0.8		ND	ND	ND	ND	ND
Iodomethane	0.6		ND	ND	ND	ND	ND
Carbon Disulfide	1.1		ND	ND	ND	ND	ND
Allyl Chloride	0.3		ND	ND	ND	ND	ND
Methylene Chloride	0.4	5	ND	ND	ND	ND	ND
Acrylonitrile	1.0		ND	ND	ND	ND	ND
t-1,2-Dichloroethene	0.3	100	ND	ND	ND	ND	ND
Methyl -t-Butyl Ether	0.4		ND	ND	ND	ND	ND
1,1-Dichloroethane	0.2		ND	ND	ND	ND	ND
2,2-Dichloropropane	1.0		ND	ND	ND	ND	ND
c-1,2-Dichloroethene	**0.2**	70	**0.6**	**1.7**	**4.0**	**1.5**	**ND**
Methyl Ethyl Ketone	0.8		ND	ND	ND	ND	ND
Propionitrile	0.3		ND	ND	ND	ND	ND
Methyl Acrylate	0.3		ND	ND	ND	ND	ND
Bromochloromethane	0.3		ND	ND	ND	ND	ND
Methacrylonitrile	0.3		ND	ND	ND	ND	ND
Tetrahydrofuran	0.5		ND	ND	ND	ND	ND
Chloroform	**0.2**	TTHM*	**0.9**	**2.1**	**ND**	**ND**	**ND**
1,1,1-Trichloroethane	**0.3**	200	**ND**	**ND**	**ND**	**0.4**	**ND**
n-Butyl Chloride	0.3		ND	ND	ND	ND	ND
Carbon Tetrachloride	0.1	5	ND	ND	ND	ND	ND
1,1-Dichloropropene	0.2		ND	ND	ND	ND	ND
Benzene	0.2	5	ND	ND	ND	ND	ND
1,2-Dichloroethane	0.3	5	ND	ND	ND	ND	ND
Trichloroethene	**0.1**	5	**ND**	**0.5**	**1.7**	**1.0**	**ND**
1,2-Dichloropropane	0.4	5	ND	ND	ND	ND	ND
Dibromomethane	0.3		ND	ND	ND	ND	ND
Methyl Methacrylate	0.2		ND	ND	ND	ND	ND
Bromodichloromethane	**0.3**	TTHM*	**2.7**	**ND**	**ND**	**ND**	**ND**
2-Nitropropane	0.3		ND	ND	ND	ND	ND
Chloroacetonitrile	0.4		ND	ND	ND	ND	ND
c-1,3-Dichloropropene	0.2		ND	ND	ND	ND	ND
4-Methyl 2-Pentanone	0.3		ND	ND	ND	ND	ND
Ethyl Methacrylate	0.3		ND	ND	ND	ND	ND
Dichloroacetone	**0.3**		**ND**	**ND**	**ND**	**ND**	**ND**
Toluene	0.2	1000	ND	ND	ND	ND	ND
t-1,3-Dichloropropene	0.2		ND	ND	ND	ND	ND
1,1,2-Trichloroethane	0.3	5	ND	ND	ND	ND	ND
Tetrachloroethene	**0.4**	5	**ND**	**ND**	**0.6**	**0.9**	**ND**
1,3-Dichloropropane	0.2		ND	ND	ND	ND	ND
Methyl Butyl Ketone	0.4		ND	ND	ND	ND	ND
Dibromochloromethane	**0.3**	TTHM*	**4.1**	**ND**	**ND**	**ND**	**ND**
1,2-Dibromoethane	0.1		ND	ND	ND	ND	ND

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).

JUN96DW.XLS

REPORT SUBMITTED 7/2/96 BY _____

CENTRAL REPORT

Sample Location:			CPS BOOSTER	CPS RAW	WELL #1	WELL #2	WELL #4
Sample Date:			6/28/96	6/28/96	6/28/96	6/28/96	6/28/96
Sampled by:			PM	PM	PM	PM	PM
Analysis Date:			7/1/96	7/1/96	7/1/96	7/1/96	7/1/96
Analyzed by:			KL	KL	KL	KL	KL
	MDL	MCL					
Chlorobenzene	0.3	100	ND	ND	ND	ND	ND
1,1,1,2-Tetrachloroethene	0.3		ND	ND	ND	ND	ND
Ethylbenzene	0.1	700	ND	ND	ND	ND	ND
m&p-Xylene	0.3	XYLENES**	ND	ND	ND	ND	ND
o-Xylene	0.1	XYLENES**	ND	ND	ND	ND	ND
Styrene	0.2	100	ND	ND	ND	ND	ND
Bromoform	**0.2**	**TTHM***	**1.5**	**ND**	**ND**	**ND**	**ND**
Isopropyl Benzene	0.2		ND	ND	ND	ND	ND
1,1,2,2-Tetrachlorethane	0.2		ND	ND	ND	ND	ND
1,2,3-Trichloropropane	0.2		ND	ND	ND	ND	ND
Bromobenzene	0.2		ND	ND	ND	ND	ND
T-1,4-Dichloro-2-Butene	0.7		ND	ND	ND	ND	ND
n-Propyl Benzene	0.1		ND	ND	ND	ND	ND
2-Chloro Toluene	0.2		ND	ND	ND	ND	ND
1,3,5-Trimethyl Benzene	0.2		ND	ND	ND	ND	ND
4-Chloro Toluene	0.2		ND	ND	ND	ND	ND
t-Butyl Benzene	0.2		ND	ND	ND	ND	ND
1,2,4-Trimethyl Benzene	0.3		ND	ND	ND	ND	ND
Pentachloroethane	1.0		ND	ND	ND	ND	ND
sec-Butyl Benzene	0.1		ND	ND	ND	ND	ND
p-Isopropyl Toluene	0.1		ND	ND	ND	ND	ND
1,4-Dichlorobenzene	0.2	75	ND	ND	ND	ND	ND
1,3-Dichlorobenzene	0.2		ND	ND	ND	ND	ND
n-Butyl Benzene	0.3		ND	ND	ND	ND	ND
1,2-Dichlorobenzene	0.2	600	ND	ND	ND	ND	ND
Hexachloroethane	0.3		ND	ND	ND	ND	ND
1,2-Dibromo-3-Chloro Propane	0.3		ND	ND	ND	ND	ND
Nitrobenzene	1.0		ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	0.1	70	ND	ND	ND	ND	ND
Hexachlorobutadiene	0.3		ND	ND	ND	ND	ND
Naphthalene	0.3		ND	ND	ND	ND	ND
1,2,3-Trichloro Benzene	0.1		ND	ND	ND	ND	ND
WARNING NOTICES:							

**TTHM = Regulated as Total Trihalomethanes with the total not to exceed 100 ug/L.*
***XYLENES= Regulated as Total Xylenes with the total not to exceed 10,000 ug/L.*

MCL = Maximum Contaminant Level Set by EPA
ND = Not Detected at MDL (Method Detection Limit)
EPA Method 524.2, results are expressed in PPB (ug/l).

JUN96DW.XLS

REPORT SUBMITTED 7/2/96 BY _____

Summer Well Sampling Data - 1995

Location	Sample Date	Batch	Cd (ug/L)	Cr (ug/L)	Cu (ug/L)	Pb (ug/L)	Ni (ug/L)	Zn (ug/L)	Ag (ug/L)	Hg (ug/L)	As (ug/L)	Se (ug/L)	Ca (mg/L)	Mg (mg/L)	K (mg/L)	Na (mg/L)	Fe (ug/L)	Mn (ug/L)	Co (ug/L)
Fire Sta 1	09/01/95	AEC	< 10	< 40	51.9	< 1.0	< 40	< 10	< 10	< 0.5	3.6	< 5.0	81	28	1.4	20.3	857	54	< 50
Fire Sta 1	10/31/96	AEM	< 10	< 40	165.6	1	< 40	12	< 10	< 0.5	< 2.0	< 5.0	100	32	2.3	50.6	342	56	< 50
Fire Sta 3	08/22/95	AEC	< 10	< 40	225.5	< 1.0	< 40	< 10	< 10	< 0.5	< 2.0	< 5.0	85	25	1.2	24.1	89	29	< 50
Fire Sta 3	10/31/96	AEM	< 10	< 40	154.5	< 1.0	< 40	< 10	< 10	< 0.5	< 2.0	< 5.0	88	27	1.5	24.3	46	19	< 50
Fire Sta 6	*09/01/95*	AEC	< 10	< 40	96.1	< 1.0	< 40	< 10	< 10	< 0.5	2.7	< 5.0	69	24	1.3	24.3	419	66	< 50
Fire Sta 6	10/31/96	AEM	< 10	< 40	141.8	1.1	< 40	< 10	< 10	< 0.5	< 2.0	< 5.0	69	25	1.3	26.5	372	60	< 50
Gull Rd	08/22/95	AEC	< 10	< 40	< 40	< 1.0	< 40	< 10	< 10	< 0.5	< 2.0	< 5.0	78	23	1.1	6.3	< 30	14	< 50
Gull Rd	10/31/96	AEM	< 10	< 40	44.4	< 1.0	< 40	< 10	< 10	< 0.5	3.6	< 5.0	76	24	1.1	6.6	< 30	< 5.0	< 50
KVCC	08/22/95	AEC	< 10	< 40	< 40	< 1.0	< 40	< 10	< 10	< 0.5	< 2.0	< 5.0	58	20	1.1	8.8	564	28	< 50
KVCC	10/31/96	AEM	< 10	< 40	< 40	< 1.0	< 40	< 10	< 10	< 0.5	5.5	< 5.0	62	22	1	13.5	2921	119	< 50
Ross Twp	09/21/95	AEC	< 10	< 40	< 40	< 1.0	< 40	< 10	< 10	< 0.5	6.8	< 5.0	71	24	< 1.0	16.7	1618	73	< 50
Sta 01 Well 04	10/31/96	AEM	< 10	< 40	< 40	< 1.0	< 40	14	< 10	< 0.5	< 2.0	< 5.0	98	32	2.5	41.1	115	102	< 50
Sta 04 Well 05	08/18/95	AEC	< 10	< 40	< 40	< 1.0	< 40	< 10	< 10	< 0.5	7.2	< 5.0	68	26	1.6	21.5	864	67	< 50
Sta 04 Well 08	08/18/95	AEC	< 10	< 40	< 40	6.9	< 40	23	< 10	< 0.5	4.1	< 5.0	70	26	1.3	12.8	1065	78	< 50
Sta 09 Well 02	10/30/96	AEM	< 10	< 40	< 40	10.2	< 40	71	< 10	< 0.5	3.2	< 5.0	72	26	1.5	29	274	153	< 50
Sta 09 Well 03	10/30/96	AEM	< 10	< 40	< 40	2	< 40	13	< 10	< 0.5	3	< 5.0	67	25	1.5	29.6	245	146	< 50
Sta 09 Well 04	10/30/96	AEM	< 10	< 40	< 40	15.5	< 40	23	< 10	< 0.5	4.4	< 5.0	64	24	1.7	27.3	474	225	< 50
Sta 09 Well 05	10/30/96	AEM	< 10	< 40	< 40	1.1	< 40	12	< 10	< 0.5	2.2	< 5.0	59	23	1.5	25.3	270	229	< 50
Sta 09 Well 06	10/30/96	AEM	< 10	< 40	< 40	1.8	< 40	13	< 10	< 0.5	2.5	< 5.0	59	21	1.3	25.4	204	194	< 50
Sta 09 Well 10	10/30/96	AEM	< 10	< 40	< 40	3	< 40	< 10	< 10	< 0.5	4.2	< 5.0	79	28	1.6	29.6	308	172	< 50
Sta 09 Well 11	10/30/96	AEM	< 10	< 40	< 40	2.3	< 40	21	< 10	< 0.5	2.6	< 5.0	79	27	1.7	53.3	341	164	< 50
Sta 12 Well 01	09/27/95	AEC	< 10	< 40	< 40	< 1.0	< 40	< 10	< 10	< 0.5	9.6	< 5.0	74	29	1.1	9.9	719	57	< 50
Sta 12 Well 02	09/27/95	AEC	< 10	< 40	< 40	1.2	< 40	< 10	< 10	< 0.5	12.2	< 5.0	84	33	1.2	7.1	761	69	< 50
Sta 12 Well 03	09/27/95	AEC	< 10	< 40	< 40	< 1.0	< 40	< 10	< 10	< 0.5	6.5	< 5.0	65	25	1.5	12.2	579	51	< 50
Sta 12 Well 04	09/27/95	AEC	< 10	< 40	< 40	< 1.0	< 40	< 10	< 10	< 0.5	6.9	< 5.0	71	26	< 1.0	10.1	801	59	< 50
Sta 24 Well 03	10/31/96	AEM	< 10	< 40	< 40	< 1.0	< 40	< 10	< 10	< 0.5	< 2.0	< 5.0	64	25	< 1.0	10.2	1304	39	< 50
Sta 24 Well 04	10/31/96	AEM	< 10	< 40	< 40	< 1.0	< 40	< 10	< 10	< 0.5	2.3	< 5.0	58	22	1.2	12.7	1131	30	< 50
Sta 24 Well 07	10/31/96	AEM	< 10	< 40	< 40	< 1.0	< 40	< 10	< 10	< 0.5	< 2.0	< 5.0	62	22	< 1.0	8.3	837	53	< 50
Sta 24 Well 15	10/31/96	AEM	< 10	< 40	< 40	1.1	< 40	25	< 10	< 0.5	2.9	< 5.0	51	15	< 1.0	3.6	1619	43	< 50
Sta 25 Well 01	09/22/95	AEC	< 10	< 40	< 40	< 1.0	< 40	< 10	< 10	< 0.5	< 2.0	< 5.0	86	26	1.2	6.1	< 30	30	< 50
Sta 25 Well 03	09/22/95	AEC	< 10	< 40	< 40	< 1.0	< 40	< 10	< 10	< 0.5	< 2.0	< 5.0	79	25	1.5	6	< 30	< 5	< 50
Sta 25 Well 05	09/22/95	AEC	< 10	< 40	< 40	< 1.0	< 40	18	< 10	< 0.5	< 2.0	< 5.0	80	24	< 1.0	5	95	18	< 50
Sta 25 Well 06	09/22/95	AEC	< 10	< 40	< 40	< 1.0	< 40	< 10	< 10	< 0.5	< 2.0	< 5.0	70	22	< 1.0	5.3	< 30	88	< 50
Sta 25 Well 08	09/22/95	AEC	< 10	< 40	< 40	< 1.0	< 40	< 10	< 10	< 0.5	< 2.0	< 5.0	81	23	< 1.0	7.5	254	51	< 50
Sta 39 Raw 01	09/06/95	AEC	< 10	< 40	< 40	< 1.0	< 40	< 10	< 10	< 0.5	8.7	< 5.0	84	21	1.5	15.2	423	133	< 50
Sta 39 Raw 02	09/06/95	AEC	< 10	< 40	< 40	< 1.0	< 40	< 10	< 10	< 0.5	9.1	< 5.0	86	21	1.5	15.7	464	133	< 50

CITY OF KALAMAZOO TRACE ORGANICS LABORATORY REPORT
SUMMER WELL STUDY

SUMMER WELL SAMPLES 1995

Units are ug/l (ppb)

Sample Location:		1-2	1-4	4-5	4-8	9-2	9-3	9-4
Sample Date:		10/14/95	10/31/95	8/28/95	8/28/95	10/30/95	10/30/95	10/30/95
Sampled by:		KL	KL	KL	KL	PM	PM	PM
Analysis Date:		10/23/95	11/2/95	9/1/95	9/1/95	10/31/95	10/31/95	10/31/95
Analyzed by:		KL	JB	KL	KL	JB	JB	JB
	MDL							
Dichlorodifluoromethane	*0.3*	ND	ND	ND	ND	ND	ND	ND
Chloromethane	*0.6*	ND	ND	ND	ND	ND	ND	ND
Vinyl Chloride	*0.2*	ND	ND	ND	ND	ND	ND	ND
Bromomethane	*0.4*	ND	ND	ND	ND	ND	ND	ND
Chloroethane	*0.4*	ND	ND	ND	ND	ND	ND	ND
Trichlorofluoromethane	*0.2*	ND	ND	ND	ND	ND	ND	ND
Diethyl Ether	*0.5*	ND	ND	ND	ND	ND	ND	ND
1,1-Dichloroethene	*0.3*	ND	ND	ND	ND	ND	ND	ND
Acetone	*5.0*	ND	ND	ND	ND	ND	ND	ND
Iodomethane	*0.6*	ND	ND	ND	ND	ND	ND	ND
Carbon Disulfide	*1.1*	ND	ND	ND	ND	ND	ND	ND
Allyl Chloride	*0.3*	ND	ND	ND	ND	ND	ND	ND
Methylene Chloride	*0.4*	ND	ND	ND	ND	ND	ND	ND
Acrylonitrile	*1.0*	ND	ND	ND	ND	ND	ND	ND
t-1,2-Dichloroethene	*0.3*	ND	ND	ND	ND	ND	ND	ND
Methyl -t-Butyl Ether	*0.4*	ND	ND	ND	ND	ND	ND	ND
1,1-Dichloroethane	*0.2*	ND	ND	ND	ND	ND	ND	ND
2,2-Dichloropropane	*1.0*	ND	ND	ND	ND	ND	ND	ND
c-1,2-Dichloroethene	*0.2*	5.4	ND	ND	ND	ND	ND	ND
Methyl Ethyl Ketone	*0.8*	ND	ND	ND	ND	ND	ND	ND
Propionitrile	*0.3*	ND	ND	ND	ND	ND	ND	ND
Methyl Acrylate	*0.3*	ND	ND	ND	ND	ND	ND	ND
Bromochloromethane	*0.3*	ND	ND	ND	ND	ND	ND	ND
Methacrylonitrile	*0.3*	ND	ND	ND	ND	ND	ND	ND
Tetrahydrofuran	*0.5*	ND	ND	ND	ND	ND	ND	ND
Chloroform	***0.2***	**ND**	**ND**	**ND**	**ND**	**ND**	**ND**	**ND**
1,1,1-Trichloroethane	*0.3*	ND	ND	ND	ND	ND	ND	ND
n-Butyl Chloride	*0.3*	ND	ND	ND	ND	ND	ND	ND
Carbon Tetrachloride	*0.1*	ND	ND	ND	ND	ND	ND	ND
1,1-Dichloropropene	*0.2*	ND	ND	ND	ND	ND	ND	ND
Benzene	*0.2*	ND	ND	ND	ND	ND	ND	ND
1,2-Dichloroethane	*0.3*	ND	ND	ND	ND	ND	ND	ND
Trichloroethene	*0.1*	1.1	ND	ND	ND	ND	ND	ND
1,2-Dichloropropane	*0.4*	ND	ND	ND	ND	ND	ND	ND
Dibromomethane	*0.3*	ND	ND	ND	ND	ND	ND	ND
Methyl Methacrylate	*0.2*	ND	ND	ND	ND	ND	ND	ND
Bromodichloromethane	***0.3***	**ND**	**ND**	**ND**	**ND**	**ND**	**ND**	**ND**
2-Nitropropane	***0.3***	**ND**	**ND**	**ND**	**ND**	**ND**	**ND**	**ND**
Chloroacetonitrile	*0.4*	ND	ND	ND	ND	ND	ND	ND
c-1,3-Dichloropropene	*0.2*	ND	ND	ND	ND	ND	ND	ND
4-Methyl 2-Pentanone	*0.3*	ND	ND	ND	ND	ND	ND	ND
Ethyl Methacrylate	*0.3*	ND	ND	ND	ND	ND	ND	ND
Dichloroacetone	*0.3*	ND	ND	ND	ND	ND	ND	ND
Toluene	*0.2*	ND	ND	ND	ND	ND	ND	ND
t-1,3-Dichloropropene	*0.2*	ND	ND	ND	ND	ND	ND	ND
1,1,2-Trichloroethane	*0.3*	ND	ND	ND	ND	ND	ND	ND
Tetrachloroethene	*0.4*	1.1	ND	ND	ND	ND	ND	ND
1,3-Dichloropropane	*0.2*	ND	ND	ND	ND	ND	ND	ND
Methyl Butyl Ketone	*0.4*	ND	ND	ND	ND	ND	ND	ND
Dibromochloromethane	***0.3***	**ND**	**ND**	**ND**	**ND**	**ND**	**ND**	**ND**
1,2-Dibromoethane	*0.1*	ND	ND	ND	ND	ND	ND	ND

ND = Not Detected at the MDL (Method Detection Limit)

SUM95.XLS

CITY OF KALAMAZOO TRACE ORGANICS LABORATORY REPORT
SUMMER WELL STUDY

SUMMER WELL SAMPLES 1995

Units are ug/l (ppb)

Sample Location:		1-2	1-4	4-5	4-8	9-2	9-3	9-4
Sample Date:		10/14/95	10/31/95	8/28/95	8/28/95	10/30/95	10/30/95	10/30/95
Sampled by:		KL	KL	KL	KL	PM	PM	PM
Analysis Date:		10/23/95	11/2/95	9/1/95	9/1/95	10/31/95	10/31/95	10/31/95
Analyzed by:		KL	JB	KL	KL	JB	JB	JB
	MDL							
Chlorobenzene	*0.3*	ND	ND	ND	ND	ND	ND	ND
1,1,1,2-Tetrachloroethene	*0.3*	ND	ND	ND	ND	ND	ND	ND
Ethylbenzene	*0.1*	ND	ND	ND	ND	ND	ND	ND
m&p-Xylene	*0.3*	ND	ND	ND	ND	ND	ND	ND
o-Xylene	*0.1*	ND	ND	ND	ND	ND	ND	ND
Styrene	*0.2*	ND	ND	ND	ND	ND	ND	ND
Bromoform	***0.2***	**ND**	**ND**	**ND**	**ND**	**ND**	**ND**	**ND**
Isopropyl Benzene	*0.2*	ND	ND	ND	ND	ND	ND	ND
1,1,2,2-Tetrachlorethane	*0.2*	ND	ND	ND	ND	ND	ND	ND
1,2,3-Trichloropropane	*0.2*	ND	ND	ND	ND	ND	ND	ND
Bromobenzene	*0.2*	ND	ND	ND	ND	ND	ND	ND
T-1,4-Dichloro-2-Butene	*0.7*	ND	ND	ND	ND	ND	ND	ND
n-Propyl Benzene	*0.1*	ND	ND	ND	ND	ND	ND	ND
2-Chloro Toluene	*0.2*	ND	ND	ND	ND	ND	ND	ND
1,3,5-Trimethyl Benzene	*0.2*	ND	ND	ND	ND	ND	ND	ND
4-Chloro Toluene	*0.2*	ND	ND	ND	ND	ND	ND	ND
t-Butyl Benzene	*0.2*	ND	ND	ND	ND	ND	ND	ND
1,2,4-Trimethyl Benzene	*0.3*	ND	ND	ND	ND	ND	ND	ND
Pentachloroethane	*1.0*	ND	ND	ND	ND	ND	ND	ND
sec-Butyl Benzene	*0.1*	ND	ND	ND	ND	ND	ND	ND
p-Isopropyl Toluene	*0.1*	ND	ND	ND	ND	ND	ND	ND
1,4-Dichlorobenzene	*0.2*	ND	ND	ND	ND	ND	ND	ND
1,3-Dichlorobenzene	*0.2*	ND	ND	ND	ND	ND	ND	ND
n-Butyl Benzene	*0.3*	ND	ND	ND	ND	ND	ND	ND
1,2-Dichlorobenzene	*0.2*	ND	ND	ND	ND	ND	ND	ND
Hexachloroethane	*0.3*	ND	ND	ND	ND	ND	ND	ND
1,2-Dibromo-3-Chloro Propane	*0.3*	ND	ND	ND	ND	ND	ND	ND
Nitrobenzene	*1.0*	ND	ND	ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	*0.1*	ND	ND	ND	ND	ND	ND	ND
Hexachlorobutadiene	*0.3*	ND	ND	ND	ND	ND	ND	ND
Naphthalene	*0.3*	ND	ND	ND	ND	ND	ND	ND
1,2,3-Trichloro Benzene	*0.1*	ND	ND	ND	ND	ND	ND	ND

ND = Not Detected at the MDL (Method Detection Limit)

CITY OF KALAMAZOO TRACE ORGANICS LABORATORY REPORT
SUMMER WELL STUDY

SUMMER WELL SAMPLES 1995

Units are ug/l (ppb)

Sample Location:		24-15	1-4
Sample Date:		10/31/95	10/31/95
Sampled by:		KL	KL
Analysis Date:		11/2/95	11/2/95
Analyzed by:		JB	JB
	MDL		
Dichlorodifluoromethane	*0.3*	ND	ND
Chloromethane	*0.6*	ND	ND
Vinyl Chloride	*0.2*	ND	ND
Bromomethane	*0.4*	ND	ND
Chloroethane	*0.4*	ND	ND
Trichlorofluoromethane	*0.2*	ND	ND
Diethyl Ether	*0.5*	ND	ND
1,1-Dichloroethene	*0.3*	ND	ND
Acetone	*5.0*	ND	ND
Iodomethane	*0.6*	ND	ND
Carbon Disulfide	*1.1*	ND	ND
Allyl Chloride	*0.3*	ND	ND
Methylene Chloride	*0.4*	ND	ND
Acrylonitrile	*1.0*	ND	ND
t-1,2-Dichloroethene	*0.3*	ND	ND
Methyl -t-Butyl Ether	*0.4*	ND	ND
1,1-Dichloroethane	*0.2*	ND	ND
2,2-Dichloropropane	*1.0*	ND	ND
c-1,2-Dichloroethene	*0.2*	ND	ND
Methyl Ethyl Ketone	*0.8*	ND	ND
Propionitrile	*0.3*	ND	ND
Methyl Acrylate	*0.3*	ND	ND
Bromochloromethane	*0.3*	ND	ND
Methacrylonitrile	*0.3*	ND	ND
Tetrahydrofuran	*0.5*	ND	ND
Chloroform	***0.2***	**ND**	**ND**
1,1,1-Trichloroethane	*0.3*	ND	ND
n-Butyl Chloride	*0.3*	ND	ND
Carbon Tetrachloride	*0.1*	ND	ND
1,1-Dichloropropene	*0.2*	ND	ND
Benzene	*0.2*	ND	ND
1,2-Dichloroethane	*0.3*	ND	ND
Trichloroethene	*0.1*	ND	ND
1,2-Dichloropropane	*0.4*	ND	ND
Dibromomethane	*0.3*	ND	ND
Methyl Methacrylate	*0.2*	ND	ND
Bromodichloromethane	***0.3***	**ND**	**ND**
2-Nitropropane	***0.3***	**ND**	**ND**
Chloroacetonitrile	*0.4*	ND	ND
c-1,3-Dichloropropene	*0.2*	ND	ND
4-Methyl 2-Pentanone	*0.3*	ND	ND
Ethyl Methacrylate	*0.3*	ND	ND
Dichloroacetone	*0.3*	ND	ND
Toluene	*0.2*	ND	ND
t-1,3-Dichloropropene	*0.2*	ND	ND
1,1,2-Trichloroethane	*0.3*	ND	ND
Tetrachloroethene	*0.4*	ND	ND
1,3-Dichloropropane	*0.2*	ND	ND
Methyl Butyl Ketone	*0.4*	ND	ND
Dibromochloromethane	***0.3***	**ND**	**ND**
1,2-Dibromoethane	*0.1*	ND	ND
Chlorobenzene	*0.3*	ND	ND

ND = Not Detected at the MDL (Method Detection Limit)

CITY OF KALAMAZOO TRACE ORGANICS LABORATORY REPORT
SUMMER WELL STUDY

SUMMER WELL SAMPLES 1995

Units are ug/l (ppb)

Sample Location:		24-15	1-4
Sample Date:		10/31/95	10/31/95
Sampled by		KL	KL
Analysis Date:		11/2/95	11/2/95
Analyzed by:		JB	JB
	MDL		
1,1,1,2-Tetrachloroethene	0.3	ND	ND
Ethylbenzene	0.1	ND	ND
m&p-Xylene	0.3	ND	ND
o-Xylene	0.1	ND	ND
Styrene	0.2	ND	ND
Bromoform	**0.2**	**ND**	**ND**
Isopropyl Benzene	0.2	ND	ND
1,1,2,2-Tetrachlorethane	0.2	ND	ND
1,2,3-Trichloropropane	0.2	ND	ND
Bromobenzene	0.2	ND	ND
T-1,4-Dichloro-2-Butene	0.7	ND	ND
n-Propyl Benzene	0.1	ND	ND
2-Chloro Toluene	0.2	ND	ND
1,3,5-Trimethyl Benzene	0.2	ND	ND
4-Chloro Toluene	0.2	ND	ND
t-Butyl Benzene	0.2	ND	ND
1,2,4-Trimethyl Benzene	0.3	ND	ND
Pentachloroethane	1.0	ND	ND
sec-Butyl Benzene	0.1	ND	ND
p-Isopropyl Toluene	0.1	ND	ND
1,4-Dichlorobenzene	0.2	ND	ND
1,3-Dichlorobenzene	0.2	ND	ND
n-Butyl Benzene	0.3	ND	ND
1,2-Dichlorobenzene	0.2	ND	ND
Hexachloroethane	0.3	ND	ND
1,2-Dibromo-3-Chloro Propane	0.3	ND	ND
Nitrobenzene	1.0	ND	ND
1,2,4-Trichlorobenzene	0.1	ND	ND
Hexachlorobutadiene	0.3	ND	ND
Naphthalene	0.3	ND	ND
1,2,3-Trichloro Benzene	0.1	ND	ND

ND = Not Detected at the MDL (Method Detection Limit)

City of Kalamazoo

Trace Organics Laboratory Report

CENTRAL PUMPING STATION PRODUCTION, MONITORING WELL, AND DISCHARGE SAMPLES

Sample Location:	C1-3	C1-4	C2-1	C2-2	D-1	D-2	D-3		
Date Sampled & Received in Lab:	6/14/95	6/14/95	6/14/95	6/14/95	6/14/95	6/14/95	6/12/95		
Sampler:	PM	PM	PM	PM	PM	PM	PM		
Analysis Date:	6/14/95	6/14/95	6/14/95	6/14/95	6/14/95	6/14/95	6/15/95	*MDL*	*MCL*
Analyzed by:	JWB	JWB	JWB	JWB	JWB	JWB	JWB	*(ug/l)*	*(ug/l)*
Dichlorodifluoromethane	**ND**	**ND**	**0.7**	**ND**	**ND**	**ND**	**ND**	***0.3***	
Chloromethane	ND	ND	ND	ND	ND	ND	ND	*0.6*	
Vinyl Chloride	**ND**	**ND**	**ND**	**ND**	**0.7**	**ND**	**ND**	***0.2***	***2***
Bromomethane	ND	ND	ND	ND	ND	ND	ND	*0.4*	
Chloroethane	ND	ND	ND	ND	ND	ND	ND	*0.4*	
Trichlorofluoromethane	ND	ND	ND	ND	ND	ND	ND	*0.2*	
1,1-Dichloroethene	ND	ND	ND	ND	ND	ND	ND	*0.3*	*7*
Methylene Chloride	ND	ND	ND	ND	ND	ND	ND	*0.4*	
t-1,2-Dichloroethene	ND	ND	ND	ND	ND	ND	ND	*0.3*	*100*
1,1-Dichloroethane	ND	ND	ND	ND	ND	ND	ND	*0.2*	
2,2-Dichloropropane	ND	ND	ND	ND	ND	ND	ND	*1.0*	
c-1,2-Dichloroethene	**ND**	**ND**	**ND**	**0.7**	**14.8**	**6.3**	**6.9**	***0.2***	***70***
Bromochloromethane	ND	ND	ND	ND	ND	ND	ND	*0.3*	
Chloroform	ND	ND	ND	ND	ND	ND	ND	*0.2*	*THM*
1,1,1-Trichloroethane	ND	ND	ND	ND	ND	ND	ND	*0.3*	*200*
Carbon Tetrachloride	ND	ND	ND	ND	ND	ND	ND	*0.1*	*5*
1,1-Dichloropropene	ND	ND	ND	ND	ND	ND	ND	*0.2*	
Benzene	**ND**	**ND**	**ND**	**ND**	**0.6**	**ND**	**ND**	***0.2***	***5***
1,2-Dichloroethane	**ND**	**ND**	**ND**	**ND**	**0.8**	**ND**	**ND**	***0.3***	***5***
Trichloroethene	***ND***	***ND***	***ND***	***0.5***	***4.3***	***4.8***	***3.7***	***0.1***	***5***
1,2-Dichloropropane	ND	ND	ND	ND	ND	ND	ND	*0.4*	*5*
Dibromomethane	ND	ND	ND	ND	ND	ND	ND	*0.3*	
Bromodichloromethane	ND	ND	ND	ND	ND	ND	ND	*0.3*	*THM*
c-1,3-Dichloropropene	ND	ND	ND	ND	ND	ND	ND	*0.2*	
Toluene	ND	ND	ND	ND	ND	ND	ND	*0.2*	*1000*
t-1,3-Dichloropropene	ND	ND	ND	ND	ND	ND	ND	*0.2*	
1,1,2-Trichloroethane	ND	ND	ND	ND	ND	ND	ND	*0.3*	
Tetrachloroethene	**ND**	**0.7**	**0.7**	**0.6**	**ND**	**3.8**	**3.0**	***0.4***	***5***
1,3-Dichloropropane	ND	ND	ND	ND	ND	ND	ND	*0.2*	
Dibromochloromethane	ND	ND	ND	ND	ND	ND	ND	*0.3*	*THM*
1,2-Dibromoethane	ND	ND	ND	ND	ND	ND	ND	*0.1*	
Chlorobenzene	ND	ND	ND	ND	ND	ND	ND	*0.3*	*100*
1,1,1,2-Tetrachloroethene	ND	ND	ND	ND	ND	ND	ND	*0.3*	
Ethylbenzene	ND	ND	ND	ND	ND	ND	ND	*0.1*	*700*
m&p-Xylene	ND	ND	ND	ND	ND	ND	ND	*0.3*	*10,000**
o-Xylene	ND	ND	ND	ND	ND	ND	ND	*0.1*	*10,000**
Styrene	ND	ND	ND	ND	ND	ND	ND	*0.2*	*100*
Bromoform	ND	ND	ND	ND	ND	ND	ND	*0.2*	*THM*
Isopropyl Benzene	ND	ND	ND	ND	ND	ND	ND	*0.2*	
1,1,2,2-Tetrachloroethane	ND	ND	ND	ND	ND	ND	ND	*0.2*	
1,2,3-Trichloropropane	ND	ND	ND	ND	ND	ND	ND	*0.2*	
Bromobenzene	ND	ND	ND	ND	ND	ND	ND	*0.2*	
n-Propyl Benzene	ND	ND	ND	ND	ND	ND	ND	*0.1*	
2-Chloro Toluene	ND	ND	ND	ND	ND	ND	ND	*0.2*	
1,3,5-Trimethyl Benzene	ND	ND	ND	ND	ND	ND	ND	*0.2*	
4-Chloro Toluene	ND	ND	ND	ND	ND	ND	ND	*0.2*	
t-Butyl Benzene	ND	ND	ND	ND	ND	ND	ND	*0.2*	
1,2,4-Trimethyl Benzene	ND	ND	ND	ND	ND	ND	ND	*0.3*	
sec-Butyl Benzene	ND	ND	ND	ND	ND	ND	ND	*0.1*	
p-Isopropyl Toluene	ND	ND	ND	ND	ND	ND	ND	*0.1*	
1,4-Dichlorobenzene	ND	ND	ND	ND	ND	ND	ND	*0.2*	*75*
1,3-Dichlorobenzene	ND	ND	ND	ND	ND	ND	ND	*0.2*	
n-Butyl Benzene	ND	ND	ND	ND	ND	ND	ND	*0.3*	
1,2-Dichlorobenzene	ND	ND	ND	ND	ND	ND	ND	*0.2*	*600*
1,2-Dibromo-3-Chloro Propane	ND	ND	ND	ND	ND	ND	ND	*0.3*	
1,2,4-Trichlorobenzene	ND	ND	ND	ND	ND	ND	ND	*0.1*	
Hexachlorobutadiene	ND	ND	ND	ND	ND	ND	ND	*0.3*	
Naphthalene	ND	ND	ND	ND	ND	ND	ND	*0.3*	
1,2,3-Trichloro Benzene	ND	ND	ND	ND	ND	ND	ND	*0.1*	

Analyzed by EPA Method 502.2 or 524.2. All results are expressed in ppb (ug/l) unless otherwise noted on the report page. REPORTED:07/07/95

MCL=Maximum Contaminant Level Set by EPA. If MCL is not listed is has not yet been established by EPA.

*Regulated as Total Xylenes

THM=Regulated as Total Trihalomethanes. The total of these 4 compounds cannot exceed 100 ppb.

ND = NOT DETECTED AT METHOD DETECTION LIMIT (MDL). If no MDL is listed for a compound, it has not yet been determined.

City of Kalamazoo

Trace Organics Laboratory Report

CENTRAL PUMPING STATION PRODUCTION, MONITORING WELL, AND DISCHARGE SAMPLES

Sample Location:	DISCHARGE	C1-2	C1-7	DISCHARGE	C1-2	C1-7		
Date Sampled & Received in Lab:	6/14/95	6/14/95	6/14/95	6/22/95	6/22/95	6/22/95		
Sampler:	PM	PM	PM	PM	PM	PM		
Analysis Date:	6/14/95	6/14/95	6/14/95	6/29/95	6/29/95	6/29/95	*MDL*	*MCL*
Analyzed by:	JWB	JWB	JWB	JWB	JWB	JWB	*(ug/l)*	*(ug/l)*
Dichlorodifluoromethane	ND	ND	ND	ND	ND	ND	*0.3*	
Chloromethane	**ND**	**ND**	**ND**	**ND**	**ND**	**12.3**	***0.6***	
Vinyl Chloride	ND	ND	ND	ND	ND	ND	*0.2*	*2*
Bromomethane	ND	ND	ND	ND	ND	ND	*0.4*	
Chloroethane	ND	ND	ND	ND	ND	ND	*0.4*	
Trichlorofluoromethane	ND	ND	ND	ND	ND	ND	*0.2*	
1,1-Dichloroethene	**ND**	**ND**	**ND**	**ND**	**ND**	**1.9**	***0.3***	***7***
Methylene Chloride	ND	ND	ND	ND	ND	ND	*0.4*	
t-1,2-Dichloroethene	ND	ND	ND	ND	ND	ND	*0.3*	*100*
1,1-Dichloroethane	**ND**	**ND**	**2.1**	**ND**	**ND**	**3.2**	***0.2***	
2,2-Dichloropropane	ND	ND	ND	ND	ND	ND	*1.0*	
c-1,2-Dichloroethene	**ND**	**ND**	**ND**	**0.8**	**ND**	**ND**	***0.2***	***70***
Bromochloromethane	ND	ND	ND	ND	ND	ND	*0.3*	
Chloroform	ND	ND	ND	1.4	ND	ND	*0.2*	*THM*
1,1,1-Trichloroethane	**ND**	**ND**	**3.8**	**ND**	**ND**	**3.9**	***0.3***	***200***
Carbon Tetrachloride	ND	ND	ND	ND	ND	ND	*0.1*	*5*
1,1-Dichloropropene	ND	ND	ND	ND	ND	ND	*0.2*	
Benzene	ND	ND	ND	ND	ND	ND	*0.2*	*5*
1,2-Dichloroethane	ND	ND	ND	ND	ND	ND	*0.3*	*5*
Trichloroethene	**0.5**	**ND**	**1.1**	**1.7**	**1.6**	**2.3**	***0.1***	***5***
1,2-Dichloropropane	ND	ND	ND	ND	ND	ND	*0.4*	*5*
Dibromomethane	ND	ND	ND	ND	ND	ND	*0.3*	
Bromodichloromethane	ND	ND	ND	ND	ND	ND	*0.3*	*THM*
c-1,3-Dichloropropene	ND	ND	ND	ND	ND	ND	*0.2*	
Toluene	ND	ND	ND	ND	ND	ND	*0.2*	*1000*
t-1,3-Dichloropropene	ND	ND	ND	ND	ND	ND	*0.2*	
1,1,2-Trichloroethane	ND	ND	ND	ND	ND	ND	*0.3*	
Tetrachloroethene	**1.1**	**9.9**	**12.1**	**1.8**	**9.3**	**10.5**	***0.4***	***5***
1,3-Dichloropropane	ND	ND	ND	ND	ND	ND	*0.2*	
Dibromochloromethane	ND	ND	ND	ND	ND	ND	*0.3*	*THM*
1,2-Dibromoethane	ND	ND	ND	ND	ND	ND	*0.1*	
Chlorobenzene	ND	ND	ND	ND	ND	ND	*0.3*	*100*
1,1,1,2-Tetrachloroethene	ND	ND	ND	ND	ND	ND	*0.3*	
Ethylbenzene	ND	ND	ND	ND	ND	ND	*0.1*	*700*
m&p-Xylene	ND	ND	ND	ND	ND	ND	*0.3*	*10,000**
o-Xylene	ND	ND	ND	ND	ND	ND	*0.1*	*10,000**
Styrene	ND	ND	ND	ND	ND	ND	*0.2*	*100*
Bromoform	ND	ND	ND	ND	ND	ND	*0.2*	*THM*
Isopropyl Benzene	ND	ND	ND	ND	ND	ND	*0.2*	
1,1,2,2-Tetrachlorethane	ND	ND	ND	ND	ND	ND	*0.2*	
1,2,3-Trichloropropane	ND	ND	ND	ND	ND	ND	*0.2*	
Bromobenzene	ND	ND	ND	ND	ND	ND	*0.2*	
n-Propyl Benzene	ND	ND	ND	ND	ND	ND	*0.1*	
2-Chloro Toluene	ND	ND	ND	ND	ND	ND	*0.2*	
1,3,5-Trimethyl Benzene	ND	ND	ND	ND	ND	ND	*0.2*	
4-Chloro Toluene	ND	ND	ND	ND	ND	ND	*0.2*	
t-Butyl Benzene	ND	ND	ND	ND	ND	ND	*0.2*	
1,2,4-Trimethyl Benzene	ND	ND	ND	ND	ND	ND	*0.3*	
sec-Butyl Benzene	ND	ND	ND	ND	ND	ND	*0.1*	
p-Isopropyl Toluene	ND	ND	ND	ND	ND	ND	*0.1*	
1,4-Dichlorobenzene	ND	ND	ND	ND	ND	ND	*0.2*	*75*
1,3-Dichlorobenzene	ND	ND	ND	ND	ND	ND	*0.2*	
n-Butyl Benzene	ND	ND	ND	ND	ND	ND	*0.3*	
1,2-Dichlorobenzene	ND	ND	ND	ND	ND	ND	*0.2*	*600*
1,2-Dibromo-3-Chloro Propane	ND	ND	ND	ND	ND	ND	*0.3*	
1,2,4-Trichlorobenzene	ND	ND	ND	ND	ND	ND	*0.1*	
Hexachlorobutadiene	ND	ND	ND	ND	ND	ND	*0.3*	
Naphthalene	ND	ND	ND	ND	ND	ND	*0.3*	
1,2,3-Trichloro Benzene	ND	ND	ND	ND	ND	ND	*0.1*	

Analyzed by EPA Method 502.2 or 524.2. All results are expressed in ppb (ug/l) unless otherwise noted on the report page. REPORTED:07/07/95

MCL=Maximum Contaminant Level Set by EPA. *If MCL is not listed is has not yet been established by EPA.*

*Regulated as Total Xylenes

THM=Regulated as Total Trihalomethanes. The total of these 4 compounds cannot exceed 100 ppb.

ND = NOT DETECTED AT METHOD DETECTION LIMIT (MDL). If no MDL is listed for a compound, it has not yet been determined.

City of Kalamazoo

Trace Organics Laboratory Report

CENTRAL PUMPING STATION PRODUCTION, MONITORING WELL, AND DISCHARGE SAMPLES

Sample Location:	C1-3	C1-4	C2-1	C2-2	D-1	D-2	D-3	Pond Pipe	Pond Pipe		
Date Sampled & Received in Lab:	6/20/94	6/20/94	6/20/94	6/20/94	6/22/94	6/22/94	6/22/94	6/14/94	6/27/94		
Sampler:	PM	PM	PM	PM	PM	PM	PM	PM	PM		
Analysis Date:	6/23/94	6/23/94	6/23/94	6/23/94	6/27/94	6/27/94	6/27/94	6/17/94	6/28/94	*MDL*	*MCL*
Analyzed by:	JB	JB	JB	JB	JB	JB	JB	JB	JB	*(ug/l)*	*(ug/l)*
Dichlorodifluoromethane	ND	ND	ND	ND	ND	ND	ND	ND	ND		
Chloromethane	ND	ND	ND	ND	ND	ND	ND	ND	ND		
Vinyl Chloride	ND	ND	ND	ND	ND	ND	ND	ND	ND	*0.5*	*2*
Bromomethane	ND	ND	ND	ND	ND	ND	ND	ND	ND		
Chloroethane	ND	ND	ND	ND	ND	ND	ND	ND	ND		
Trichlorofluoromethane	ND	ND	ND	ND	ND	ND	ND	ND	ND		
1,1-Dichloroethene	ND	ND	ND	ND	ND	ND	ND	ND	ND	*0.3*	*7*
Methylene Chloride	ND	ND	ND	ND	ND	ND	ND	ND	ND		
t-1,2-Dichloroethene	ND	ND	ND	ND	ND	ND	ND	ND	ND	*0.4*	*100*
1,1-Dichloroethane	ND	ND	ND	ND	ND	ND	ND	ND	ND		
2,2-Dichloropropane	ND	ND	ND	ND	ND	ND	ND	ND	ND		
c-1,2-Dichloroethene	ND	ND	ND	6.3	6.6	3.8	4.4	ND	ND	*0.7*	*70*
Bromochloromethane	ND	ND	ND	ND	ND	ND	ND	ND	ND	*0.4*	*THM*
Chloroform	ND	ND	ND	ND	ND	ND	ND	ND	ND	*0.5*	*THM*
1,1,1-Trichloroethane	ND	ND	ND	ND	ND	ND	ND	ND	ND	*0.3*	*200*
Carbon Tetrachloride	ND	ND	ND	ND	ND	ND	ND	ND	ND	*0.3*	*5*
1,1-Dichloropropene	ND	ND	ND	ND	ND	ND	ND	ND	ND		
Benzene	ND	ND	ND	ND	ND	ND	ND	ND	ND	*0.5*	*5*
1,2-Dichloroethane	ND	ND	ND	ND	ND	ND	ND	ND	ND	*0.7*	*5*
Trichloroethene	ND	0.7	ND	nd	2.7	5.5	3.6	ND	ND	*0.6*	*5*
1,2-Dichloropropane	ND	ND	ND	ND	ND	ND	ND	ND	ND	*0.4*	*5*
Dibromomethane	ND	ND	ND	ND	ND	ND	ND	ND	ND		
Bromodichloromethane	ND	ND	ND	ND	ND	ND	ND	ND	ND		
c-1,3-Dichloropropene	ND	ND	ND	ND	ND	ND	ND	ND	ND		
Toluene	ND	ND	ND	ND	ND	ND	ND	ND	ND	*0.4*	*1000*
t-1,3-Dichloropropene	ND	ND	ND	ND	ND	ND	ND	ND	ND		
1,1,2-Trichloroethane	ND	ND	ND	ND	ND	ND	ND	ND	ND		
Tetrachloroethene	ND	ND	ND	0.9	ND	4.1	2.5	ND	0.9	*0.6*	*5*
1,3-Dichloropropane	ND	ND	ND	ND	ND	ND	ND	ND	ND		
Dibromochloromethane	ND	ND	ND	ND	ND	ND	ND	ND	ND	*0.3*	*THM*
1,2-Dibromoethane	ND	ND	ND	ND	ND	ND	ND	ND	ND		
Chlorobenzene	ND	ND	ND	ND	ND	ND	ND	ND	ND	*0.5*	*100*
1,1,1,2-Tetrachloroethene	ND	ND	ND	ND	ND	ND	ND	ND	ND		
Ethylbenzene	ND	ND	ND	ND	ND	ND	ND	ND	ND	*0.5*	*700*
m&p-Xylene	ND	ND	ND	ND	ND	ND	ND	ND	ND	*0.6*	*10,000**
o-Xylene	ND	ND	ND	ND	ND	ND	ND	ND	ND	*0.2*	*10,000**
Styrene	ND	ND	ND	ND	ND	ND	ND	ND	ND	*0.4*	*100*
Bromoform	ND	ND	ND	ND	ND	ND	ND	ND	ND	*0.3*	*THM*
Isopropyl Benzene	ND	ND	ND	ND	ND	ND	ND	ND	ND		
1,1,2,2-Tetrachloroethane	ND	ND	ND	ND	ND	ND	ND	ND	ND		
1,2,3-Trichloropropane	ND	ND	ND	ND	ND	ND	ND	ND	ND		
Bromobenzene	ND	ND	ND	ND	ND	ND	ND	ND	ND		
n-Propyl Benzene	ND	ND	ND	ND	ND	ND	ND	ND	ND		
2-Chloro Toluene	ND	ND	ND	ND	ND	ND	ND	ND	ND		
1,3,5-Trimethyl Benzene	ND	ND	ND	ND	ND	ND	ND	ND	ND		
4-Chloro Toluene	ND	ND	ND	ND	ND	ND	ND	ND	ND		
t-Butyl Benzene	ND	ND	ND	ND	ND	ND	ND	ND	ND		
1,2,4-Trimethyl Benzene	ND	ND	ND	ND	ND	ND	ND	ND	ND		
sec-Butyl Benzene	ND	ND	ND	ND	ND	ND	ND	ND	ND		
p-Isopropyl Toluene	ND	ND	ND	ND	ND	ND	ND	ND	ND		
1,4-Dichlorobenzene	ND	ND	ND	ND	ND	ND	ND	ND	ND	*0.4*	*75*
1,3-Dichlorobenzene	ND	ND	ND	ND	ND	ND	ND	ND	ND		
n-Butyl Benzene	ND	ND	ND	ND	ND	ND	ND	ND	ND		
1,2-Dichlorobenzene	ND	ND	ND	ND	ND	ND	ND	ND	ND	*0.5*	*600*
1,2-Dibromo-3-Chloro Benzene	ND	ND	ND	ND	ND	ND	ND	ND	ND		
1,2,4-Triclorobenzene	ND	ND	ND	ND	ND	ND	ND	ND	ND		
Hexachlorobutadiene	ND	ND	ND	ND	ND	ND	ND	ND	ND		
Naphthalene	ND	ND	ND	ND	ND	ND	ND	ND	ND		
1,2,3-Trichloro Benzene	ND	ND	ND	ND	ND	ND	ND	ND	ND		

Analyzed by EPA Method 502.2 or 524.2. All results are expressed in ppb (ug/l).

MCL=Maximum Contaminant Level Set by EPA. If MCL is not listed is has not yet been established by EPA.

*Regulated as Total Xylenes

THM=Regulated as Total Trihalomethanes. The total of these 4 compounds cannot exceed 100 ppb.

ND = NOT DETECTED AT METHOD DETECTION LIMIT (MDL). If no MDL is listed for a compound, it has not yet been determined.

City of Kalamazoo

Trace Organics Laboratory Report

CENTRAL PUMPING STATION PRODUCTION, MONITORING WELL, AND DISCHARGE SAMPLES

Sample Location:	DISCHARGE	C1-2	C1-7	DISCHARGE	C1-2	C1-7		
Date Sampled & Received in Lab:	6/14/94	6/14/94	6.14.94	6/27/94	6/27/94	6/27/94		
Sampler:	PM	PM	PM	PM	PM	PM		
Analysis Date:	6/16/94	6/16/94	6/16/94	6/28/94	6/28/94	6/28/94	*MDL*	*MCL*
Analyzed by:	JB	JB	JB	JB	JB	JB	*(ug/l)*	*(mg/l)*
Dichlorodifluoromethane	ND	ND	ND	ND	ND	ND		
Chloromethane	ND	ND	ND	ND	ND	ND		
Vinyl Chloride	ND	ND	ND	ND	ND	ND	*0.5*	*2*
Bromomethane	ND	ND	ND	ND	ND	ND		
Chloroethane	ND	ND	ND	ND	ND	ND		
Trichlorofluoromethane	ND	ND	ND	ND	ND	ND		
1,1-Dichloroethene	ND	ND	ND	ND	ND	ND	*0.3*	*7*
Methylene Chloride	ND	ND	ND	ND	ND	ND		
t-1,2-Dichloroethene	ND	ND	ND	ND	ND	ND	*0.4*	*100*
1,1-Dichloroethane	0.8	ND	2.0	0.8	ND	2.0		
2,2-Dichloropropane	ND	ND	ND	ND	ND	ND		
c-1,2-Dichloroethene	ND	ND	ND	ND	ND	ND	*0.7*	*70*
Bromochloromethane	ND	ND	ND	ND	ND	ND	*0.4*	*THM*
Chloroform	ND	ND	ND	ND	ND	ND	*0.5*	*THM*
1,1,1-Trichloroethane	1.3	ND	3.5	1.2	ND	3.4	*0.3*	*200*
Carbon Tetrachloride	ND	ND	ND	ND	ND	ND	*0.3*	*5*
1,1-Dichloropropene	ND	ND	ND	ND	ND	ND		
Benzene	ND	ND	ND	ND	ND	ND	*0.5*	*5*
1,2-Dichloroethane	ND	ND	ND	ND	ND	ND	*0.7*	*5*
Trichloroethene	0.5	ND	1.2	0.5	ND	1.0	*0.6*	*5*
1,2-Dichloropropane	ND	ND	ND	ND	ND	ND	*0.4*	*5*
Dibromomethane	ND	ND	ND	ND	ND	ND		
Bromodichloromethane	ND	ND	ND	ND	ND	ND		
c-1,3-Dichloropropene	ND	ND	ND	ND	ND	ND		
Toluene	ND	ND	ND	ND	ND	ND	*0.4*	*1000*
t-1,3-Dichloropropene	ND	ND	ND	ND	ND	ND		
1,1,2-Trichloroethane	ND	ND	ND	ND	ND	ND		
Tetrachloroethene	10.0	10.5	17.0	9.3	10.3	15.	*0.6*	*5*
1,3-Dichloropropane	ND	ND	ND	ND	ND	ND		
Dibromochloromethane	ND	ND	ND	ND	ND	ND	*0.3*	*THM*
1,2-Dibromoethane	ND	ND	ND	ND	ND	ND		
Chlorobenzene	ND	ND	ND	ND	ND	ND	*0.5*	*100*
1,1,1,2-Tetrachloroethene	ND	ND	ND	ND	ND	ND		
Ethylbenzene	ND	ND	ND	ND	ND	ND	*0.5*	*700*
m&p-Xylene	ND	ND	ND	ND	ND	ND	*0.6*	*10,000**
o-Xylene	ND	ND	ND	ND	ND	ND	*0.2*	*10,000**
Styrene	ND	ND	ND	ND	ND	ND	*0.4*	*100*
Bromoform	ND	ND	ND	ND	ND	ND	*0.3*	*THM*
Isopropyl Benzene	ND	ND	ND	ND	ND	ND		
1,1,2,2-Tetrachloroethane	ND	ND	ND	ND	ND	ND		
1,2,3-Trichloropropane	ND	ND	ND	ND	ND	ND		
Bromobenzene	ND	ND	ND	ND	ND	ND		
n-Propyl Benzene	ND	ND	ND	ND	ND	ND		
2-Chloro Toluene	ND	ND	ND	ND	ND	ND		
1,3,5-Trimethyl Benzene	ND	ND	ND	ND	ND	ND		
4-Chloro Toluene	ND	ND	ND	ND	ND	ND		
t-Butyl Benzene	ND	ND	ND	ND	ND	ND		
1,2,4-Trimethyl Benzene	ND	ND	ND	ND	ND	ND		
sec-Butyl Benzene	ND	ND	ND	ND	ND	ND		
p-Isopropyl Toluene	ND	ND	ND	ND	ND	ND		
1,4-Dichlorobenzene	ND	ND	ND	ND	ND	ND	*0.4*	*75*
1,3-Dichlorobenzene	ND	ND	ND	ND	ND	ND		
n-Butyl Benzene	ND	ND	ND	ND	ND	ND		
1,2-Dichlorobenzene	ND	ND	ND	ND	ND	ND	*0.5*	*600*
1,2-Dibromo-3-Chloro Benzene	ND	ND	ND	ND	ND	ND		
1,2,4-Trichlorobenzene	ND	ND	ND	ND	ND	ND		
Hexachlorobutadiene	ND	ND	ND	ND	ND	ND		
Naphthalene	ND	ND	ND	ND	ND	ND		
1,2,3-Trichloro Benzene	ND	ND	ND	ND	ND	ND		

Analyzed by EPA Method 502.2 or 524.2. All results are expressed in ppb (ug/l).

MCL=Maximum Contaminant Level Set by EPA. If MCL is not listed is has not yet been established by EPA.

*Regulated as Total Xylenes

THM=Regulated as Total Trihalomethanes. The total of these 4 compounds cannot exceed 100 ppb.

ND = NOT DETECTED AT METHOD DETECTION LIMIT (MDL). If no MDL is listed for a compound, it has not yet been determined.

CITY OF KALAMAZOO

SWS_1993.DBF

SUMMER WELL SAMPLING RESULTS FOR 1993

(Results in mg/L, Cond. IN uMOS)

Stal

IDENT	DATE	ALKALINITY	AMMONIA	CHLORIDE	CONDCTIVTY	FLOURIDE	HARDNESS	NITRATES	D_OXYGEN	PH	O- PHOSPHATE	SILICATE	SULFATE	TEMP (C)
C1-RAW	05/19/1993	290	0.080	79.50	0.897	0.129	447	1.00	1.25	7.01	0.02	6.30	41.63	12.0
C1-2	05/19/1993	291	0.030	51.35	0.769	0.121	378	0.87	1.35	7.11	0.08	6.44	33.42	12.0
C1-3	05/19/1993	314	0.160	88.95	0.960	0.135	464	1.12	1.70	7.04	0.05	6.36	51.28	12.0
C1-4	05/19/1993	280	0.030	58.83	0.754	0.131	344	0.35	1.50	7.13	0.04	6.28	28.85	12.0
C1-5	06/22/1993	336	0.020	102.29	0.968	0.137	413	0.00	1.80	6.79	0.01	7.17	52.93	13.0
C1-6	05/19/1993	301	0.100	60.59	0.825	0.147	396	7.13	1.60	7.01	0.06	7.25	57.46	13.0
C1-7	05/19/1993	302	0.030	54.87	0.793	0.146	403	0.94	2.60	7.02	0.17	6.70	52.34	14.0
C-D2	07/26/1993	348	0.020	105.89	1.018	0.135	396	1.21	2.10	6.99	0.04	6.90	46.46	13.0
C-D3	07/26/1993	352	0.080	107.14	1.120	0.129	413	0.61	1.70	6.92	0.04	7.13	59.99	13.0
C2-RAW	05/21/1993	332	0.020	95.52	0.742	0.577	430	0.13	1.00	7.53	0.14	7.66	65.19	13.0
C2-2	05/21/1993	319	0.090	101.16	0.895	0.132	378	0.08	1.50	6.98	0.06	6.39	50.84	13.0
C2-3	05/25/1993	234	0.020	22.90	0.692	0.126	344	0.60	2.05	7.07	0.02	5.41	32.24	12.0
C2-4	05/21/1993	292	0.020	67.40	0.773	0.136	361	0.74	1.83	7.05	0.06	5.27	39.60	12.0
C2-5	05/21/1993	320	0.050	62.02	0.732	0.146	344	0.00	1.63	7.19	0.07	5.61	44.40	12.0
C2-6	05/25/1993	307	0.040	45.62	0.841	0.127	396	0.48	2.08	7.09	0.02	5.83	54.21	12.0
C2-8	05/21/1993	270	0.060	22.52	0.580	0.169	258	0.00	5.30	7.26	0.07	6.09	25.85	12.0
S3-RAW	05/26/1993	322	0.050	30.43	0.787	0.130	361	0.70	2.20	7.04	0.04	6.24	41.55	12.0
S3-1	06/24/1993	306	0.060	50.36	0.735	0.150	378	0.69	2.08	7.15	0.02	7.14	37.12	13.0
S3-2	05/26/1993	306	0.060	21.58	0.750	0.151	327	0.22	1.30	7.03	0.02	6.28	38.16	12.0
S3-3	05/28/1993	318	0.050	31.48	0.808	0.135	361	0.77	1.60	7.05	0.02	6.38	41.80	12.0
S3-4	05/26/1993	358	0.120	72.17	0.932	0.113	361	2.10	3.75	7.12	0.02	6.24	38.96	13.0
S3-5	05/28/1993	296	0.050	28.89	0.691	0.136	327	0.38	1.30	7.08	0.02	6.71	43.77	12.0
S4-RAW	07/09/1993	292	0.170	30.43	0.600	0.492	378	0.00	1.65	7.41	0.50	7.35	37.09	13.0
S4-3	07/28/1993	290	0.090	19.08	0.541	0.205	310	0.01	1.20	7.61	0.04	7.67	25.19	11.0
S4-5	07/28/1993	274	0.020	33.84	0.602	0.271	258	0.01	1.90	8.18	0.03	7.73	19.15	11.0
S4-9	07/28/1993	290	0.030	54.76	0.795	1.220	344	0.80	2.60	7.31	0.25	7.37	40.46	14.0
S4-10	07/28/1993	278	0.100	32.27	0.638	0.432	327	0.00	0.90	7.48	0.02	7.90	28.38	13.0
S5-RAW1	07/28/1993	338	0.070	43.24	0.842	0.165	378	0.00	1.00	7.50	0.09	6.71	68.81	11.0
S5-RAW2	07/28/1993	366	0.070	41.62	0.876	0.136	430	2.51	2.50	7.52	0.02	7.54	66.33	12.0
S5-2	07/28/1993	352	0.080	45.30	0.840	0.134	361	0.05	1.58	7.63	0.04	7.07	75.66	12.0
S5-4	07/28/1993	372	0.040	37.41	0.885	0.133	413	6.04	4.20	7.75	0.07	7.59	52.13	12.0
S7-1	07/01/1993	334	0.150	46.92	0.770	0.158	378	0.05	2.05	7.40	0.04	7.66	44.72	14.0
S7-2	07/01/1993	334	0.120	57.30	0.801	0.132	396	0.09	2.10	7.36	0.04	6.97	46.32	13.0
S8-RAW	08/04/1993	286	0.170	57.81	0.706	0.149	344	0.00	1.65	7.33	0.02	7.61	38.75	12.0
S8-1	08/04/1993	270	0.200	12.39	0.583	0.151	275	0.00	1.90	7.83	0.02	7.75	28.80	12.0
S8-2	08/04/1993	272	0.190	43.88	0.635	0.149	310	0.00	1.95	8.78	0.02	7.24	32.36	12.0
S8-3	08/04/1993	278	0.170	52.07	0.678	0.144	310	0.00	1.65	7.91	0.02	7.51	34.80	12.0
S8-4	08/04/1993	264	0.190	54.06	0.552	0.151	327	0.00	2.05	7.37	0.03	7.67	39.29	12.0
S8-5	08/04/1993	272	0.110	108.90	0.878	0.142	396	0.00	1.50	7.49	0.03	7.36	51.47	12.0
S8-6	08/04/1993	263	0.180	59.85	0.505	0.160	310	0.01	1.10	8.36	0.02	7.31	38.54	12.0
S-9RAW	06/25/1993	248	0.080	49.17	0.624	0.132	292	0.01	1.20	7.36	0.01	6.26	25.84	14.0
S9-1	06/25/1993	262	0.220	51.45	0.621	0.138	292	0.02	1.75	7.53	0.00	6.15	17.07	21.0
S9-2	06/25/1993	236	0.050	39.42	0.558	0.130	292	0.01	0.95	7.45	0.00	6.46	18.85	15.0
S9-3	06/25/1993	234	0.050	58.75	0.636	0.129	292	0.01	1.50	7.46	0.01	6.20	25.17	13.0

City of Kalamazoo – Department of Public Utilities
Summer Well Sampling 1993

Batch ID: SWS 93-A Analyst(s): MK/SD

Detection Limits

#	Well I.D.	Sampler Date	Ca	Mg	K	Na	Fe	Mn	Co	Si	Cd	Cr	Cu	Pb	Ni	Zn	Ag	As	Se
			0.06	0.8	1.0	0.08	20	5	10		0.3	40	40	2	40	10	10	5	5
1	C1-RAW	5-19-93	103	33.8	2.20	46.5	537	133	6	6.74	-0.2	-1.4	2.1	1.88	1.3	18.3	1.7	0.66	-1.44
2	C1-2	5-19-93	90.2	28.0	2.16	37.0	236	27	1	6.68	-0.2	-1.6	7.8	1.19	0.2	4.7	1.2	-6.52	-0.48
3	C1-3	5-19-93	112	31.8	2.60	52.6	49	107	-1	6.98	-0.4	-1.5	300	12.91	1.4	197	2.2	-0.12	1.00
4	C1-4	5-19-93	86.3	28.1	1.71	36.8	187	89	1	6.52	-0.4	-1.3	9.9	1.99	0.6	10.4	0.1	0.08	1.09
5	C1-5	6-22-93	109	37.9	2.81	49.2	1470	190	-6	7.03	-0.2	-1.4	4.0	2.40	0.2	13.9	0.1	2.21	0.39
6	C1-6	5-19-93	107	33.6	2.46	34.6	924	120	-3	7.62	-0.1	-0.9	-1.5	1.50	0.2	7.5	-0.3	1.68	-2.69
7	C1-7	5-19-93	99.9	28.7	2.70	37.9	48	108	-1	6.73	-0.4	-0.6	8.5	1.36	-0.3	5.6	0.9	-0.27	1.51
8	C2-1	5-25-93	113	37.5	2.59	54.9	76	84	-2	6.84	-0.3	-1.4	13.3	2.44	0.8	43.6	2.7	-1.05	-0.70
9	C2-2	5-21-93	106	34.9	2.62	55.9	1410	196	-1	6.64	0.0	-2.2	0.8	1.49	0.0	12.3	1.6	0.30	-0.93
10	C2-3	5-25-93	85.5	28.4	1.59	26.7	129	81	-3	5.86	-0.3	-2.7	9.9	2.26	34.8	9.5	1.0	-0.26	-1.34
11	C2-4	5-21-93	98.3	31.7	1.91	36.3	53	89	-4	6.41	0.1	-0.6	1.6	1.53	1.3	9.3	-1.6	-0.73	1.31
12	C2-5	5-21-93	96.6	32.9	1.76	31.6	1110	171	0	6.74	0.1	-0.5	-2.0	1.41	-0.0	5.0	-0.0	2.91	-3.12
13	C2-6	5-25-93	95.9	34.1	1.59	35.2	524	108	-4	6.67	0.3	-0.0	8.6	3.33	0.8	16.5	-1.8	-0.48	-1.53
14	C2-8	5-21-93	75.1	27.2	1.34	14.4	1870	124	-5	7.20	-0.1	-1.1	-1.0	0.81	0.1	5.4	-1.0	2.27	-1.78
15	D2	7-26-93	95.0	32.7	1.75	55.0	59	83	-3	6.57	0.5	-0.3	12.7	1.39	1.5	7.4	-1.7	0.35	0.07
16	D3	7-26-93	109	36.1	2.41	66.9	754	138	-1	6.56	0.0	0.2	27.8	0.77	2.4	41.9	-1.2	0.92	0.68
17	STA 2	4-21-93	111	38.8	2.46	53.3	790	163	-9	7.04	0.0	-0.5	6.0	0.65	13.5	14.1	-2.1	0.31	-1.88
18	STA 3-RAW	5-26-93	952	31.4	1.66	33.8	671	93	-5	6.70	0.2	-0.2	5.9	1.17	3.2	6.0	-1.3	0.99	-1.38
~~19~~																			
~~20~~																			
~~21~~																			
~~22~~																			
~~23~~																			
~~24~~																			
~~25~~																			
	QUALITY CONTROL																		
	CVS SKA		X	X	X	X	X	X	X	X	X	X	X	20.13	X	X	X	86.38	76.47
	CVS SKB		X	X	X	X	X	X	X	X	26.3	108	136	X	261	270	22.6	X	X
	CVS SKC		X	X	X	X	2280	1050	1,030	X	X	X	X	X	X	X	X	X	X
	ICV-1	(SPEX)	244	257	245	280	4640	722	2310	X	111	223	590	~~755~~	853	496	257	X	X
			(250)	(250)	(250)	(280)	(5000)	(750)	(2500)	X	(125)	(250)	(625)	(1000)	(1000)	(500)	(250)	X	X
	DUPLICATES																		
19	C1-RAW-DUP		103	33.9	1.69	45.7	538	124	-3	6.75	0.0	-1.1	1.2	1.87	6.2	18.0	-1.8	-0.02	-0.40
20	STA-2		112	38.6	2.99	52.8	789	164	-4	7.00	0.0	-1.2	7.0	1.31	0.8	13.5	-0.7	0.28	-0.74

Sta Wells

Comments: Ca, Mg, K, Na, and Si reported in mg/L. All others in ug/L.
Ca, Mg, K, Na, Si, Fe, Mn, and Co analyzed by EPA method 200.7.
Cd, Cr, Cu, Ni, Zn, and Ag analyzed by EPA method 200.7 with the USN.
Pb, As, and Se analyzed by EPA method 200.9.

City of Kalamazoo

Trace Organics Laboratory Report

CENTRAL PUMPING STATION PRODUCTION, MONITORING WELL, AND DISCHARGE SAMPLES

Sample Location:	C1-3	C1-4	C2-1	C2-2	D-2	D-3	POND PIPE	POND PIPE		
Date Sampled & Received in Lab:	6/1/93	6/1/93	6/1/93	6/1/93	6/17/93	6/17/93	6/3/93	6/17/93		
Sampler:	PM	PM	PM	PM	PM	PM	PM	PM		
Analysis Date:	6/1/93	6/2/93	6/1/93	6/1/93	6/18/93	6/18/93	6/9/93	6/18/93	***MDL***	***MCL***
Analyzed by:	KL	KL	KL	KL	KL	KL	KL	KL	*(ug/l)*	*(mg/l)*
Benzene	ND	ND	ND	ND	ND	ND	ND	ND	*0.5*	*5*
Bromodichloromethane	ND	ND	ND	ND	ND	ND	ND	ND	*0.4*	*THM*
Bromoform	ND	ND	ND	ND	ND	ND	ND	ND	*0.3*	*THM*
Carbon Tetrachloride	ND	ND	ND	ND	ND	ND	ND	ND	*0.3*	*5*
Chlorobenzene	ND	ND	ND	ND	ND	ND	ND	ND	*0.5*	*100*
Chloroform	ND	ND	ND	ND	ND	ND	11.5	0.5	*0.5*	*THM*
Dibromochloromethane	ND	ND	ND	ND	ND	ND	ND	ND	*0.3*	*THM*
1,2-Dichlorobenzene	ND	ND	ND	ND	ND	ND	ND	ND	*0.5*	*600*
1,4-Dichlorobenzene	ND	ND	ND	ND	ND	ND	ND	ND	*0.4*	*75*
1,2-Dichloroethane	ND	ND	ND	0.5	ND	ND	ND	ND	*0.7*	*5*
c-1,2-Dichloroethene	0.2	ND	0.5	6.9	3.8	6.3	0.8	1.0	*0.7*	*70*
t-1,2-Dichloroethene	ND	ND	ND	ND	ND	ND	ND	ND	*0.4*	*100*
1,1-Dichloroethene	ND	ND	ND	ND	ND	ND	ND	ND	*0.3*	*7*
1,2-Dichloropropane	ND	ND	ND	ND	ND	ND	ND	ND	*0.4*	*5*
Ethylbenzene	ND	ND	ND	ND	ND	ND	ND	ND	*0.5*	*700*
Styrene	ND	ND	ND	ND	ND	ND	ND	ND	*0.4*	*100*
Tetrachloroethene	0.5	1.4	1.4	0.5	4.8	3.9	ND	ND	*0.6*	*5*
Toluene	ND	ND	ND	ND	ND	ND	ND	ND	*0.4*	*1000*
1,1,1-Trichloroethane	ND	ND	ND	ND	ND	ND	ND	ND	*0.3*	*200*
Trichloroethene	ND	ND	ND	1.4	5.6	1.6	ND	ND	*0.6*	*5*
m & p-Xylene	ND	ND	ND	ND	ND	ND	ND	ND	*0.6*	*10,000**
o-Xylene	ND	ND	ND	ND	ND	ND	ND	ND	*0.2*	*10,000**
Vinyl Chloride	ND	ND	ND	ND	ND	ND	1.0	1.5	*0.5*	*2*

Analyzed by EPA Method 524.2 or 502.2. All results are expressed in ppb (ug/l).
MCL=Maximum Contaminant Level Set by EPA.
*Regulated as Total Xylenes
THM=Regulated as Total Trihalomethanes. The total of these 4 compounds cannot exceed 100 ppb.
ND = NOT DETECTED AT A DETECTION LIMIT OF 1.0 PPB (ug/l
This laboratory is certified by the Michigan Department of Public Health for the analysis of all regulated VOC's. This includes all VOC's listed on this report.
Reported: 07/08/93

City of Kalamazoo

Trace Organics Laboratory Report

CENTRAL PUMPING STATION PRODUCTION, MONITORING WELL, AND DISCHARGE SAMPLES

Sample Location:	DISCHARGE	C1-2	C1-7	DISCHARGE	C1-2	C1-7		
Date Sampled & Received in Lab:	6/7/93	6/7/93	6/7/93	6/21/93	6/21/93	6/21/93		
Sampler:	PM	PM	PM	PM	PM	PM		
Analysis Date:	6/9/93	6/9/93	6/9/93	6/23/93	6/23/93	6/23/93	***MDL***	***MCL***
Analyzed by:	KL	KL	KL	KL	KL	KL	*(ug/l)*	*(mg/l)*
Benzene	ND	ND	ND	ND	ND	ND	*0.5*	*5*
Bromodichloromethane	ND	ND	ND	ND	ND	ND	*0.4*	*THM*
Bromoform	ND	ND	ND	ND	ND	ND	*0.3*	*THM*
Carbon Tetrachloride	ND	ND	ND	ND	ND	ND	*0.3*	*5*
Chlorobenzene	ND	ND	ND	ND	ND	ND	*0.5*	*100*
Chloroform	ND	ND	ND	ND	ND	ND	*0.5*	*THM*
Dibromochloromethane	ND	ND	ND	ND	ND	ND	*0.3*	*THM*
1,2-Dichlorobenzene	ND	ND	ND	ND	ND	ND	*0.5*	*600*
1,4-Dichlorobenzene	ND	ND	ND	ND	ND	ND	*0.4*	*75*
1,2-Dichloroethane	ND	ND	ND	ND	ND	ND	*0.7*	*5*
c-1,2-Dichloroethene	ND	ND	0.6	ND	0.5	ND	*0.7*	*70*
t-1,2-Dichloroethene	ND	ND	ND	ND	ND	ND	*0.4*	*100*
1,1-Dichloroethene	ND	ND	0.7	ND	0.5	ND	*0.3*	*7*
1,2-Dichloropropane	ND	ND	ND	ND	ND	ND	*0.4*	*5*
Ethylbenzene	ND	ND	ND	ND	ND	ND	*0.5*	*700*
Styrene	ND	ND	ND	ND	ND	ND	*0.4*	*100*
Tetrachloroethene	9.2	8.7	18.6	9.1	16.3	7.3	*0.6*	*5*
Toluene	ND	ND	ND	ND	ND	ND	*0.4*	*1000*
1,1,1-Trichloroethane	0.6	ND	2.2	0.6	2.2	ND	*0.3*	*200*
Trichloroethene	0.6	ND	1.0	0.6	0.8	ND	*0.6*	*5*
m & p-Xylene	ND	ND	ND	ND	ND	ND	*0.6*	*10,000**
o-Xylene	ND	ND	ND	ND	ND	ND	*0.2*	*10,000**
Vinyl Chloride	ND	ND	ND	ND	ND	ND	*0.5*	*2*

Analyzed by EPA Method 524.2 or 502.2. All results are expressed in ppb (ug/l).
MCL=Maximum Contaminant Level Set by EPA.
*Regulated as Total Xylene.
THM=Regulated as Total Trihalomethanes. The total of these 4 compounds cannot exceed 100 ppb.
ND = NOT DETECTED AT A DETECTION LIMIT OF 1.0 PPB (ug/l
This laboratory is certified by the Michigan Department of Public Health for the analysis of all regulated VOC's. This includes all VOC's listed on this report.
Reported: 07/08/93