From: David Craymer (Generation - 34) [/O=DOMINION/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=DAVID09]
Sent: 4/28/2015 7:08:35 AM
To: John Cima (Generation - 34) [/O=DOMINION/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=John171]; Michael J Winters (Generation - 34) [/O=DOMINION/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=MIC1082]; Doug Wight (Generation - 34) [/O=DOMINION/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=Dougla7]
Subject: FW: E Pond Ash Removal

FYI

Dave Craymer

804-273-3685 (W)

804-839-2791 (C)

From: Leonard C Pope (Generation - 34)
Sent: Monday, April 27, 2015 6:54 PM
To: Michael A Glagola (Generation - 34); Bob Jackson (Generation - 34); Jeffrey C Heffelman (Generation - 3); Jeffrey R Marcell (Generation - 3); Donald Fines (Generation - 34)
Cc: Leonard C Pope (Generation - 34)
Subject: E Pond Ash Removal

No safety and no environmental issues other than the water leaking through what appears to be a seam in the concrete in E Spillway discharge . Glover started receiving trucks this morning stockpiling stone for the hall road from E pond to D pond around 54 loads today, E pond dewatering pump is up and running again pumping to D pond , Glover is installing a pump in the E pond outfall basin to pump the water back into E pond until the leak can be stopped.

Bruce Howard moving mats out of E Pond and placing around A/B/C ponds.

Fishburn has worked around D pond today.

GAI continuing to direct Bruce Howard and Fishburn.

Crofton arrived on site today looked at water leaks on C pond spillway and E pond spillway with Ruben Williams Supt for Glover and will get back with Ruben on repair and price for E spillway leak.

DOM Carter Cole has been on site with Crofton today.

Leonard "Whitey" C Pope

Dominion Lead

possum point

Cell PH 804-854-3359

Leonard.C Pope@Dom.Com