OHIO RUBBER COMPANY

SPILL PREVENTION CONTROL & COUNTERMEASURE PLAN

WILLOUGHBY FACILITY

US EPA RECORDS CENTER REGION 5
484306

OIL STORAGE TANK INSPECTION

DESCRIPTION OF STORAGE TANK	DATE INSPECTED	NAME & CLOCK NO. INSPECTOR	DEFECTS OBSERVED	DESCRIPTION DEFECTS	DESCRIPTION REPAIR WORK REQUIRED	ESTIMATED COMPLETION DATE REPAIR WORK	FOREMANS NAME
Dept. 953							
Outside Oil Storage Tanks							
#1 - 10,000 gallons	10-21-82	927-2917 E Collings	OK				
#2 - 10,000 gallons	10-21-82	927-2917 E Collings	OK				
#3 - 6,000 gallons	10-21-82	927-2917 E Collings	OK				
Inside Oil Storage Tanks							
#1 - 1,000 gallons	10-21-82	927-2917 E Collings	OK				
#2 - 1,000 gallons	10-21-82	927-2917 E Collings	OK				
#3 - 300 gallons	10-21-82	927-2917 E Collings	OK				
#4 - 300 gallons	10-21-82	927-2917 E Collings	OK				
Orco Gas Well Collection Tanks							
#1 - 8,400 gallons	10-21-82	927-2917 E Collings		needs paint			
#2 - 4,200 gallons	10-21-82	927-2917 E Collings		needs. paint			
Dept. 132 - Hot Oil Press #15 - 30 gallons	10-21-82	927-2917 E Collings		OK			

OHIO RUBBER COMPANY

SPILL PREVENTION CONTROL & COUNTERMEASURE PLAN

WILLOUGHBY FACILITY

OIL STORAGE TANK INSPECTION

DESCRIPTION OF STORAGE TANK	DATE INSPECTED	NAME & CLOCK NO. INSPECTOR	DEFECTS OBSERVED	DESCRIPTION DEFECTS	DESCRIPTION REPAIR WORK REQUIRED	ESTIMATED COMPLETION DATE REPAIR WORK	FOREMANS NAME
Dept. 113 Degreaser Fluid	10-21-82	927-2917 E Collings					
Dept. 926 #2 Fuel Oil Storage Tanks							
#1	10-21-82	927-2917 E Collings					
#2	10-21-82	927-2917 E Collings					
#3	10-21-82	927-2917 E Collings					
#4	10-21-82	927-2917 E Collings					
Dept. 938 (Inside Bldg."B") Process Oil							
6,000 Gallons	10-20-82	927-2917 E Collings	OK				
4,000 Gallons	10-20-82	927-2917 E Collings	OK				
3,000 Gallons	10-20-82	927-2917 E Collings	OK				
3,000 Gallons	10-20-82	927-2917 E Collings	OK				