POOR LEGIBILITY

ONE OR MORE PAGES IN THIS DOCUMENT ARE DIFFICULT TO READ
DUE TO THE QUALITY OF THE ORIGINAL

SEMS-RM DOCID # 1164766

February 4, 1964

Eugene Moon, Superintendent of Public Works

Lawrence Phillips, Sewage Treatment Plant Supervisor

TRICHLORETHYLENE IN INFLUENT

At 1700, February 3, 1963 trichlorethylene was detected in the influent at the Plant.

At 1700, February 3, 1964 started bypassing Plant to slough.

Grabbed sample of sewage at Whisman Rd. in front of Fairchild - Slight Odor.

Lifted manhole cover at corner of Frontage Rd. and Whisman Rd. - Strong Odor.

Lifted manhole cover on Frontage Rd. where Fairchild sewage line dumps into main sewer line - Strong Odor.

Lifted manhole cover on Frontage Rd. and National - No Odor of trichlor.

At 2000, put sewage back through Plant.

February 4, 1964 at 0830, went to Fairchild and contacted Mr. E. Friberg, their Plant Engineer.

Made the rounds of their settling tank and at this time could not detect any trichlor going over their weir into the sewage lines.

Odor was still strong in the manhole at the corner of Frontage Rd. and Whisman Rd. at the lift station.

L. O. PHILLIPS

City Manager
Dir. Public Works
Phillips
Downs
Elliott
F/y