POOR LEGIBILITY

ONE OR MORE PAGES IN THIS DOCUMENT ARE DIFFICULT TO READ
DUE TO THE QUALITY OF THE ORIGINAL

SEMS-RM DOCID # 1164796

McKinnon			
See			
Hinkley		HANDLING	
McPheeters		DISCARD	
Shelley		FILE	✓

CITY OF MOUNTAIN VIEW | MOUNTAIN VIEW, CALIFORNIA

Public Works Sanitation Division
Industrial Wastes Sampling

RECEIVED
JUL 3 Department
City of Mountain View
Dept. of Public Works

Date: June 30, 1967

Printex
145 Evelyn Avenue
Mountain View, California

RE: SEWAGE VIOLATION

Gentlemen:

Attention: Mr. Shewarin

A sample of the liquid industrial waste being discharged into the City of Mountain View's Sewer System by your operations on June 29, 1967 at * as listed below showed a pH value of * as listed below.

Such a heavy acid/alkali concentration could have disasterous results in the Sewage Treatment Plant Digesters by seriously damaging or permanently destroying the bacterial action of the digester.

The City of Mountain View Sewer Ordinance 175.638 has limits set for a pH value from 5.5 to 9.0 with 7.0 considered to be a neutral solution. In view of the seriousness of this type of violation, it is requested that corrective action be taken immediately.

Very truly yours,

Eugene Downs
Public Works Superintendent

ED/cm

* 1010 hours	2.3
1015 hours	12.0
1020 hours	12.0
1130 hours	11.0
1135 hours	11.0

McPheeters/File
Public Works Supt.

540 CASTRO STREET · PHONE 967-7211