POOR LEGIBILITY

ONE OR MORE PAGES IN THIS DOCUMENT ARE DIFFICULT TO READ
DUE TO THE QUALITY OF THE ORIGINAL

SEMS-RM DOCID # 1164797

McKinnon			
Sea			
Hinkley		HANDLING	
[illegible]		DISCARD	
Shelley		94040	✓

CITY OF MOUNTAIN VIEW | MOUNTAIN VIEW, CALIFORNIA

RECEIVED MAR 21 1967 City of Mountain View Dept. of Public Works

Department: Public Works Sanitation Division
Industrial Wastes Sampling

Date: March 20, 1967

RE: SEWAGE VIOLATION

Fairchild Controls
423 National Avenue
Mountain View, California

962-2357

Attention: Mr. H. Rundburg

A sample of the liquid industrial waste being discharged into the City of Mountain View's Sewer System by your operations on March 17, 1967 at 1409 hours showed a pH value of 2.9.

Such a heavy acid concentration could have disasterous results in the Sewage Treatment Plant Digesters by seriously damaging or permanently destroying the bacterial action of the digester.

The City of Mountain View Sewer Ordinance 175.638 has limits set for a pH value from 5.5 to 9.0 with 7.0 considered to be a neutral solution. In view of the seriousness of this type of violation, it is requested that corrective action be taken immediately.

Very truly yours,

EUGENE DOWNS,
Public Works Superintendent

Public Works/File
Public Works Supt.

540 CASTRO STREET PHONE 967-7211