POOR LEGIBILITY

ONE OR MORE PAGES IN THIS DOCUMENT ARE DIFFICULT TO READ
DUE TO THE QUALITY OF THE ORIGINAL

SEMS-RM DOCID # 1164798

McKinnon			
See			
Hinkley		HANDLING	
McPheeters		DISCARD	
Shelley		FILE 94040	✓

RECEIVED MAR 21 1967 City of Mountain View Dept. of Public Works

CITY OF MOUNTAIN VIEW | MOUNTAIN VIEW, CALIFORNIA

CITY OF MOUNTAIN VIEW SANTA CLARA COUNTY · CALIFORNIA

Department: Public Works Sanitation Division
Industrial Wastes Sampling

Date: March 20, 1967

RE: SEWAGE VIOLATION

Hewlett - Packard
333 Logue Avenue
Mountain View, California

968-7291

Attention: Mr. George Bender

A sample of the liquid industrial waste being discharged into the City of Mountain View's Sewer System by your operations on March 17, 1967 at 1430 hours showed a pH value of 5.2.

Such a heavy acid concentration could have disasterous results in the Sewage Treatment Plant Digesters by seriously damaging or permanently destroying the bacterial action of the digester.

The City of Mountain View Sewer Ordinance 175.638 has limits set for a pH value from 5.5 to 9.0 with 7.0 considered to be a neutral solution. In view of the seriousness of this type of violation, it is requested that corrective action be taken immediately.

Very truly yours,

EUGENE DOWNS,
Public Works Superintendent

Public Works/File
Public Works Supt.

Small plating operation
Not neutralizing. By detention only.
Per Mr. Bender
GFM
3-22

[illegible]

[illegible] 3-28-67

540 CASTRO STREET PHONE 967-7211