POOR LEGIBILITY

ONE OR MORE PAGES IN THIS DOCUMENT ARE DIFFICULT TO READ
DUE TO THE QUALITY OF THE ORIGINAL

SEMS-RM DOCID # 1164800

CITY OF MOUNTAIN VIEW | MOUNTAIN VIEW, CALIFORNIA
94040

Department | Public Works Sanitation Division
Industrial Wastes Sampling

Date: September 12, 1966

RE: SEWAGE VIOLATION

Fairchild
313 Fairchild Drive
Mountain View, California

Attention: Mr. Harold Rundburg

A sample of the liquid industrial waste being discharged into the City of Mountain View's Sewer System by your operations on September 8, 1966 at 2:50 PM showed a pH value of 11.4. Building #2

Such a heavy alkali concentration could have disasterous results in the Sewage Treatment Plant Digesters by seriously damaging or permanently destroying the bacterial action of the digester.

The City of Mountain View Sewer Ordinance 175.638 has limits set for a pH value from 5.5 to 9.0 with 7.0 considered to be a neutral solution. In view of the seriousness of this type of violation, it is requested that corrective action be taken immediately.

Very truly yours,

Eugene Downs,
Public Works Superintendent

ED:ncb
cc:PW File
SPW

540 CASTRO STREET · PHONE 967-7211