Example[a]

~~143~~ ~~106~~ 104

REC'D
FEB 14 2011
APCO

Initial Notification of Applicability[b]

National Emission Standards for Hazardous Air Pollutants:
Stationary Reciprocating Internal Combustion Engines
40 CFR part 63, subpart ZZZZ

X☐ Yes, I am subject to 40 CFR part 63, subpart ZZZZ National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

NAICS code(s): 221112

Compliance Date: X☐ Existing (before 6/12/2006) source: Oct 19, 2013

☐ New/reconstructed (on or after 6/12/2006) source: Upon initial startup

Note: The Oct 19, 2013 compliance date for existing sources applies to the following engine types:

- Existing stationary spark ignition (SI) RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions
- Existing stationary SI RICE located at an area source of HAP emissions

Company name: __Hertz Investment Group

Facility name (if different): _Laclede Gas Building [Managed by Hertz St. Louis One, LLC]

Facility (physical location) address: _720 Olive St.. St. Louis, Missouri 63101

My facility is a (please choose one): X☐ Major source ☐ Area source
Major for criteria pollutants. Area source for HAPS

Owner name/title: _William Zev Hertz Asset manager

Owner/company address: __1522 second St. Santa Monica, Ca 90401-2303

[a] This is an example of the type of information that must be submitted to fulfill the Initial Notification of Applicability Status requirement of 40 CFR part 63, subpart ZZZZ. You may submit the information in another form or format, or you may use this form.
[b] Initial Notification is due 120 days after the effective date (10/19/2010) of the rule or 120 days after you become subject to the rule

Example[a]

Owner telephone number: __310-584-8000

Owner email address (if available): __zev@hertzgroup.com

If the Operator information is different from the Owner, please provide the following:

Operator name/title: __Brenda Adams Senior Property Manager

Operator telephone number: _314-436-1711

Operator email address (if available): __badams@hertzgroup.com

Brief description of the stationary RICE at the facility, including number of engines and the site-rated HP of each engine: _The Laclede Gas Bldg has a total energy plant to provide cooling-heating-power to this 500,000 sq ft office bldg. It is not hooked to the electric utility. There are six engines to provide all the electric required by the building. As these engines generate electricity, they generate heat that is recovered as low pressure steam which provides hot water for restrooms and domestic uses and for HVAC. This steam is also used to power an absorption unit which makes chilled water for air conditioning. These are internal combustion engines burning natural gas. Engines #1 and #2 are rated at 550 kw, 3025 lbs/hr steam at 767 hp. Engines #3, 4, 5 and 6 are 800 kw, 4400 lbs/hr steam at 1006 horsepower each. There are two engines that power air conditioning compressors. They are natural gas rated at 401 horsepower each.

Example[a]

I hereby certify that the information presented herein is correct to the best of my knowledge.

Brenda Adams
(Signature)

2/10/11
(Date)

Brenda Adams / Sr. Property Mgr
(Name/title)

(314) 436-1711
(Telephone No.)

Example[a]

Submit the Initial Notification to one of the following offices, as appropriate:

a. If your State has been delegated the authority for this regulation under section 112(l) of the Clean Air Act[c], submit the notification to your State agency found at the following link: http://www.epa.gov/ttn/atw/area/table_state_contacts.doc

If your state/local contact is not listed at the above link, use this link: http://www.4cleanair.org/contactUsaLevel.asp

b. If your EPA Region has assumed the authority for this rule, submit the notification to your Regional Office of the EPA, from list below:

EPA Region I (Connecticut, Maine, Massachusetts, New Hampshire, Rhode Island, Vermont)
US Environmental Protection Agency
5 Post Office Square, Suite 100, Mail code: OES04-2,
Boston MA 02109-3912 Attention: Air Clerk

EPA Region II (New Jersey, New York, Puerto Rico, Virgin Islands)
Director, Division of Enforcement and Compliance Assistance
290 Broadway, New York, NY 10007-1866

EPA Region III (Delaware, District of Columbia, Maryland, Pennsylvania, Virginia, West Virginia)
Director, Air Protection Division, 1650 Arch Street, Philadelphia, PA 19103

EPA Region IV (Alabama, Florida, Georgia, Kentucky, Mississippi, North Carolina, South Carolina, Tennessee)
Director, Air, Pesticides and Toxics Management Division
Atlanta Federal Center, 61 Forsyth Street, Atlanta, GA 30303–3104

EPA Region V (Illinois, Indiana, Michigan, Minnesota, Ohio, Wisconsin)
Director, Air and Radiation Division, 77 West Jackson Blvd., Chicago, IL 60604–3507

EPA Region VI (Arkansas, Louisiana, New Mexico, Oklahoma, Texas)
Director, Air, Pesticides and Toxics, 1445 Ross Avenue, Dallas, TX 75202–2733

EPA Region VII (Iowa, Kansas, Missouri, Nebraska)
Director, Air and Waste Management Division, U.S. Environmental Protection Agency
901 N. 5th Street, Kansas City, KS 66101

EPA Region VIII (Colorado, Montana, North Dakota, South Dakota, Utah, Wyoming)
Director, Air and Toxics Technical Enforcement Program, Office of Enforcement, Compliance and Environmental Justice, 1595 Wynkoop Street, Denver, CO 80202-1129

EPA Region IX (Arizona, California, Hawaii, Nevada, American Samoa, Guam)
Director, Air and Toxics Division, 75 Hawthorne Street, San Francisco, CA 94105

EPA Region X (Alaska, Idaho, Oregon, Washington)
Director, Office of Air, Waste and Toxics, 1200 6th Ave., Suite 900, AWT-107, Seattle, WA 98101

---

[c] To determine whether your State has been delegated the authority for this regulation under section 112(l) of the Clean Air Act, contact your EPA Regional Office, listed above.