COLBERT LANDFILL WELL SAMPLING PROGRAM
NOVEMBER, 1994 colsf 8.2
SUMMARY SHEET VI

RECEIVED
MAR 0 3 1995
SUPERFUND REMEDIAL BRANCH

NAME	DATE SAMPLED	WELL NO.	TCA	DCE	DCA	TCE	PCE	MC
(b) (6)	11/17/94	1073D-1	0.7	ND	ND	ND	ND	ND
	11/17/94	1673H-2	ND	ND	ND	ND	ND	ND
	11/18/94	1473D-2	ND	ND	ND	ND	ND	ND
N. GLEN ESTATES	11/18/94	1073D-2	15.5	ND	1.5	ND	ND	ND
(b) (6)	11/18/94	1573C-2	ND	ND	ND	ND	ND	ND
	11/17/94	0373L-1	2.0	ND	ND	ND	ND	ND
	11/17/94	0373A-4	2.2	ND	ND	ND	ND	ND
	11/17/94	1073E-1	47.6	1.5	2.8	ND	ND	ND
WAHOO WATER	11/17/94	1073J-2	0.3	ND	ND	ND	ND	ND

reported in ug/L (ppb).

Sample results are from Laucks Testing Laboratories. These results have been condensed and simplified. you have any questions contact Bill Wedlake at Spokane County Utilities Dept. 456-3604

USEPA SF
1414361

Preformance Standards

Maximum ALLOWABLE CONTAMINANT CONCENTRATIONS

Health Protection Levels

Health protection levels are not to be exceeded during opperational life of remedial action in effluents from groundwater treatment systems. Permenent reduction of contaminant concentrations below these levels throughout the site will indicate completion of the remedial action.

Contaminant		Maximum concentration Basis parts per billion (ug/L)	
1,1,1,-Trichloroethane	(TCA)	200.0	MCL
1,1, -Dichloroethylene	(DCE)	7.0	MCL
1,1, -Dichloroethane	(DCA)	4050.0	HCA
Trichloroethylene	(TCE)	5.0	MCL
Tetrachloroethylene	(PCE)	0.7	10-5 C.R.
Methylene Chloride	(MC)	2.5	10-5 C.R.

C.R.=cancer risk

Lower 11/17/94

WELL #	TCA	DCE	DCA	TCE	PCE	MC
(b) (6) 0373A-4	2.2	NO	NO	NO	NO	NO

Upper 11/17/94

WELL #	TCA	DCE	DCA	TCE	PCE	MC
(b) (6) 0373L-1	2.0	NO	NO	NO	NO	NO
1073D-1	0.7	NO	NO	NO	NO	NO
N. GLEN 1073D-2	15.5	NO	1.5	NO	NO	NO
(b) (6) 1073E-1	47.8	1.5	2.5	NO	NO	NO

Lower 11/19/94

WELL #	TCA	DCE	DCA	TCE	PCE	MC
WAHOO 1073J-2	0.3	NO	NO	NO	NO	NO
(b) (6) 1673H-2	NO	NO	NO	NO	NO	NO

Upper 11/18/94

WELL #	TCA	DCE	DCA	TCE	PCE	MC
(b) (6) 1473D-2	NO	NO	NO	NO	NO	NO
1573C-2	NO	NO	NO	NO	NO	NO

SCALE-NONE

SYMBOL	LAYER	DESCRIPTION
	GRID	1/16 SECTIONS
	LOT_BLK	SHORT PLOTS
●	SHALLOW	WELLS UNDER 12W WOOP
▲	DEEP	WELLS OVER 12W WOOP
◇	OTHER	WELLS OVER OTHER AQUIFER
		DESIGNATE COLBORT LANDFILL