File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

# WATER WELL REPORT 29/[redacted]-36P

STATE OF WASHINGTON

Application No. .....

Permit No. .....

1.2

**(1) OWNER:** Name (b) (6) Address (b) (6) Marysville

**(2) LOCATION OF WELL:** County Snohomish — SE ¼ SW ¼ Sec 36 T. 29 N., R. 4E W.M.

Bearing and distance from section or subdivision corner

**(3) PROPOSED USE:** Domestic ☒ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☐ Other ☐

**(4) TYPE OF WORK:** Owner's number of well (if more than one) ....

New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☒ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

**(5) DIMENSIONS:** Diameter of well 6 inches.
Drilled 153 ft. Depth of completed well 153 ft.

**(6) CONSTRUCTION DETAILS:**

Casing installed: 6 " Diam. from 0 ft. to 148 ft.
Threaded ☐ " Diam. from ft. to ft.
Welded ☒ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☒
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes ☒ No ☐
Manufacturer's Name Johnson
Type Wirewound Model No. Stainless
Diam. 6 Slot size .035 from 148 ft. to 153 ft.
Diam. Slot size from ft. to ft.

Gravel packed: Yes ☐ No ☒ Size of gravel:
Gravel placed from ft. to ft.

Surface seal: Yes ☒ No ☐ To what depth? 18 ft.
Material used in seal puddled clay
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? Depth of strata
Method of sealing strata off

**(7) PUMP:** Manufacturer's Name Goulds
Type: Sub #10EJ07412 H.P. 3/4

**(8) WATER LEVELS:** Land-surface elevation above mean sea level .... 130 ft.
Static level 125 ft. below top of well Date 9-28-76
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

**(9) WELL TESTS:** Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☐ No ☒ If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

| Time | Water Level | Time | Water Level | Time | Water Level |
|---|---|---|---|---|---|
| | | | | | |

Date of test
Bailer test 30 gal./min. with 10 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water 50 Was a chemical analysis made? Yes ☐ No ☒

**(10) WELL LOG:**

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

| MATERIAL | FROM | TO |
|---|---|---|
| Soil, sandy | 0 | 5 |
| Hardpan gravel, brown, coarse | 5 | 23 |
| Boulder | 23 | 25 |
| Hardpan gravel, brown, coarse | 25 | 32 |
| Gravel, dry | 32 | 125 |
| Sand & gravel, medium, loose, wet | 125 | 153 |

USEPA SF
1560764

Work started 9-15, 1976 Completed 9-28, 1976

**WELL DRILLER'S STATEMENT:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Ace Drilling & Pump Service (Person, firm, or corporation) (Type or print)

Address Rt 1 Box 203 Arlington, Wa. 98223

[Signed] Robert E. Freeman (Well Driller)

License No. 0137 Date 10-4, 1976

(USE ADDITIONAL SHEETS IF NECESSARY)

S. F. No. 7356—OS—(Rev. 4-71).