Agency Use Only

Clean Air Agency

110 Union Street, Suite 500
Seattle, WA 98101-2038
www.pscleanair.org

NOTICE OF INTENT

Bldg 23

Agency Use Only

A. Project Type: 1. ☒ Friable Asbestos Removal 2. ☐ Friable Asbestos Removal & Demolition 3. ☐ Demolition Only

B. Property Owner: RAINIER COMMONS, LLC | Phone: 206-447-0263

Mailing Address: 3100 AIRPORT WAY S | City: Seattle | State: WA | Zip: 98134

C. Asbestos Contractor: PDG, INC (PLEASE PRINT CLEARLY, THIS WILL BE YOUR RETURN MAILING LABEL.) | ~~Owner/CEO~~: Hector Rodriguez

Mailing Address: 679 STRander Blvd | Phone: 206-575-7484 | Contract Job No.:

City: Tukwila | State: WA | Zip: 98188 | Fax: 206-575-1197

D. Site Address: 3100 AIRPORT WAY S | City: Seattle | Zip: 98134

Site Manager: ELAN HAZEN | Local Phone: 206-447-0263

E. ☐ Asbestos Survey or ☒ Mat'l Presumed | No. of Structures: 8 | Date of Asbestos Survey: N/A | Was Friable Asbestos Identified? ☐ Yes ☐ | Was Nonfriable Asbestos Identified? ☐ Yes ☐

AHERA Building Inspector: N/A | Certification #: Exp. Date: N/A | *Attach a copy of the survey when friable asbestos has not been identified.*

An AHERA Survey is required before all demolition projects

F. Demolition Information: Start Date: N/A | No. of Structures: N/A | 1. ☐ Training Fire (List Fire Dept.) 2. ☐ Ordered Demolition (attach copy of Ord

Demolition Contractor: N/A (*Insert demolition contractor's mailing address on back.*) | Will nonfriable asbestos be left in place during demo? ☐ Yes ☐ N | If yes, list type and qty. Note disposal requirements in Step 6 (on back

G. Friable Asbestos Project Information: Start Date: 6-19-06 | Completion Date: 12-31-06 | Work Days: M T W Th F Sa Su | Hours: 5PM - 2AM

Total Qty. to be Removed: 900 Linear Ft. | 4,000 Square Ft. | Will all friable asbestos materials be removed? ☐ Yes ☒ No

☐ Boiler\Furnace Insulation ☐ Duct Insulation ☒ Pipe Insulation ☐ Fireproofing ☐ Paints ☐ Plaster ☐ Textured Coatings

☐ Cement Board ☐ Cement Pipe ☒ Friable Flooring ☐ Friable Roofing Material Other:

H. Asbestos/Demolition Project Categories:	**Notification Period**	**Project Fee**	**Demolition Surcharg**
1. **Single-Family Residence (owner-occupied):**			
A. ☐ Asbestos Removal Project Only	A. Prior Notice	A. $25	
B. ☐ Demolition Project (with or without asbestos removal project) *(Asbestos removal can begin upon notification; demolition must wait 10 days)	B. 10 Days*	B. $50	

Note: If the single family residence is owned by one family who has been or will be using the residence as their domicile, the above boxes 1A or 1B may be checked. ***If this is not an owner-occupied residence, one of the categories listed below must be used instead.*** *A single family residence does not include rental property, multi-family units, or any mixed-use building.*

2. ☐ All Other Demolitions (with no Asbestos removal or Nonfriable Asbestos only or less than 10 linear feet and/or 48 square feet of friable Asbestos)	10 Days		$100
Friable Asbestos Projects (other than Single Family Residence):	**Asbestos** / **Demo**		
3. ☐ ≥ 10 - 259 linear feet and/or ≥ 48 - 159 square feet of asbestos	Prior Notice / 10 Days	$100	$100
4. ☐ 260 - 999 linear feet and/or 160 - 4,999 square feet of asbestos	10 Days	$200	$100
5. ☐ >1,000 linear feet and/or >5,000 square feet of asbestos	10 Days	$600	$100
6. ☐ Emergency Asbestos Project or ☐ Emergency Demolition Project (Single-Family Residences are exempt from emergency fee; however, property owners must provide a	Prior Notice written emergency request)	$50 Emergency Fee	

I certify that the information contained in this notification & supplemental data is, to the best of my knowledge, accurate & complete.

Signature	Representing	Date	Agency Use Only: Reviewed By
Hector Rodriguez	PDG, INC	6-8-06	

HP Officejet 7210
Personal Printer/Fax/Copier/Scanner

Log for
PDG Inc.
2065751193
Jun 08 2006 3:40PM

Last Transaction

Date	Time	Type	Identification	Duration	Pages	Result
Jun 8	3:40PM	Fax Sent	6894073	0:48	1	OK

Labor and Industries
Industrial Hygiene Compliance
(Regional addresses and phone numbers on page 2)

NOTICE OF ASBESTOS ABATEMENT PROJECT

THIS NOTICE MUST BE RECEIVED NO LATER THAN 10 CALENDAR DAYS PRIOR TO THE START DATE
COMPLETE ALL APPLICABLE BOXES – INCOMPLETE OR ILLEGIBLE NOTICES WILL NOT BE ACCEPTED
MAIL OR FAX TO THE REGIONAL OFFICE – CIRCLE CHANGES ON AMENDED NOTICES

Notice date: 6/8/06	Initial ☐ Amended ☐	Site Work Hours	Su	Mo	Tu	We	Th	Fr	Sa
Start date: 6/9/06	On Hold ☐ Off Hold ☐	7 am to 10 am						X	
Completion: 6/9/06	Emergency ☒	6 pm pm	Project Dates and Work Hours must be Exact						

CONTRACTOR		PROPERTY OWNER	
Company Name	PDG, INC	Name	RAINIER COMMONS LLC
Contractor Certification Number	1326	Owner's Agent	ELAN HAZEN
Signature	[signature]	Company	RAINIER COMMON LLC
Printed Name	Hector Rodriguez	Address	3100 AIRPORT WAY S
Phone Number	425-766-5207	City / State / ZIP+4	Seattle / WA / 98134
Job Site C.A.S.	Melanie Blea	Phone number	206-447-0267

JOB SITE		FACILITY	
Address	3100 AIRPORT WAY S	Type	Office Bldgs
Building Name	COURT YARD / Room	Age / Size	40 / 100,000
City	Seattle / WA	☐ Remodel	☐ Demolition
ZIP + 4	98134 / County KING	☒ Repair	☐ Maintenance

QUANTITY OF ASBESTOS TO BE: ☒ **REMOVED** ☐ **ENCAPSULATED**

Quantity _____ square feet		☒ Indoors	☒ Outdoors
☐ Fireproofing	☐ Boiler insulation	**CONTROL MEASURES**	
☐ Popcorn ceiling	☐ Duct paper	☐ Neg. pres. enclosure	☒ Wrap & cut
☐ CAB	☐ VAT	☐ Glove bag	☒ Wet methods
☐ Sheet vinyl	☐ Roofing	☐ Mini enclosure	☒ HEPA vacuum
☐ Asbestos paper	☐ Other _____	☒ Critical barriers	☒ Manual methods
Quantity 50 linear feet		☐ Other _____	☐ Other _____
☒ Mag. pipe insulation	☐ Cement asbestos pipe	**RESPIRATORY PROTECTION**	
☐ Air cell pipe insulation	☒ Mudded pipe ins.	☒ ½ mask APR	☐ Type C continuous flow
☐ Ducting/duct insulation	☐ Duct tape	☐ Full face APR	☐ Type C pressure demand
☐ Other _____	☐ Other _____	☐ PAPR	☐ Other _____

Labor and Industries
Industrial Hygiene Compliance
(Regional addresses and phone numbers on page 2)

NOTICE OF ASBESTOS ABATEMENT PROJECT

THIS NOTICE MUST BE RECEIVED NO LATER THAN 10 CALENDAR DAYS PRIOR TO THE START DATE
COMPLETE ALL APPLICABLE BOXES – INCOMPLETE OR ILLEGIBLE NOTICES WILL NOT BE ACCEPTED
MAIL OR FAX TO THE REGIONAL OFFICE – CIRCLE CHANGES ON AMENDED NOTICES

Notice date: 6/8/06	Initial ☒ Amended ☐	Site Work Hours	Su	Mo	Tu	We	Th	Fr	Sa
Start date: 6/19/06	On Hold ☐ Off Hold ☐	am 2 am to 5 pm pm		X	X	X	X	X	
Completion: 12/31/06	Emergency ☐	Project Dates and Work Hours must be Exact							

CONTRACTOR		PROPERTY OWNER	
Company Name	PDG, Inc	Name	Rainier Commons, LLC
Contractor Certification Number	1326	Owner's Agent	Elan Hazen
Signature	Hector Rodriguez	Company	Rainier Commons, LLC
Printed Name	Hector Rodriguez	Address	3100 Airport Way S.
Phone Number	425-766-5207	City / State / ZIP+4	Seattle / WA / 98134
Job Site C.A.S.	Melanie Bleq	Phone number	206-447-0267

JOB SITE		FACILITY	
Address	3100 Airport Way S.	Type	Office Bldg
Building Name	ALL Bldg	Age / Size	40 / 100,000
Room			
City / State	Seattle / WA	☒ Remodel	☐ Demolition
ZIP + 4 / County	98134 / King	☐ Repair	☐ Maintenance

QUANTITY OF ASBESTOS TO BE: ☐ **REMOVED** ☐ **ENCAPSULATED**

Quantity 4,000 square feet		☐ Indoors	☐ Outdoors
☐ Fireproofing	☐ Boiler insulation	**CONTROL MEASURES**	
☐ Popcorn ceiling	☐ Duct paper	☐ Neg. pres. enclosure	☒ Wrap & cut
☐ CAB	☒ VAT	☐ Glove bag	☒ Wet methods
☐ Sheet vinyl	☐ Roofing	☒ Mini enclosure	☒ HEPA vacuum
☐ Asbestos paper	☒ Other MASTIC	☒ Critical barriers	☒ Manual methods
Quantity 900 linear feet		☐ Other	☐ Other
☒ Mag. pipe insulation	☐ Cement asbestos pipe	**RESPIRATORY PROTECTION**	
☒ Air cell pipe insulation	☒ Mudded pipe ins.	☒ ½ mask APR	☐ Type C continuous flow
☐ Ducting/duct insulation	☐ Duct tape	☐ Full face APR	☐ Type C pressure demand
☐ Other	☐ Other	☐ PAPR	☐ Other

HP Officejet 7210
Personal Printer/Fax/Copier/Scanner

Log for
PDG Inc.
2065751193
Jun 08 2006 3:42PM

Last Transaction

Date	Time	Type	Identification	Duration	Pages	Result
Jun 8	3:41PM	Fax Sent	5152784	1:16	2	OK

NVL Laboratories, Inc.
4708 Aurora Ave N, Seattle, WA 98103
Tel: 206.547.0100 Emerg.Pager: 206.344.1878
Fax: 206.634.1936 1.888.NVL.LABS (685.5227)

CHAIN of CUSTODY SAMPLE LOG

NVL LABS HAZARDOUS MATERIALS SERVICES

Client: Ethan Construction
Street: 3100 Airport Way S
Seattle Wa 98134

Project Manager: Elan Hazen
Project Location: 3100 Airport Way S Bldg. 23
Seattle wa 98134

Phone: (206) 575-9773 Fax: (206) 575-1193

NVL Batch Number:
Client Job Number:
Total Samples: 2
Turn Around Time: ☒ 1-Hr ☐ 24-Hrs ☐ 4 Days ☐ 2-Hrs ☐ 2 Days ☐ 5 Days ☐ 4-Hrs ☐ 3 Days ☐ 6 to 10 Days
Please call for TAT less than 24 Hrs
Email address: hrodriguez@pdge.com
(425) 766-5207

☒ Asbestos Air — ☒ PCM (NIOSH 7400) ☐ TEM (NIOSH 7402) ☐ TEM (AHERA) ☐ TEM (EPA Level II) ☐ Other

☐ Asbestos Bulk — ☐ PLM (EPA/600/R-93/116) ☐ PLM (EPA Point Count) ☐ PLM (EPA Gravimetry) ☐ TEM Bulk

☐ Mold/Fungus — ☐ Mold Air ☐ Mold Bulk ☐ Rotometer Calibration

METALS	Inst./Det Limit	Matrix		RCRA Metals ☐ All 8		Other Metals ☐ All 3
☐ Total Metals ☐ TCLP	☐ FAA (ppm) ☐ ICP (ppm) ☐ GFAA (ppb)	☐ Air Filter ☐ Drinking water ☐ Dust/wipe (Area) ☐ Soil ☐ Paint Chips in %	☐ Paint Chips in cm2 ☐ Waste Water ☐ Other	☐ Arsenic (As) ☐ Barium (Ba) ☐ Cadmium (Cd) ☐ Chromium (Cr) ☐ Lead (Pb)	☐ Mercury (Hg) ☐ Selenium (Se) ☐ Silver (Ag)	☐ Copper (Cu) ☐ Nickel (Ni) ☐ Zinc (Zn)

☐ Other Types of Analysis — ☐ Fiberglass ☐ Silica ☐ Nuisance Dust ☐ Respirable Dust ☐ Other (Specify)

Condition of Package: ☒ Good ☐ Damaged (no spillage) ☐ Severe damage (spillage)

Seq.#	Lab ID	Client Sample Number	Comments (e.g Sample are, Sample Volume, etc)	A/R
1		RB-01	PCC Samples Bldg 23	A
2		RB-01	Clearance Bldg 23	A
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				

	Print Below	Sign Below	Company	Date	Time
Sampled by	H Rodriguez	[illegible]		6-9-06	6 AM
Relinquished by	H Rodriguez	[illegible]		6-9-06	10 AM
Received by	J. Browne	James Browne	NVL-SEA	6/9/06	1006
Analyzed by	J. Browne	[illegible]			1015
Results Called by					
Results Faxed by					no fax per client request JB

Special Instructions: Unless requested in writing, all samples will be disposed of two (2) weeks after analysis.

* Client paid w/ cash $28.00 (attached) JMB 6/9/06

NVL Laboratories, Inc.
4708 Aurora Ave. N., Seattle, WA 98103
Tel: 206.634.1879, Fax: 206.634.1936
Emergency Pager #: 344.1878

AIR SAMPLE DATA SHEET

NVL Batch # - _____
Client Proj. # _____

Client: Ethan Construction
Project Location: 3100 Airport Way S Bldg 23
Sampled by: H Rodriguez — Date 6-9-06 — of _____ (Company)
Delivered by: H Rodriguez — 6-9-06
Received by: [illegible] — 6/9/06
Analyzed by: [illegible] — 6/9/06
Regular _____
Rush _____
Total Samples 2
Blank Count = _____

Method- NIOSH 7400 Microscope field area: 0.00785 Blank cassettes: None

Sample ID	Sample Type	Protection	Decon	Environment	Pump #	Date	Location	Activities	Worker	SS#	Cert#	Time Start	Time End	Minutes	Rate Start	Rate End	Average	Liters	Fibers /fields	LOD	Fibers /cc
RB-01	P	E	D	H	2	6-9-06	Bldg 23 2nd Floor	Pre Sample During Clean-Up	Melanie Bleq			6:00	6:30	30	15	15	15	450	17/100	0.006	0.019
RB-02	CL				2	6-9-06	Bldg. 23 2nd Floor	Clearance				7:00	9:00	120	10	10	10	1200	0/100	0.002	<0.002

SAMPLE TYPES

P	Pre abatement	X	Aggressive clearance
A	Area	FB	Field blank
I	Inside reg. area	TB	Trip blank
O	Outside reg. area	B	Breathing zone (TWA)
H	HEPA exhaust	C	Ceiling (STEL)
CL	Clearance		

CONTROLS

RESP. PROT.	DECON.	ENVIRONMENT
PA Pressure dem. air	D,S Decon. w/ shower	H HEPA vac.
CA Continuous flow air	D Decon. w/o shower	N Negative air
PAPR		G Glovebag
F Full face mask APR		O Outside
M Half face mask APR		

PAGE ___ OF ___