REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS,PROBLEMS,& REMARKS (W/O#)
MONDAY	7/30	7 AM	4.9	15	12.36	9.95	—	—	833	35	120	129	128				
		3 PM	4.9	12	10.74	9.79	—	—	914	6	122	124	128				
		11PM	4.9	10	11.24	9.88	—	—	1555	21	123	121	110				
TUESDAY	7/31	7 AM	4.6	10	10.41	9.87	—	—	1555	21	120	128	129				Cleaned Sump
		3 PM	4.4	5	11.43	9.76	—	—	824	25	125	121	127				
		11PM	3.8	16	10.79	9.86	—	—	1672	42	121	123	109				
WEDNESDAY	8/1	7 AM	3.8	16	9.93	9.84	—	—	1672	42	120	118	128				
		3 PM	3.8	14	12.07	10.81	—	—	553	59	124	121	128				
		11PM	3.0	10	10.18	10.84	—	—	1675	77	122	120	110				
THURSDAY	8/2	7 AM	2.8	9	11.76	10.78	—	—	1675	83	121	123	128				~~Cleaned Sump~~
		3 PM	2.8	5	11.25	10.71	—	—	529	11	124	125	127				
		11PM	2.3	15	9.88	10.44	—	—	1702	26	121	125	109				
FRIDAY	8/3	7 AM	2.0	15	10.55	10.38	—	—	1702	31	120	120	127				Cleaned Sump
		3 PM	24.8	13	10.61	10.58	—	—	1031	4	119	120	128				
		11PM	24.3	5	9.94	10.33	—	—	2163	57	124	122	108				
SATURDAY																	
SUNDAY																	

AKC-0006655

REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° DAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	8/6	7 AM	24.0	5	10.46	9.93	—	—	2163	62	93	88	125				Boiler off
		3 PM	23.8	15	9.91	10.27	—	—	3587	94	95	119	128				forgot to Reset.
		11PM	23.5	10	10.07	10.22	—	—	4585	117	106	125	107				flow & cycles
TUESDAY	8/7	7 AM	23.3	8	11.29	10.14	—	—	4585	126	106	126	128				
		3 PM	23.0	5	9.82	10.86	—	—	1089	24	112	119	128				
		11PM	22.5	3	10.05	10.44	—	—	1972	52	119	118	108				
WEDNESDAY	8/8	7 AM	22.5	3	9.66	10.69	—	—	1972	60	119	119	128				
		3 PM	22.0	10	10.02	11.00	—	—	1680	30	122	121	128				
		11PM	21.5	2	9.99	10.61	—	—	3093	59	124	120	109				
THURSDAY	8/9	7 AM	20.9	2	10.65	10.52	—	—	3093	76	119	126	128				Cleaned Sump
		3 PM	21.0	13	9.96	10.55	—	—	835	6	124	120	126				
		11PM	20.5	6	9.58	10.84	—	—	2381	39	119	116	108				
FRIDAY	8/10	7 AM	20.5	6	11.52	10.78	—	—	2411	42	118	120	129				
		3 PM	20.2	5	10.49	10.52	—	—	757	10	122	125	128				
		11PM	20.0	2	10.41	10.25	—	—	1246	26	126	123	112				
SATURDAY	8/11	800	19.9	17	9.78	10.13	—	—	1246	26	116	107	98				
		1200	19.7	16	10.53	10.12	—	—	245	14	120	123	130				
																	5 hrs
SUNDAY																	

AKC-0006656

REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	8/13	7 AM	19.4	17	10.91	9.92	—	—	245	30	122	127	110				
		3 PM	18.8	13	10.32	10.32	—	—	1053	23	124	119	128				
		11PM	18.4	10	9.89	10.36	—	—	1727	44	119	123	111				
TUESDAY	8/14	7 AM	18.6	10	11.63	10.77	—	—	1813	54	118	124	128				CLEANED Sump
		3 PM	18.5	10	9.96	10.70	—	—	913	1	124	120	126				
		11PM	18.4	9	9.68	10.91	—	—	1779	26	121	118	108				
WEDNESDAY	8/15	7 AM	17.9	9	10.78	10.67	—	—	1779	57	119	128	128				
		3 PM	17.4	10	10.46	10.50	—	—	531	14	123	125	126				
		11PM	17.4	9	10.72	10.34	—	—	2000	41	120	121	110				
THURSDAY	8/16	7 AM	17.4	9	11.25	10.27	—	—	2000	55	120	121	128				
		3 PM	16.9	8	10.46	10.64	—	—	805	18	124	122	126				
		11PM	16.6	5	9.60	10.69	—	—	1301	49	122	123	110				
FRIDAY	8/17	7 AM	16.4	5	11.27	10.56	—	—	1313	58	120	127	128				Cleaned Sump
		3 PM	16.3	3	10.34	10.59	—	—	1768	75	125	127	125				
		11PM	16.1	15	10.75	10.41	—	—	2192	98	126	119	109				
SATURDAY																	
SUNDAY																	

AKC-0006657

REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	8/20	7 AM	15.7	15	9.86	9.78	—	—	2192	98	127	128	128				
		3 PM	15.7	13	10.35	10.26	—	—	1242	8	118	127	124				
		11PM	15.5	11	10.14	10.46	—	—	2110	21	123	121	108				
TUESDAY	8/21	7 AM	15.2	11	9.67	10.45	—	—	2110	36	120	123	127				
		3 PM	14.4	9	10.26	10.43	—	—	779	16	124	128	127				
		11PM	14.5	5	9.93	10.45	—	—	2318	57	121	121	108				
WEDNESDAY	8/22	7 AM	14.2	5	11.85	10.46	—	—	2318	70	120	118	127				Cleaned Sump
		3 PM	13.0	2	9.84	10.31	—	—	720	20	123	120	108				
		11PM	13.4	17	10.24	9.79	—	—	1894	51	125	117	108				
THURSDAY	8/23	7 AM	13.2	17	10.34	10.39	—	—	2147	61	118	119	128				
		3 PM	12.5	15	10.41	10.41	—	—	1119	33	110	110	126				
		11PM	12.4	12	9.82	10.19	—	—	2072	68	116	119	110				
FRIDAY	8/24	7 AM	12.2	12	10.47	10.20	—	—	2171	82	113	128	129				Cleaned Sump
		3 PM	11.6	7	10.32	10.40	—	—	1471	18	117	120	125				
		11PM	11.6	4	10.29	10.70	—	—	2216	51	124	129	111				
SATURDAY	8/25	5:30	11.3	4		10.67	—	—	2214	57	118	114	99				
		4:30	11.1	17	10.08	10.84	—	—	1825	38	127	118	128				
																	16hrs
SUNDAY																	

AKC-0006658

REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	8/22	7 AM	10.8	10	9.60	10.41	—	—	1826	50	126	120	96				
		3 PM	10.0	11	11.84	10.46	—	—	1735	44	124	122	128				
		11PM	9.8	7	9.67	10.27	—	—	2531	78	119	119	119				
TUESDAY	8/23	7 AM	9.5	7	10.53	10.20	—	—	2769	83	116	128	128				Cleaned Sump
		3 PM	9.2	3	11.11	9.52	—	—	1045	26	121	123	128				
		11PM	9.0	2	10.38	9.88	—	—	2716	69	122	121	118				
WEDNESDAY	8/25	7 AM	8.7	2	10.71	9.73	—	—	2116	73	121	126	128				
		3 PM	8.5	12	9.70	9.61	—	—	1328	20	127	119	128				
		11PM	8.5	11	10.22	9.20	—	—	1714	35	120	126	119				
THURSDAY	8/26	7 AM	8.2	11	11.29	10.44	—	—	1714	44	117	130	115				Forgot to Reset Flow & Cycles
		3 PM	8.2	8	9.29	10.79	—	—	2878	59	124	123	104				
		11PM	8.0	7	9.55	10.33	—	—	3844	67	121	open	97				
FRIDAY	8/27	7 AM	8.0	7	11.46	10.28	—	—	3844	68	121	Ean	88				Cleaned Sump
		3 PM	7.7	5	10.12	10.65	—	—	1278	17	123	123	129				
		11PM	7.5	17	10.44	10.73	—	—	1993	40	126	118	128				
SATURDAY																	
SUNDAY																	

AKC-0006659