REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS,PROBLEMS,& REMARKS (W/O#)
MONDAY	1/1	7 AM	16.5	13	10.84	10.18	—	—	1087	65	121	82	102				1/2
		3 PM	16.1	7	11.65	10.47	—	—	1386	82	122	78	94				
		11PM	15.9	2	9.96	10.71	—	—	2380	70	126	84	99				
TUESDAY	1/2	7 AM	15.7	2	11.47	10.68	—	—	2380	89	122	81	86				1/3
		3 PM	15.1	12	10.62	10.44	—	—	968	29 ~~123~~	123 ~~87~~	83	96				
		11PM	14.9	5	10.58	9.99	—	—	2150	57	125	80	101				
WEDNESDAY	1/3	7 AM	14.9	5	9.79	9.87	—	—	2380	03	116	75	110				1/4
		3 PM	14.9	2	10.13	10.55	—	—	571	12	123	82	94				
		11PM	14.4	15	10.61	10.44	—	—	1794	35	126	85	101				
THURSDAY	1/4	7 AM	14.4	15	10.14	10.37	—	—	1194	44	125	82	111				1/5
		3 PM	13.9	15	10.19	10.16	—	—	683	8	120	77	98				
		11PM	13.9	10	9.62	10.04	—	—	1313	28	100	72	109				
FRIDAY	1/5	7 AM															
		3 PM															
		11PM															
SATURDAY																	
SUNDAY																	

..\WOUT\500-0007, 03/04/99

AKC-0007095

REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS,PROBLEMS,& REMARKS (W/O#)
MONDAY	1/8	7 AM	13.9	10	11.31	9.90	—	—	1313	35	79	58	77				
		3 PM	13.4	7	10.68	9.96	—	—	913	36	99	63	74				
		11PM	13.0	2	10.02	10.44	—	—	1671	59	115	66	88				
TUESDAY	1/5	7 AM	13.0	2	12.25	10.42	—	—	1671	65	115	65	80				
		3 PM	12.8	14	10.02	10.75	—	—	1166	9	127	69	71				
		11PM	12.5	10	11.34	10.34	—	—	1839	60	120	69	70				
WEDNESDAY	1/10	7 AM	11.3	9	11.14	10.03	—	—	2345	59	121	68	75				
		3 PM	10.8	5	10.78	10.05	—	—	366	31	122	69	94				
		11PM	10.8	14	10.38	10.08	—	—	1377	65	126	69	86				
THURSDAY	1/11	7 AM	10.5	14	10.55	10.08	—	—	1377	72	120	66	85				
		3 PM	10.2	12	9.98	10.30	—	—	739	11	127	65	101				
		11PM	9.9	10	9.89	10.22	—	—	1344	32	114	60	90				
FRIDAY	1/12	7 AM	9.7	10	13.04	10.18	—	—	1344	46	103	55	86				Boiler was out
		3 PM	9.7	8	11.86	10.12	—	—	2950		114	55	102				
		11PM	9.4	5	10.46	10.76	—	—	1286	25	126	55	92				
SATURDAY			9.4	3	9.91	10.74	—	—	1286	28	117	50	79				
		4:30	9.2	1	11.89	12.47	—	—	858	19	123	55	103				
SUNDAY																	

OUT\500-0007, 03/04/99

AKC-0007096

REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	1/15	7 AM	8.9	13	10.18	10.45	–	–	1655	36	120	46?	100				low temp in Small tank.
		3 PM	8.4	10	9.80	10.53	–	–	727	50	122	57?	106				
		11PM	8.1	8	9.82	10.20	–	–	1348	96	126	60	92				
TUESDAY	1/16	7 AM	8.1	8	11.86	10.18	–	–	1358	99	119	58	92				
		3 PM	7.6	7	11.40	10.15	–	–	29	17	127	65	110				
		11PM	7.6	1	9.83	10.17	–	–	771	44	122	67	98				
WEDNESDAY	1/17	7 AM	7.6	3	9.89	10.16	–	–	815	44	115	65	96				Forgot to Reset flow & cycles
		11PM	6.0	12	11.18	9.99	–	–	1691	113	113	72	101				
		11PM															
THURSDAY	1/18	7 AM	6.0	12	10.71	9.91	–	–	~~1691~~	~~113~~	106	69	101				1691 815 876 / 113 44 69 / 1854 739 1115 259 1374
		3 PM	5.5	8	10.30	9.83	–	–	834	30	105	74	113				
		11PM	5.5	5	11.25	9.97	–	–	1447	54	107	77	104				
FRIDAY	1/19	7 AM	5.0	15	9.91	9.91	–	–	1854	0?	101	73	105				
		3 PM	4.4	14	9.72	9.95	–	–	253	34	108	75	119				
		11PM	3.9	8	11.58	10.40	–	–	1111	73	116	74	104				
SATURDAY		7 AM	3.9	7	8.12	10.37	–	–	1111	78	104	69	95				Shut down @ 12pm.
		12	3.4	4	10.33	10.70	–	–	317	[illegible]	[illegible]	[illegible]	108				
SUNDAY																	

REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS,PROBLEMS,& REMARKS (W/O#)
MONDAY	1/22	7 AM	3.1	3	10.80	9.97	-	-	970	37	119	65	103				
		3 PM	3.1	2	9.62	9.24	-	-	420	50	105	65	118				
		11PM	2.3	16	10.25	9.99	-	-	933	125	113	67	107				
TUESDAY	1/23	7 AM	1.8	16	12.23	9.96	-	-	933	137	106	64	104				
		3 PM	1.5	13	10.34	10.12	-	-	547	33	99	63	119				1:30 Boiler off Relit
		11PM	2.3	10	9.80	10.20	-	-	758	76	105	68	108				
WEDNESDAY	1/24	7 AM	1.3	9	12.71	10.80	-	-	1204	79	92	54	107				
		3 PM	1.0	7	9.77	10.20	-	-	1685	9	106	68	122				
		11PM	0.7	2	10.03	9.83	-	-	2371	26?	110	70	108				
THURSDAY	1/25	7 AM	.8	2	9.76	9.80	-	-	2371	26	108	68	107				
		3 PM	25.1	14	10.21	10.38	-	-	1313	200	108	70	120				
		11PM	24.9	8	10.16	10.18	-	-	2112	58	111	72	105				
FRIDAY	1/26	7 AM	24.9	7	9.70	10.63	-	-	2112	60	106	68	106				
		3 PM	24.4	5	9.97	10.44	-	-	850	17	107	70	117				
		11PM	24.1	12	9.78	10.29	-	-	696	47	109	70	102				
SATURDAY																	
SUNDAY																	

AKC-0007098

:\WOUT\500-0007, 03/04/99