REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS,PROBLEMS,& REMARKS (W/O#)
MONDAY	1/24	7 AM	16.6	6	9.95	10.12	–	–	1979	57	DNF	118	97				Forgot to Reset Cycles
		3 PM	16.6	5	9.71	10.35	–	–	813	67	113	120	89				
		11PM	16.1	17	9.93	10.10	–	–	2103	100	121	119	82				Breaker to oakite heaters was tripped.
TUESDAY	1/25	7 AM	16.1	17	9.60	9.96	–	–	2103	101	116	117	81				
		3 PM	15.8	16	11.29	9.89	–	–	671	50	121	121	125				
		11PM	15.3	14	9.62	9.94	–	–	2245	77	110	109	107				
WEDNESDAY	1/26	7 AM	15.4	14	9.62	9.98	–	–	2245	79	105	110	120				
		3 PM	15.1	11	9.65	10.01	–	–	988	4	108	122	129				
		11PM	14.8	8	10.55	9.91	–	–	1967	20	121	121	112				
THURSDAY	1/27	7 AM	14.9	8	9.90	9.88	–	–	2131	24	114	120	128				
		3 PM	14.6	7	10.10	9.94	–	–	582	35	122	120	128				
		11PM	14.3	5	9.81	10.00	–	–	1306	57	126	124	101				
FRIDAY	1/28	7 AM	14.1	5	10.42	10.02	–	–	1490	63	117	112	115				
		3 PM	14.1	20	9.89	10.13	–	–	658	18	123	125	114				
		11PM	13.8	18	9.60	10.08	–	–	1208	26	118	123	98				
SATURDAY																	
SUNDAY																	

..\WOUT\500-0007, 03/04/99

AKC-0007997

REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS,PROBLEMS,& REMARKS (W/O#)
MONDAY	1/03	7 AM	5.9	7	9.64	9.53	–	–	2103	90	65	63	78				
		3 PM	5.6	7	11.75	9.50	–	–	342	48	75	86	122				
		11PM	4.8	5	9.54	9.51	–	–	1309	46	82	101	111				
TUESDAY	1/04	7 AM	4.8	5	9.61	9.51	–	–	1532	53	80	101	106				
		3 PM	4.0	18	9.50	9.85	–	–	546	8	95	111	125				
		11PM	3.8	17	10.03	10.08	–	–	1603	35	90	124	113				
WEDNESDAY	1/05	7 AM	3.8	17	9.55	10.10	–	–	1603	50	86	110	108				
		3 PM	2.5	15	10.54	10.24	–	–	1231	67	86	114	112				
		11PM	2	12	9.89	9.93	–	–	2010	115	91	125	129				
THURSDAY	1/06	7 AM	2.0	13	9.71	9.81	–	–	2102	125	86	115	107				
		3 PM	30.0	10	10.00	9.85	–	–	573	9	92	123	101				
		11PM	29.5	9	10.42	9.79	–	–	1935	82	99	125	126				
FRIDAY	1/07	7 AM	29.6	8	10.25	9.63	–	–	1955	89	94	118	110				
		3 PM	28.4	6	9.74	9.75	–	–	935	19	99	126	86				
		11PM	27.8	3	9.56	9.47			2200	68	108	124	83				
SATURDAY																	
SUNDAY																	

..\WOUT\500-0007, 03/04/99

AKC-0007998

REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS,PROBLEMS,& REMARKS (W/O#)
MONDAY	1/10	7 AM	28.0	2	9.64	9.56	—	—	2254	77	94	128	88				
		3 PM	27.4	14	9.88	9.76	—	—	1574	52	94	112	99				
		11PM	26.9	12	9.94	9.65	—	—	3175	117	99	123	130				
TUESDAY	1/11	7 AM	27.0	12	9.97	9.48	—	—	3175	125	94	116	108				mix tank at 11:00pm ~~10.34~~ pH 10.34
		3 PM	26.4	8	10.36	9.42	—	—	1039	45	97	127	100				Indicator Strip is pH 8
		11PM	25.5	6	10.53	9.57	—	—	2100	50	108	124	128				
WEDNESDAY	1/12	7 AM	25.7	6	9.53	9.44	—	—	2139	60	103	118	113				
		3 PM	25.4	5	10.50	9.45	—	—	891	49	107	122	131				
		11PM	24.9	3	11.17	9.60	—	—	2025	84	111	120	112				
THURSDAY	1/13	7 AM	24.9	3	9.51	9.45	—	—	2146	85	109	111	104				
		3 PM	24.1	18	10.18	9.71	—	—	1281	11	124	108	129				
		11PM	23.6	16	9.74	9.94	—	—	2140	57	114	120	112				
FRIDAY	1/14	7 AM	23.8	16	10.31	9.83	—	—	2140	61	107	114	104				
		3 PM	23.1	14	9.79	10.24	—	—	960	46	107	122	129				
		11PM	22.6	13	9.86	10.12	—	—	1715	98	115	122	112				
SATURDAY																	
SUNDAY																	

..\WOUT\500-0007, 03/04/99

AKC-0007999

REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS,PROBLEMS,& REMARKS (W/O#)
MONDAY	1/17	7 AM	22.5	13	9.74	9.19	—	—	1899	114	102	115	105				
		3 PM	21.6	10	9.70	9.46	—	—	941	61	101	115	109				
		11PM	21.3	5	9.61	9.38	—	—	282	98	110	117	116				
TUESDAY	1/18	7 AM	21.3	5	9.69	9.31	—	—	3000	106	106	119	113				
		3 PM	19.5	18	10.15	9.46	—	—	1269	82	111	125	127				
		11PM	18.9	15	10.40	10.53	—	—	2305	115	123	124	120				
WEDNESDAY	1/19	7 AM	18.7	15	9.71	11.64	—	—	2305	116	118	118	118				
		3 PM	18.4	14	10.44	10.44	—	—	640	17	118	119	120				
		11PM	17.4	13	8.87	10.45	—	—	1710	37	114	19	121				
THURSDAY	1/20	7 AM	18.4	13	9.71	10.32	—	—	1710	39	113	118	116				
		3 PM	17.9	12		10.25	—	—	870	33	122	120	122				
		11PM	17.4	10	9.65	10.30	—	—	1701	53	119	117	120				
FRIDAY	1/21	7 AM	17.4	10	9.54	10.32	—	—	1905	55	112	118	115				
		3 PM	16.9	7	9.83	10.33	—	—	1109	43	120	124	126				
		11PM	16.6	6	10.44	10.30	—	—	1776	53	119	126	117				
SATURDAY																	
SUNDAY																	

..\WOUT\500-0007, 03/04/99

AKC-0008000