NOVEMBER
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
NOVEMBER 7, 2002
COMPOSITE M68983



ALASKAN COPPER WORKS
3200 FACILITY
NOVEMBER 14, 2002
COMPOSITE M69030

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.48	0.47	0.49	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.28	0.20	0.14	0.05
LIMITS	2.75	3.00	2.50	2.61

NOVEMBER
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
NOVEMBER 21, 2002
COMPOSITE M89595



ALASKAN COPPER WORKS
3200 FACILITY
NOVEMBER 27, 2002
COMPOSITE M69095

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.29	0.19	0.17	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.26	0.24	0.21	0.05
LIMITS	2.75	3.00	2.50	2.61