APRIL
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
APRIL 4, 2002
COMPOSITE M67821



ALASKAN COPPER WORKS
3200 FACILITY
APRIL 11, 2002
COMPOSITE M67845

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.12	0.13	0.08	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.14	0.20	0.15	0.05
LIMITS	2.75	3.00	2.50	2.61

APRIL
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
APRIL 19, 2002
COMPOSITE M67881



ALASKAN COPPER WORKS
3200 FACILITY
APRIL 25, 2002
COMPOSITE M67910

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.22	0.19	0.13	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.27	0.27	0.15	0.05
LIMITS	2.75	3.00	2.50	2.61