REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	7/2	7 AM	16.2	6	10.84	10.47	—	—	1417	76	87	87	150				
		3 PM	15.8	18	10.50	10.37	—	—	625	0	114	121	129				
		11PM	15.5	16	10.66	1031	—	—	92.6	5	117	130	124				
TUESDAY	7/5	7 AM	15.6	17	10.90	10.43	—	—	1418	2?	121	129	126				No Power to Pump Bad Relay + Socket board
		3 PM	15.6	16	10.67	10.63	—	—	399	4	121	130	126				
		11PM	14.6	14	10.66	10.61	—	—	569	22	125	122	127				
WEDNESDAY	7/4	7 AM															Holiday
		3 PM															
		11PM															
THURSDAY	7/5	7 AM	14.5	13	9.81	10.53	—	—	569	1?	118	115	117				no power to Pump
		3 PM	14.5	10	9.84	10.48	—	—	1177	13	120	126	128				
		11PM	14.3	8	9.97	1049	—	—	137	24	126	128	123				
FRIDAY	7/6	7 AM	14.3	5	9.92	10.87	—	—	1603	25	119	119	126				
		3 PM	14.3	18	10.15	10.80	—	—	616	12?	120	120	130				
		11PM	13.8	16	10.93	10.62	—	—	133	44	126	126	123				
SATURDAY																	
SUNDAY																	

\WOTT\500-0007, 03/04/99

AKC-0009590

REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING		pH PAPER		FLOWMETER	CYCLES	TEMP F°			REVETMENT			COMMENTS, PROBLEMS, & REMARKS (W/O#)
					PROCESS MONITOR	OUTPUT MONITOR	PROCESS MONITOR	OUTPUT MONITOR			LARGE TANK	SMALL TANK	OAKITE TANK	LARGE RINSE	LARGE ACID	SMALL TANKS	
MONDAY	7/9	7 AM	13.8	14	9.71	10.54	—	—	1331	50	122	128	129				
		3 PM	13.3	10	9.89	10.43	—	—	780	19	128	120	127				
		11PM	13.0	8	10.20	10.38	—	—	1530	32	125	126	125				
TUESDAY	7/10	7 AM	13.0	8	11.62	10.40	—	—	1877	40	118	126	129				
		3 PM	12.7	5	9.84	10.33	—	—	0009	19	121	127	126				
		11PM	12.2	3	9.99	10.27	—	—	797	52	120	127	124				
WEDNESDAY	7/11	7 AM	12.0	3	11.59	10.78	—	—	1795	59	116	118	126				
		3 PM	11.4	16	10.01	10.26	—	—	712	22	123	130	130				
		11PM	10.7	14	10.45	10.34	—	—	877	62	119	123	125				
THURSDAY	7/12	7 AM	10.4	14	9.81	10.46	—	—	1585	95	114	116	128				
		3 PM	9.3	10	10.11	10.42	—	—	10.98	44	127	126	126				
		11PM	8.1	8	10.37	10.34	—	—	1991	88	121	123	125				
FRIDAY	7/13	7 AM	8.3	8	9.59	10.36	—	—	2281	126	113	121	130				
		3 PM	7.5	5	10.45	10.31	—	—	1009	37	121	123	126				
		11PM	6.8	3	10.44	10.26	—	—	1854	84	125	129	127				
SATURDAY																	
SUNDAY																	

AKC-0009591

REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	7/16	7 AM	6.2	3	9.94	9.10	—	—	2095	109	124	131	98				
		3 PM	6.2	~~0~~	9.52	10.23	—	—	1131	140	120	130	128				
		11PM	5.2	16	10.34	10.41	—	—	1805	175	123	128	125				
TUESDAY	7/17	7 AM	5.2	15	9.97	10.44	—	—	2170	208	117	116	129				
		3 PM	3.9	14	10.32	10.32	—	—	612	35	120	121	126				
		11PM	3.6	11	9.90	10.19	—	—	1530	80	125	133	126				
WEDNESDAY	7/18	7 AM	2.6	11	9.71	10.26	—	—	1554	108	115	123	126				
		3 PM	2.3	8	9.89	10.20	—	—	738	26	118	130	125				
		11PM	1.8	5	10.42	10.23	—	—	1570	67	121	125	123				
THURSDAY	7/19	7 AM	1.2	5	10.44	10.35	—	—	1947	90	121	129	129				Forgot to Reset flow
		3 PM	1.0.4	18	10.09	10.37	—	—	3058	25	122	130	128				
		11PM	10.2	15	10.02	10.31	—	—	3987	64	126	121	125				
FRIDAY	7/20	7 AM	10.2	14	9.61	10.42	—	—	2040 / 3987	91	118	122	128				3987
		3 PM	9.6	12	9.79	10.29	—	—	1161	25	124	122	128				1947
		11PM	9.1	10	10.57	10.15	—	—	1944	65	122	131	123				2040
SATURDAY																	
SUNDAY																	

\WOUT\500-0007, 03/04/99

AKC-0009592

REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING		pH PAPER		FLOWMETER	CYCLES	TEMP F°			REVETMENT			COMMENTS, PROBLEMS, & REMARKS (W/O#)
					PROCESS MONITOR	OUTPUT MONITOR	PROCESS MONITOR	OUTPUT MONITOR			LARGE TANK	SMALL TANK	OAKITE TANK	LARGE RINSE	LARGE ACID	SMALL TANKS	
MONDAY	7/23	7 AM	9.1	10	10.90	9.97	—	—	1944	76	117	126	106				
		3 PM	8.3	8	11.03	9.92	—	—	602	27	119	126	129				
		11PM	~~7.8~~	5	10.22	10.06	—	—	1247	57	126	131	123				
TUESDAY	7/24	7 AM	7.8	5	11.77	10.30	—	—	1894	72	112	119	130				
		3 PM	7.5	3	11.03	10.37	—	—	199	15	118	130	130				
		11PM	7.3	15	10.21	10.76	—	—	872	5?	126	124	124				
WEDNESDAY	7/25	7 AM	7.3	15	9.94	10.80	—	—	572	5	119	119	127				
		3 PM	6.2	14	9.98	10.43	—	—	976	28	126	120	128				
		11PM	~~5.2~~	11	10.51	10.12	—	—	1975	87	119	129	124				
THURSDAY	7/26	7 AM	5.2	10	10.76	10.16	—	—	2196	97	116	119	127				
		3 PM	5.2	9	9.62	10.36	—	—	516	14	126	122	125				
		11PM	3.9	8	9.78	10.35	—	—	1347	95	120	128	129				$4/3 \cdot r^3 \cdot \pi$
FRIDAY	7/27	7 AM	3.9	7	9.85	10.20	—	—	1971	112	127	123	128				959
		3 PM	3.6	5	10.35	10.12	—	—	256	15	124	128	126				
		11PM	2.6	3	9.80	10.31			1850	42	125	121	128				
SATURDAY																	
SUNDAY																	

AKC-0009593