JUNE
METRO LIMITS





ALASKAN COPPER WORKS
3200 FACILITY
JUNE 8, 2001
COMPOSITE M66238

ALASKAN COPPER WORKS
3200 FACILITY
JUNE 22, 2001
COMPOSITE M66323

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.25	0.29	0.26	0.07
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.31	0.22	0.18	0.05
LIMITS	2.75	3.00	2.50	2.61

JUNE
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
JUNE 28, 2001
COMPOSITE M65868

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.46	0.35	0.35	0.07
LIMITS	2.75	3.00	2.50	2.61