# JANUARY
## METRO LIMITS




**ALASKAN COPPER WORKS**
3200 FACILITY
JANUARY 20, 2000
COMPOSITE M63349




**ALASKAN COPPER WORKS**
3200 FACILITY
JANUARY 27, 2000
COMPOSITE M63444

VISUAL REPRESENTATION OF THE LAB RESULTS

| | CHROME | COPPER | NICKEL | ZINC |
|---|---|---|---|---|
| RESULTS | 0.25 | 0.27 | 0.27 | 0.05 |
| LIMITS | 2.75 | 3.00 | 2.50 | 2.61 |

| | CHROME | COPPER | NICKEL | ZINC |
|---|---|---|---|---|
| RESULTS | 0.13 | 0.14 | 0.16 | 0.07 |
| LIMITS | 2.75 | 3.00 | 2.50 | 2.61 |

# JANUARY
## METRO LIMITS




**ALASKAN COPPER WORKS**
3200 FACILITY
JANUARY 6, 2000
COMPOSITE M63305




**ALASKAN COPPER WORKS**
3200 FACILITY
JANUARY 13, 2000
COMPOSITE M63348

VISUAL REPRESENTATION OF THE LAB RESULTS

| | CHROME | COPPER | NICKEL | ZINC |
|---|---|---|---|---|
| RESULTS | 0.36 | 0.37 | 0.42 | 0.05 |
| LIMITS | 2.75 | 3.00 | 2.50 | 2.61 |

| | CHROME | COPPER | NICKEL | ZINC |
|---|---|---|---|---|
| RESULTS | 0.29 | 0.30 | 0.30 | 0.05 |
| LIMITS | 2.75 | 3.00 | 2.50 | 2.61 |