DECEMBER
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
DECEMBER 2, 1999
COMPOSITE M63130



ALASKAN COPPER WORKS
3200 FACILITY
DECEMBER 9, 1999
COMPOSITE M63158

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.12	0.16	0.13	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.37	0.41	0.46	0.05
LIMITS	2.75	3.00	2.50	2.61

DECEMBER
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
DECEMBER 17, 1999
COMPOSITE M63209



ALASKAN COPPER WORKS
3200 FACILITY
DECEMBER 22, 1999
GRAB M63234

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.59	0.72	0.59	0.10
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.12	0.15	0.13	0.05
LIMITS	2.75	3.00	2.50	2.61



	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.24	0.20	0.26	0.05
LIMITS	2.75	3.00	2.50	2.61