OCTOBER
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
OCTOBER 7, 1999
COMPOSITE M62766



ALASKAN COPPER WORKS
3200 FACILITY
OCTOBER 14, 1999
COMPOSITE M62806

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.23	0.30	0.27	0.06
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.43	0.27	0.36	0.05
LIMITS	2.75	3.00	2.50	2.61

OCTOBER
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
OCTOBER 21, 1999
COMPOSITE M62855



ALASKAN COPPER WORKS
3200 FACILITY
OCTOBER 28, 1999
COMPOSITE M62918

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.71	0.49	0.44	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.83	1.10	0.79	0.29
LIMITS	2.75	3.00	2.50	2.61