SEPTEMBER
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
SEPTEMBER 2, 1999
COMPOSITE M62543



ALASKAN COPPER WORKS
3200 FACILITY
SEPTEMBER 9, 1999
COMPOSITE M62544

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.33	0.26	0.31	0.07
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.22	0.15	0.12	0.05
LIMITS	2.75	3.00	2.50	2.61

SEPTEMBER
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
SEPTEMBER 16, 1999
COPMOSITE M62582



ALASKAN COPPER WORKS
3200 FACILITY
SEPTEMBER 23, 1999
COMPOSITE M62658

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.26	0.24	0.19	0.06
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.22	0.21	0.16	0.07
LIMITS	2.75	3.00	2.50	2.61



	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.27	0.36	0.31	0.15
LIMITS	2.75	3.00	2.50	2.61