AUGUST
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
AUGUST 12, 1999
COMPOSITE M62437



ALASKAN COPPER WORKS
3200 FACILITY
AUGUST 19, 1999
COMPOSITE M62471

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.20	0.18	0.11	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.28	0.23	0.23	0.05
LIMITS	2.75	3.00	2.50	2.61

AUGUST
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
AUGUST 26, 1999
COMPOSITE M62512



ALASKAN COPPER WORKS
3200 FACILITY
AUGUST 30, 1999
COMPOSITE M62523

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.23	0.14	0.11	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.58	0.55	0.26	0.06
LIMITS	2.75	3.00	2.50	2.61