MAY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
MAY 6, 1999
COMPOSITE M79029



ALASKAN COPPER WORKS
3200 FACILITY
MAY 13, 1999
COMPOSITE M61966

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.45	0.84	0.75	0.07
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.46	0.51	0.38	0.07
LIMITS	2.75	3.00	2.50	2.61

MAY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
MAY 18, 1999
GRAB M79101



ALASKAN COPPER WORKS
3200 FACILITY
MAY 19, 1999
COMPOSITE M61999

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.54	0.56	0.58	0.06
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	1.10	1.10	1.30	0.15
LIMITS	2.75	3.00	2.50	2.61



	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.24	0.25	0.29	0.08
LIMITS	2.75	3.00	2.50	2.61