APRIL
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
APRIL 1, 1999
COMPOSITE M61742



ALASKAN COPPER WORKS
3200 FACILITY
APRIL 8, 1999
COMPOSITE M78778

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.24	0.42	0.33	0.11
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.50	0.49	0.48	0.05
LIMITS	2.75	3.00	2.50	2.61

APRIL
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
APRIL 15, 1999
COPMOSITE M61818



ALASKAN COPPER WORKS
3200 FACILITY
APRIL 22, 1999
COMPOSITE M61845

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.42	0.33	0.21	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.41	0.43	0.39	0.07
LIMITS	2.75	3.00	2.50	2.61



	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.84	0.74	0.80	0.05
LIMITS	2.75	3.00	2.50	2.61