MARCH
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
MARCH 4, 1999
COMPOSITE M61548



ALASKAN COPPER WORKS
3200 FACILITY
MARCH 11, 1999
COMPOSITE M78545

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.76	0.65	0.89	0.07
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.22	0.28	0.30	0.16
LIMITS	2.75	3.00	2.50	2.61

AKC-0010588

MARCH
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
MARCH 18, 1999
COPMOSITE M78624



ALASKAN COPPER WORKS
3200 FACILITY
MARCH 25, 1999
COMPOSITE M78760

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.62	0.61	0.64	0.08
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.24	0.32	0.21	0.06
LIMITS	2.75	3.00	2.50	2.61

AKC-00105589