FEBRUARY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
FEBRUARY 4, 1999
COMPOSITE M78287



ALASKAN COPPER WORKS
3200 FACILITY
FEBRUARY 11, 1999
COMPOSITE M78354

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.32	0.43	0.45	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.30	0.22	0.33	0.05
LIMITS	2.75	3.00	2.50	2.61

AKC-0010596

FEBRUARY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
FEBRUARY 18, 1999
COPMOSITE M78412



ALASKAN COPPER WORKS
3200 FACILITY
FEBRUARY 25, 1999
COMPOSITE M78468

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.51	0.49	0.58	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.19	0.18	0.14	0.05
LIMITS	2.75	3.00	2.50	2.61

AKC-0010597