JANUARY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
JANUARY 14, 1999
COMPOSITE M78111



ALASKAN COPPER WORKS
3200 FACILITY
JANUARY 21, 1999
COMPOSITE M78182

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.29	0.38	0.32	0.07
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.30	0.34	0.36	0.14
LIMITS	2.75	3.00	2.50	2.61

AKC-0010647



	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.62	0.68	0.72	0.06
LIMITS	2.75	3.00	2.50	2.61

AKC-0010648