DECEMBER
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
DECEMBER 3, 1998
COMPOSITE M61136



ALASKAN COPPER WORKS
3200 FACILITY
DECEMBER 10, 1998
COMPOSITE M77881

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.44	0.30	0.35	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.35	0.42	0.38	0.05
LIMITS	2.75	3.00	2.50	2.61

AKC-0010684

DECEMBER
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
DECEMBER 17, 1998
COPMOSITE M77929



ALASKAN COPPER WORKS
3200 FACILITY
DECEMBER 22, 1998
COMPOSITE M77971

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.52	0.52	0.58	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.42	0.24	0.31	0.05
LIMITS	2.75	3.00	2.50	2.61

AKC-0010685



	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.31	0.28	0.31	0.05
LIMITS	2.75	3.00	2.50	2.61

AKC-0010686