AUGUST
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
AUGUST 6, 1998
COMPOSITE M11909



ALASKAN COPPER WORKS
3200 FACILITY
AUGUST 13, 1998
COMPOSITE M76905

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.58	0.29	0.56	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.54	0.29	0.59	0.05
LIMITS	2.75	3.00	2.50	2.61

AKC-0010841

AUGUST
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
AUGUST 20, 1998
COPMOSITE M11992



ALASKAN COPPER WORKS
3200 FACILITY
AUGUST 28, 1998
COMPOSITE M76998

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.30	0.28	0.30	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.97	0.94	1.20	0.08
LIMITS	2.75	3.00	2.50	2.61

AKC-0010842