JULY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
JULY 2, 1998
COMPOSITE M11598



ALASKAN COPPER WORKS
3200 FACILITY
JULY 9, 1998
COMPOSITE M11653

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.50	0.27	0.41	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.22	0.22	0.31	0.05
LIMITS	2.75	3.00	2.50	2.61

AKC-0010876

JULY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
JULY 16, 1998
COPMOSITE M11711



ALASKAN COPPER WORKS
3200 FACILITY
JULY 23, 1998
COMPOSITE M11763

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.23	0.22	0.29	0.07
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.57	0.32	0.66	0.06
LIMITS	2.75	3.00	2.50	2.61

AKC-0010877



	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.71	0.45	0.86	0.10
LIMITS	2.75	3.00	2.50	2.61

AKC-0010878