REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° OAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/O#)
MONDAY	10/6	7 AM	14	5	10.15	9.51	–	–	2422	117	125	Err	101				
		3 PM	13	16	9.89	10.20	–	–	552	99	125	Err	125				
		11PM	11	13	10.21	9.91	–	–	1283	147	Error	Error	Error				
TUESDAY	10/7	7 AM	11	12	11.63	9.90	–	10	1562	160	Err	Err	Err				
		3 PM	10	10	9.90	9.77	–	–	700	60	120	121	Err				
		11PM	9	7		9.83	–	–	2226	91	120	131	Error				
WEDNESDAY	10/8	7 AM	9	6	9.85	9.72	–	–	2721	103	125	140	Err				
		3 PM	8	18	10.24	9.66	–	–	965	34	115	136	Err				
		11PM	7	15	10.71	9.98	–	–	1793	82	124	145	Err				
THURSDAY	10/9	7 AM	6	14	9.87	10.08	–	–	2240	91	121	149	Err				I THINK ACID TANK TEMPS ARE OFF
		3 PM	33	12	10.08	9.93	–	–	630	31	119	146	ERR				
		11PM	32	10	10.60	10.25	–	–	1315	71	123	150	Error				
FRIDAY	10/10	7 AM	32	10	9.81	9.88	–	–	2030	99	120	153	Err				
		3 PM	32	9	10.41	9.78	–	–	537	30	127	153	Err				
		11PM	30	6	11.00	9.66	–	–	1556	92	Error	151	Error				
SATURDAY		AM															
		PM															
		PM															
SUNDAY		AM															
		PM															
		PM															

AKC-0011245