SEPTEMBER
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
SEPTEMBER 4, 1997
GRAB M60703



ALASKAN COPPER WORKS
3200 FACILITY
SEPTEMBER 4, 1997
COMPOSITE M60702

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	1.50	1.10	1.60	0.08
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	1.20	1.00	0.80	0.09
LIMITS	2.75	3.00	2.50	2.61

AKC-0011303