MAY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
MAY 7, 1998
COMPOSITE M10954



ALASKAN COPPER WORKS
3200 FACILITY
MAY 14, 1998
COMPOSITE M11049

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.38	0.24	0.42	0.06
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.68	0.37	0.60	0.07
LIMITS	2.75	3.00	2.50	2.61

AKC-0010946

MAY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
MAY 21, 1998
COPMOSITE M11160



ALASKAN COPPER WORKS
3200 FACILITY
MAY 28, 1998
COMPOSITE M11208

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.51	0.32	0.55	0.12
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.40	0.26	0.37	0.06
LIMITS	2.75	3.00	2.50	2.61

AKC-0010947