FEBRUARY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
FEBRUARY 5, 1998
COMPOSITE M59989



ALASKAN COPPER WORKS
3200 FACILITY
FEBRUARY 12, 1998
COMPOSITE M59993

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.69	0.77	0.52	0.11
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.59	0.70	0.59	0.12
LIMITS	2.75	3.00	2.50	2.61

AKC-0011051

FEBRUARY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
FEBRUARY 19, 1998
COPMOSITE M10133



ALASKAN COPPER WORKS
3200 FACILITY
FEBRUARY 26, 1998
COMPOSITE M10207

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.77	0.50	0.63	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.56	0.38	0.47	0.05
LIMITS	2.75	3.00	2.50	2.61

AKC-0011052