NOVEMBER
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
NOVEMBER 6, 1997
COMPOSITE M59019



ALASKAN COPPER WORKS
3200 FACILITY
NOVEMBER 10, 1997
GRAB M59039

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.31	0.30	0.34	0.09
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.49	0.55	0.59	0.11
LIMITS	2.75	3.00	2.50	2.61

AKC-0011195

NOVEMBER
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
NOVEMBER 13, 1997
COPMOSITE M59089



ALASKAN COPPER WORKS
3200 FACILITY
NOVEMBER 20, 1997
COMPOSITE M59166

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.32	0.37	0.28	0.10
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.55	0.57	0.53	0.07
LIMITS	2.75	3.00	2.50	2.61

AKC-0011196

NOVEMBER
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
NOVEMBER 13, 1997
COPMOSITE M59089



ALASKAN COPPER WORKS
3200 FACILITY
NOVEMBER 20, 1997
COMPOSITE M59166

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.32	0.37	0.28	0.10
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.55	0.57	0.53	0.07
LIMITS	2.75	3.00	2.50	2.61

AKC-0011197



	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.90	0.42	0.92	0.05
LIMITS	2.75	3.00	2.50	2.61

AKC-0011198



VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.90	0.42	0.92	0.05
LIMITS	2.75	3.00	2.50	2.61

AKC-0011199

NOVEMBER
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
NOVEMBER 6, 1997
COMPOSITE M59019



ALASKAN COPPER WORKS
3200 FACILITY
NOVEMBER 10, 1997
GRAB M59039

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.31	0.30	0.34	0.09
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.49	0.55	0.59	0.11
LIMITS	2.75	3.00	2.50	2.61

AKC-0011194