AUGUST
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
AUGUST 5, 1997
GRAB M58026



ALASKAN COPPER WORKS
3200 FACILITY
AUGUST 7, 1997
COMPOSITE M58062

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.89	0.97	1.10	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.60	1.40	0.78	0.33
LIMITS	2.75	3.00	2.50	2.61

AKC-0011408

AUGUST
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
AUGUST 14, 1997
COMPOSITE M58140



ALASKAN COPPER WORKS
3200 FACILITY
AUGUST 19, 1997
GRAB M58177

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.20	0.48	0.39	0.06
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.54	0.57	0.62	0.05
LIMITS	2.75	3.00	2.50	2.61

AKC-0011409

AUGUST
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
AUGUST 21, 1997
COMPOSITE M58207



ALASKAN COPPER WORKS
3200 FACILITY
AUGUST 25, 1997
GRAB M58232

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.73	0.72	0.74	0.07
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.33	0.55	0.39	0.11
LIMITS	2.75	3.00	2.50	2.61

AKC-0011410



	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.94	0.74	1.10	0.12
LIMITS	2.75	3.00	2.50	2.61

AKC-00114111