JULY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
JULY 1, 1997
COMPOSITE M57705



ALASKAN COPPER WORKS
3200 FACILITY
JULY 3, 1997
COMPOSITE M74695

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.35	0.31	0.29	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.34	0.35	0.33	0.07
LIMITS	2.75	3.00	2.50	2.61

AKC-0011418

JULY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
JULY 10, 1997
COMPOSITE M57788



ALASKAN COPPER WORKS
3200 FACILITY
JULY 14, 1997
GRAB M57810

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.49	0.37	0.58	0.08
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.35	0.22	0.25	0.05
LIMITS	2.75	3.00	2.50	2.61

AKC-0011419

JULY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
JULY 17, 1997
COMPOSITE M57846



ALASKAN COPPER WORKS
3200 FACILITY
JULY 22, 1997
GRAB M57890

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.23	0.31	0.27	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.75	0.76	0.93	0.10
LIMITS	2.75	3.00	2.50	2.61

AKC-0011420

JULY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
JULY 31, 1997
COMPOSITE M57983

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.44	0.47	0.52	0.05
LIMITS	2.75	3.00	2.50	2.61

AKC-0011421