JUNE
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
JUNE 4, 1997
GRAB M57380



ALASKAN COPPER WORKS
3200 FACILITY
JUNE 5, 1997
COMPOSITE M57412

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	1.70	1.50	2.10	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.48	0.60	0.49	0.06
LIMITS	2.75	3.00	2.50	2.61

AKC-0011464

JUNE
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
JUNE 11, 1997
GRAB M57492



ALASKAN COPPER WORKS
3200 FACILITY
JUNE 12, 1997
COMPOSITE M57499

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.28	0.24	0.28	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.28	0.24	0.28	0.05
LIMITS	2.75	3.00	2.50	2.61

AKC-0011465

JUNE
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
JUNE 16, 1997
GRAB M57538



ALASKAN COPPER WORKS
3200 FACILITY
JUNE 19, 1997
COMPOSITE M57597

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.47	0.35	0.64	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.38	0.35	0.44	0.05
LIMITS	2.75	3.00	2.50	2.61

AKC-0011466

JUNE
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
JUNE 25, 1997
GRAB M57641



ALASKAN COPPER WORKS
3200 FACILITY
JUNE 26, 1997
COMPOSITE M57658

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.24	0.30	0.23	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.27	0.34	0.25	0.05
LIMITS	2.75	3.00	2.50	2.61

AKC-0011467