MAY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
MAY 2, 1995
M41235 COMPOSITE



ALASKAN COPPER WORKS
3200 FACILITY
MAY 3, 1995
M41264 COMPOSITE

VISUAL REPRESENTATION OF LABS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	2.2	0.87	1.7	0.05
LIMITS	2.75	3.00	2.5	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	2.4	0.76	1.7	0.05
LIMITS	2.75	3.00	2.5	2.61

AKC-0012910

MAY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
MAY 4, 1995
M41097 COMPOSITE



ALASKAN COPPER WORKS
3200 FACILITY
MAY 5, 1995
M41096 COMPOSITE

VISUAL REPRESENTATION OF LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	2.1	0.73	1.6	0.07
LIMITS	2.75	3.00	2.5	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	2.3	0.84	1.8	0.05
LIMITS	2.75	3.00	2.5	2.61

AKC-0012911

MAY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
MAY 9, 1995
M41327 COMPOSITE



ALASKAN COPPER WORKS
3200 FACILITY
MAY 10, 1995
M41345 COMPOSITE

VISUAL REPRESENTATION OF LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	2.00	0.97	1.7	0.05
LIMITS	2.75	3.00	2.5	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	2.8	1.4	2.1	0.08
LIMITS	2.75	3.00	2.5	2.61

AKC-0012912

MAY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
MAY 11, 1995
M41346 COMPOSITE



ALASKAN COPPER WORKS
3200 FACILITY
MAY 12,1995
M41364 COMPOSITE

VISUAL REPRESENTATION OF LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	12.00	5.3	11.00	0.2
LIMITS	2.75	3.00	2.5	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	1.3	0.5	0.89	0.05
LIMITS	2.75	3.00	2.5	2.61

AKC-0012913

MAY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
MAY 15, 1995
M41379 COMPOSITE



ALASKAN COPPER WORKS
3200 FACILITY
MAY 16, 1995
MM41410 COMPOSITE

VISUAL REPRESENTATION OF LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	1.1	0.4	0.8	0.05
LIMITS	2.75	3.00	2.5	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	1.3	0.59	0.9	0.05
LIMITS	2.75	3.00	2.5	2.61

AKC-0012914

MAY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
MAY 17, 1995
M41424 COMPOSITE



ALASKAN COPPER WORKS
3200 FACILITY
MAY 18, 1995
M41436 COMPOSITE

VISUAL REPRESENTATION OF LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	1.4	0.59	1.1	0.05
LIMITS	2.75	3.00	2.5	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	1.3	0.5	1.00	0.05
LIMITS	2.75	3.00	2.5	2.61

AKC-0012915

MAY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
MAY 19, 1995
M41456 COMPOSITE



ALASKAN COPPER WORKS
3200 FACILITY
MAY 22, 1995
M41462 COMPOSITE

VISUAL REPRESENTATION OF LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	1.8	0.8	1.4	0.05
LIMITS	2.75	3.00	2.5	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.94	0.36	0.65	0.05
LIMITS	2.75	3.00	2.5	2.61

AKC-0012916

MAY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
MAY 23, 1995
M41477 COMPOSITE



ALASKAN COPPER WORKS
3200 FACILITY
MAY 24, 1995
M41955 COMPOSITE

VISUAL REPRESENTATION OF LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	1.7	0.7	1.2	0.07
LIMITS	2.75	3.00	2.5	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	1.8	0.77	1.3	0.05
LIMITS	2.75	3.00	2.5	2.61

AKC-0012917

MAY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
MAY 25, 1995
M41970 COMPOSITE



ALASKAN COPPER WORKS
3200 FACILITY
MAY 26, 1995
M41976 COMPOSITE

VISUAL REPRESENTATION OF LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	1.3	0.57	0.98	0.05
LIMITS	2.75	3.00	2.5	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	2.2	0.91	1.7	0.05
LIMITS	2.75	3.00	2.5	2.61

AKC-0012918



	CHROME	COPPER	NICKEL	ZINC
RESULTS	1.2	0.35	0.71	0.05
LIMITS	2.75	3.00	2.5	2.61

AKC-0012919