MARCH
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
MARCH 9,1995
M38711 GRAB



ALASKAN COPPER WORKS
3200 FACILITY
MARCH 10,1995
M40470 COMPOSITE

VISUAL REPRESENTATION OF LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	2.5	1.4	1.9	0.08
LIMITS	2.75	3.00	2.5	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	16.00	7.6	14.00	0.29
LIMITS	2.75	3.00	2.5	2.61

AKC-0012992

MARCH
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
MARCH 11,1995
M40480 GRAB



ALASKAN COPPER WORKS
3200 FACILITY
MARCH 28,1995
M40487 COMPOSITE

VISUAL REPRESENTATION OF LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	2.00	0.98	1.9	0.1
LIMITS	2.75	3.00	2.5	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	2.1	0.87	1.7	0.07
LIMITS	2.75	3.00	2.5	2.61

AKC-0012993