FEBRUARY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
FEBRUARY 10, 1995
M40251 COMPOSITE



ALASKAN COPPER WORKS
3200 FACILITY
FEBRUARY 21, 1995
M40324 COMPSITE

VISUAL REPRESENTATION OF LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.81	0.51	0.64	0.05
LIMITS	2.77	3.00	3.98	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.41	0.25	0.3	0.05
LIMITS	2.77	3.00	3.98	2.61

AKC-0013023