REF. DWG NO. 500-0007

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP °F LARGE TANK	TEMP °F SMALL TANK	COMMENTS, PROBLEMS, & REMARKS
MONDAY	10/31	7:00	18	6	10.7	9.82	—	—	1315	28	120°	120°	PAC Press emptied
		3:00	16	5	9.9	10.36	—	—	674	14	120°	120°	
		11:30	15	4	11.8	10.40	—	—	1475	35	120	110	
TUESDAY	11/1	7:00	15	4	10.8	10.53	—	—	1628	34	120°	120°	Met with Tim Coffey of metro Regarding sump changes
		3:00											
		11:30	12	3	11.7	10.66	—	10	1622	33	120°	110°	
WEDNESDAY	11/2	7:00	12	3	10.0	10.50	—	10	1895	38	120°	120°	
		3:00	10	2	11.6	10.26	—	—	630	9	120°	120°	
		11:30	9	2	11.9	10.52	—	—	1508	34	115	110	
THURSDAY	11/3	7:00	9	1	11.2	10.55	—	10	1716	38	115°	115°	Power to Pumphouse was turned off for 1hr for work on the Gate Area
		3:00	8	1	11.5	10.0	—	~~10~~	502	5	120	120	
		11:30	6	5	9.3	10.18			1675	29	115	115	
FRIDAY	11/4	7:00	6	1	10.8	10.24	—	10	1931	29	115	115	Added Floc & Caustic
		3:00	16	15	12.3	10.70	—	—	614	10	115°	115°	
		11:30	16	13	11.9	11.08	—	—	1375	21	115	110	
SATURDAY	11/5	5:00	16	13	9.7	10.97	—	11	1650	22	115	110	Emptied PAC press
		1:30	16	12	11.4	9.38	—	—	649	7	120°	120°	
		9:00	15	11	10.1	10.14	—	10	1185	16	115°	110°	
SUNDAY													

AKC-0013092

REF. DWG NO. 500-0007

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP °F LARGE TANK	TEMP °F SMALL TANK	COMMENTS, PROBLEMS, & REMARKS
MONDAY	11/7	7:00	15	12	10.6	9.92	–	10	1185	17	125°	100°	
		3:00	14	10	11.5	10.51	–	–	1064	13	130	105°	
		11:30	13	10	11.7	10.13	–	10	1804	23	140°	105°	
TUESDAY	11/8	7:00	13	10	10.2	9.94	–	10	2139	24	140°	105°	Sumps Cleaned
		3:00											Checked pH by hand.
		11:30	11	9	11.3	Err	–	10	1125	47	115°	112°	
WEDNESDAY	11/9	7:00	11	9	11.2	Err	–	11.5	1323	51	120°	120°	Ph Probe Repair and working @ 8:54
		3:00	8	8	9.5	9.68			1772	33	115	115	Emptied Pac-Press
		11:30	~~8~~	~~8~~	~~11.2~~	~~9.77~~	~~–~~	~~10~~		~~40~~	~~11~~		
THURSDAY	11/10	7:00	8	8	11.2	9.72	–	10	1986	40	115	115	5:30 Start
		3:00	7	7	10.1	9.69	–	10	968	4	115°	115°	Caustic is added at pH 9.[illegible] ?
		11:30	5	6	9.6	9.80			1973	24	115	125	
FRIDAY	11/11	7:00	4	6	9.8	9.56	–	10	2079	36	120°	120°	added Caustic
		3:00	17	5	10.4	10.50			1262	38	115	140	?
		11:30	17										
SATURDAY	11/12	5:00	17	5	11.7	10.19	–	10	1316	39	115°	135°	
		1:30	17	5	11.6	10.55	–	–	1418	8	115°	130°	
		~~11~~	16	4	11.9	11.42			1996	20	115	145	
SUNDAY													

AKC-0013093

REF. DWG NO. 500-00

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP °F LARGE TANK	TEMP °F SMALL TANK	COMMENTS, PROBLEMS, & REMARKS
MONDAY	11/14	7:00	16	5	11.3	10.91	—	11	2401	26	115°	150°	Check the probe,
		3:00	15	4	11.3	10.83	—	—	754	10	115°	140°	Adding caustic at pH 9.4
		11:30	13	3	11.4	12.54	—	11	1591	29	110°	135°	
TUESDAY	11/15	7:00	13	3	10.5	Ear 12.83	—	11	1719	36	115°	130°	Out Put Probe Reading 12.82 Ph Paper 11
		3:00	12	2	11.3	8.60	—	—	2923	9	115	125°	Recalibrated Forgot to reset
		11:30	10	1	11.7	8.89	—	9.	3651	31	115°	120°	Changed Great Lakes Electrode
WEDNESDAY	11/16	5:00 ~~7:00~~	10	1	11.5				2232 / 3951	53	115°	120°	5:00 Start Acid 3:00 Start Al PJT 3951 / 1719 / 2232
		3:00	6										
		11:30	6	?	12.1	11.43			1331	70	116	115	
THURSDAY	11/17	7:00	6	1	11.54	10.4	—	11	1453	72	115°	115°	8:00 Start
		3:00											
		11:30	9	13	9.7	12.0	—	11	1530	94	110°	115°	
FRIDAY	11/18	7:00	8	13	10.9	11.9	—	—	1745	96	115°	115°	
		3:00	8	12	10.4	12.08	—	12	537	8	115°	115°	
		11:30	7	12	10.2	11.29	—	11.00	1145	22	115°	120°	
SATURDAY		5:30	7	14	10.4	11.2			1193	24	110°	115°	
SUNDAY													

AKC-0013094

REF. DWG NO. 500-0007

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP °F LARGE TANK	TEMP °F SMALL TANK	COMMENTS, PROBLEMS, & REMARKS
MONDAY	11/21	7:00	5	11	10.4	11.25	—		1468	24	115	120°	Added Caustic
		3:00	32	10	11.5	11.8	—	11	651	15	115°	115°	
		11:30	31	10	11.5	12.03			1233	28	115	115	
TUESDAY	11/22	7:00	31	9	9.9	12.04	—	12	1665	33	115	115	500 Start
		3:00	29	8	11.9	12.06		~~12.06~~	941	02	110	115	Empty Pac Press /
		11:30	28	7	9.5	11.81			1310	21	110	130	Cleaned Filters
WEDNESDAY	11/23	7:00	28	7	10.9		—	10	1829	29	115°	115°	3:00 Start Dam Project Prepwork
		3:00											5:00 Shop Start
		11:30	24	7	10.4	11.44			~~2584~~ 4413	38	105	130	6:00 System Back together & Cleaned forgot to Reset 3367 4413 1829 2584
THURSDAY	Thanksgiving	7:00											
		3:00											
		11:30											
FRIDAY	Holiday	7:00											Worked on Output Pit
		3:00											
		11:30											
SATURDAY													
SUNDAY													

AKC-0013095

REF. DWG NO. 500-0007

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP °F LARGE TANK	TEMP °F SMALL TANK	COMMENTS, PROBLEMS, & REMARKS
MONDAY	11/28	7:00	24	7	9.6	7.74	—	—	2740	46	85	115	5:00 start
		3:00	23	6	11.7	10.86	—	—	1409	20	95	ERR	
		11:30	22	5	11.08	11.04	—	10.	2227	38	110°	Err	
TUESDAY	11/29	7:00	22	5	10.6	11.15	—	11	2546	41	110	ERR	5:00 start Emptied PAC Press Pumped Recirculant
		3:00	21	5	11.9	12.22	—	—	700	1	110	90°	
		11:30	21	4	10.4	11.88	—	—	1103	9	110	120	
WEDNESDAY	11/30	7:00	20	4	10.1	10.87	—	—	1844	13	120°	120°	5:00 start
		3:00	20	4	10.9	11.70	—	11.	451	4	120°	120°	
		11:30	20	3	11.1	10.77	—	10.	934	12	115°	120°	
THURSDAY	12/1	7:00	19	3	12.0	10.61	—	10	1689	14	120°	120°	5:00 start
		3:00	18	2	9.8	11.37	—	—	830	8	115	120	
		11:30	18	2	10.5	11.18	—	—	1095	18	115	125	
FRIDAY	12/2	7:00	17	1	10.0	10.77	—	11	1506	22	115	135	5:00 start
		~~3:00~~	16	1	11.4	11.49			1366	01	115	135	
		11:30							1366				
SATURDAY													
SUNDAY													

AKC-0013096