REF. DWG NO. 500-0007 REV. A 1594

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC. LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP F° LARGE TANK	TEMP F° SMALL TANK	TEMP F° DAKITE TANK	REVETMENT LARGE RINSE	REVETMENT LARGE ACID	REVETMENT SMALL TANKS	COMMENTS, PROBLEMS, & REMARKS (W/D#)
MONDAY	6/16	7 AM	7	14	10.42	9.71	–	10	1915	106	130°	130°	116°				
		3 PM	6	12	12.16	10.00	–	–	1089	43	130	130	125°				
		11PM	5	9	11.62	9.96	–	–	2310	91	125	125	128				
TUESDAY	6/17	7 AM	4	8	10.75	10.34	–	10	2851	126	125°	125	130°				
		3 PM	3	7	9.77	9.97	–	–	758	38	125	125	122				
		11PM	3	17	10.1	10.21	–	–	1582	78	130°	125°	124°				
WEDNESDAY	6/18	7 AM	3	16	10.56	10.08	–	–	2048	103	125°	130°	122°				Forgot to Reset Flow & Cycles
		3 PM	34	14	12.55	10.48	–	–	3301	136	125	125	127				Added Caustic
		11PM	33	12	11.84	11.21	–	–	4259	171	125	125	130				Emptied pac press
THURSDAY	6/19	7 AM	33	12	12.05	9.81	–	–	2770/4778	196	125	125	129				
		3 PM	32	9	10.81	9.79	–	–	747	37	125°	125°	121°				
		11PM	31	7	10.41	9.55	–	–	1726	107	125°	125°	121°				
FRIDAY	6/20	7 AM	30	4	9.67	9.81	–	10	283	146	128°	125°	130°				made floc
		3 PM	29	18	10.52	9.63	–	–	1173	43	125	125	121				
		11PM	29	16	10.14	9.93	–	–	1876	93	125	125	122				
SATURDAY	6/21	4:30 AM	29	15	9.78	9.81	–	–	2277	110	125	125	124				
		1:00 PM	32	12½	10.31	9.84	–	–	939	48	128°	125°	102°				
		PM															
SUNDAY		AM															
		PM															
		PM															

AKC-0011511

4778
2048
2730

5841
1830
2071