MAY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
MAY 1, 1997
COMPOSITE M57058



ALASKAN COPPER WORKS
3200 FACILITY
MAY 8, 1997
COMPOSITE M57143

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.30	0.28	0.29	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.48	0.57	0.80	0.13
LIMITS	2.75	3.00	2.50	2.61

AKC-0011517

MAY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
MAY 9, 1997
GRAB M57155



ALASKAN COPPER WORKS
3200 FACILITY
MAY 14, 1997
GRAB M57191

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.33	0.34	0.41	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.29	0.24	0.29	0.05
LIMITS	2.75	3.00	2.50	2.61

AKC-0011518

MAY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
MAY 15, 1997
COMPOSITE M57215



ALASKAN COPPER WORKS
3200 FACILITY
MAY 16, 1997
GRAB M74393

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.33	0.34	0.42	0.05
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.36	0.25	0.36	0.05
LIMITS	2.75	3.00	2.50	2.61

AKC-0011519

MAY
METRO LIMITS



ALASKAN COPPER WORKS
3200 FACILITY
MAY 21, 1997
GRAB M57272



ALASKAN COPPER WORKS
3200 FACILITY
MAY 22, 1997
COMPOSITE M57284

VISUAL REPRESENTATION OF THE LAB RESULTS

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.42	0.44	0.71	0.06
LIMITS	2.75	3.00	2.50	2.61

	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.89	0.63	0.93	0.06
LIMITS	2.75	3.00	2.50	2.61

AKC-0011520



	CHROME	COPPER	NICKEL	ZINC
RESULTS	0.73	0.61	0.83	0.06
LIMITS	2.75	3.00	2.50	2.61

AKC-0011521