REF. DWG NO. 500-0007

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP °F LARGE TANK	TEMP °F SMALL TANK	COMMENTS, PROBLEMS, & REMARKS
MONDAY	3/28	7:00	4	5	8.6	9.49	—	9	3236	29	135°	115°	
		3:00	3	4	9.9	8.72	—	8	1184	16	135°	115°	
		11:30	2	3	8.0	10.13	—	10	2015	33	130°	115°	
TUESDAY	3/29	7:00	2	2	9.56	12.2	—	9	2710	41	130°	120°	Add caustic
		3:00	33	2	10.57	10.51	—	—	1117	4	130°	120°	
		11:30	33	2	12.1	11.13	—	10.	1926	11	130°	120°	
WEDNESDAY	3/30	7:00	33	1	8.0	10.86	—	10	2567	11	150°	115°	Emptied Pac-Press.
		3:00	32	1	12.4	10.67	—	—	1691	10	150°	110°	
		11:30	32	1	8.3	10.66	—	10	2473	16	150°	110°	
THURSDAY	3/31	7:00	32	1	9.5	10.55	—	10	2672	17	160°	110°	
		3:00	31	35	8.6	10.78	—	—	1706	3	145°	110°	
		11:30	29	1	9.4	10.19	—	10	2544	23	135°	110°	
FRIDAY	4/1	7:00	29	13	11.4	11.07	—	11	2975	96	135°	120°	
		3:00	29	13	11.1	10.74	—	—	1156	8	130°	115°	
		11:30	28	12	12	10.70	—	10	1954	20	130°	105°	
SATURDAY													
SUNDAY													

AKC-0013305

REF. DWG NO. 500-0007

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP °F LARGE TANK	TEMP °F SMALL TANK	COMMENTS, PROBLEMS, & REMARKS
MONDAY	4/4	7:00	27	12	11.9	10.65	–	10	2278	22	90°	80°	Emptied PAC Press
		3:00	27	10	12.0	11.08	–	–	3510	7	105°	80°	forgot to Reset flow meter
		11:30	~~25~~										
TUESDAY	4/5	7:00	25	10	11.7	10.94	–	10	5441 / 3163	31	145°	90°	Need to Reset flowmeter
		3:00	25	10	10.1	11.17	–	–	6292 / 851	7	140°	95°	
		11:30	24	9	12.4	11.11	–	10	7286	21	190°	100°	metro GRAD 24 HR
WEDNESDAY	4/6	7:00	24	8	8.4	11.07	–	11	7764 / 2323	23	140°	100°	WAS 5441 IS 7764
		3:00	23	7	11.4	10.07	–	–	2051	13	140°	100°	
		11:30	22	6	10.7	10.99	–	10	3157	28	135°	100°	
THURSDAY	4/7	7:00	22	6	11.6	10.48	–	~~[illegible]~~	3522	34	140°	105°	Called at 3:15 Arrived 4:40
		3:00	21	5	9.4	10.49	–	–	2013	7	140°	105°	Acid yard Complete flooded flow maxed
		11:30	19	4	11.3	10.80	–	10	3748	23	140°	110°	Ph 6.92 Hose on
FRIDAY	4/8	7:00	19	4	8.8	9.79	–	–	3892	24	140°	110°	Cleaned sumps
		3:00	18	4	10.00	10.80	–	–	1697	12	140°	105°	
		11:30	16	3	11.3	10.22	–	10	3233	33	140°	105°	
SATURDAY			16	2	10.4	10.2	–	–	756	5	140°	105°	
SUNDAY													

6292 / 5441 / 851

631 / 7836 / 5441 / 1995

7764 / 5441 / 2323

3522

AKC-0013306

REF. DWG NO. 500-0007

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP °F LARGE TANK	TEMP °F SMALL TANK	COMMENTS, PROBLEMS, & REMARKS
MONDAY	4/11	7:00	16	1	10.1	10.23	–	–	756 ~~3983~~	38	140	95	Emptied Pac-Press.
		3:00	15	1	7.7	10.52	–	–	1363	04	135°	100°	
		11:30	15	1	7.6	10.72	–	10	2167	15	110°	90°	
TUESDAY	4/12	7:00	14	1	12.2	10.36	–	10	2637	18	110°	90°	Cleaned Hopper in Boiler room Power off for 1/2 hr to repair float in Teal Tank.
		3:00	14	10	8.8	9.95	–	–	536	19	110°	90°	
		11:30	14	8	12.1	9.94	–	10	1397	25	140°	90°	
WEDNESDAY	4/13	7:00	14	8	11.2	10.48	–	10	1926	25	135°	90°	
		3:00	14	7	10.8	10.58	–	–	800	6	130°	90°	
		11:30	14	5	11.9	10.96	–	10	1053	6	130°	100°	
THURSDAY	4/14	7:00	13	5	9.0	11.26	–	11	1626	7	135°	95°	
		3:00	13	4	12.5	10.52	–	[illegible]	200	5	140°	95°	
		11:30											
FRIDAY	4/15	7:00	13	4	9.9	10.60	–	10	1149	11	140°	100°	
		3:00	13	4	12.1	10.55	–	–	552	5	140°	100°	
		11:30	13	4	9.0	10.79	–	10	772	8	130°	100°	
SATURDAY													
SUNDAY													

AKC-0013307

REF. DWG NO. 500-0007

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP °F LARGE TANK	TEMP °F SMALL TANK	COMMENTS, PROBLEMS, & REMARKS
MONDAY	4/18	7:00	11	3	8.2	10.90	—	11	2978	29	90°	70°	
		3:00	10	15	11.9	10.55	—	—	313	2	95°	70°	
		11:30	9	13	9.8	11.69	—	10	1228	14	115°	90°	
TUESDAY	4/19	7:00	9	13	11.2	11.57	—	11	1772	14	140°	90°	
		3:00	9	13	11.5	11.53	—	—	621	6	140°	100°	
		11:30	8	10	9.4	11.42	—	10	1535	17	140°	105°	
WEDNESDAY	4/20	7:00	8	10	8.7	11.36	—	11	1973	17	140°	105°	5:00 start
		3:00	7	9	9.3	11.10	—	—	852	1	140°	100°	
		11:30	7	8	11.0	10.32	—	10	2318	5	150°	105°	
THURSDAY	4/21	7:00	7	8	10.1	11.12	—	11	2774	5	160°	105°	500 start
		3:00											
		11:30	4	7	8.0	11.35	—	10	2455	32	155°	100°	
FRIDAY	4/22	7:00	4	5	11.3	11.06	—	11	2552	37	155°	105°	500 start
		3:00	4	5	8.5	10.81	—	—	1614	9	160°	100°	
		11:30	3	4	12.0	10.48	—	10	2699	20	160°	105°	
SATURDAY									2699				
		3:00	1	1	5.7	12.07	—	12	4589	56	120°	90°	
			32	1	7.8	12.09	—	11	4655	62	115°	85°	
SUNDAY									2391				

4581
5080
2699
2391

AKC-0013308

REF. DWG NO. 500-0007

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP °F LARGE TANK	TEMP °F SMALL TANK	COMMENTS, PROBLEMS, & REMARKS
MONDAY	4/25	7:00	33	15	11.8	11.60	—	—	2391	66	140°	90°	500 start
		3:00	32	15	12.5	11.04	—	—	1315	8	140°	95°	
		11:30	31	13	8.0	11.02	—	10	2124	19	140°	100°	
TUESDAY	4/26	7:00	31	13	10.6	10.98	—	10	2609	26	140°	105°	500 start
		3:00	30	13	9.2	10.46	—	—	3652	10	140°	105°	← forgot to Reset
		11:30	29	12	11.8	11.01	—	10	4487	19	140°	105°	
WEDNESDAY	4/27	7:00	29	10	8.5	10.75	—	10	2203 / 4812	22	140°	105°	forgot to Reset
		3:00	29	10	11.5	9.81	—		1223 / 6035	6	130°	105°	
		11:30	28	9	7.5	10.71	—	10	6886	13	115°	100°	Reseted boiler.
THURSDAY	4/28	7:00	28	9	11.7	10.11	—	—	2625 / 7437	16	145°	105°	Emptied Pac-Press.
		3:00	27	8	12.2	9.75	—	—	647	8	140°	105°	
		11:30	26	7	9.8	10.76	—	10	1603	12	140°	105°	
FRIDAY	4/29	7:00	26	7	12.2	9.12	—	—	1876	24	150°	105°	cleaned sump 5:00 start
		3:00	25	6	8.4	11.97	—	—	952	2	135°	105°	
		11:30	25	5	11.1	11.58	—	10	1730	10	140°	105°	
SATURDAY													
SUNDAY													

48x2 = 2609 − 2203

6035 − 4812 = 1223

7437 − 4812 = 2625

2369

AKC-0013309