REF. DWG NO. 500-0007

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP °F LARGE TANK	TEMP °F SMALL TANK	COMMENTS, PROBLEMS, & REMARKS
MONDAY	11/29	7:00	08	15	11.2	9.96	–	10	1483	37	100°	80°	
		3:00	7	14	7.7	9.99	–	–	2186	19	110°	90°	
		11:30	5	13	10.8	9.91	–	9	3008	32	115°	100°	
TUESDAY	11/30	7:00	5	13	10.8	9.95	–	10	3008	40	115°	105°	Press Emptied
		3:00	4	12	11.3	10.4	–	10	4332	17	120	115	Forgot to Reset 5762,
		11:30	2	12	8.7	10.11	–	9	5547	37	120°	120°	
WEDNESDAY	12/1	7:00	33	12	7.8	10.26	–	10	2762	42	120°	120°	Added Caustic
		3:00	32	10	11.4	10.71	–	10	2217	12	120	120	
		11:30	30	10	9.3	10.23	–	10	3745	34	125°	125°	
THURSDAY	12/2	7:00	30	10	[illegible]	10.23	–	10		38	125°	125°	PAC Press emptied Low water tripped.
		3:00	29	10	7.8	11.04	–	9	894	7	115°	115°	
		11:30	27	9	8.2	10.87	–	10	1751	26	120°	115°	
FRIDAY	12/3	7:00	27	8	12.2	10.82	–	11	2451	27	130°	120°	
		3:00	26	7	9.5	10.6	–	10	1247	9	125	125	
		11:30	25	6	9.9	10.6	–	10	1955	25	130°	125°	
SATURDAY													
SUNDAY													

AKC-0013399

REF. DWG NO. 500-0007

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP °F LARGE TANK	TEMP °F SMALL TANK	COMMENTS, PROBLEMS, & REMARKS
MONDAY	12/6	7:00	24	7	7.7	10.32	—	10	2448	27	120°	115°	Press Emptied
		3:00	23	4	8.3	10.24	—	10	443	17	105°	100°	Cleaned & calibrated probe process
		11:30	21	4	11.4	10.38	—	10	443	54	100°	100°	Low water tripped.
TUESDAY	12/7	7:00	21	4	12.2	10.40	—	10	2467	37?	125°	100°	[illegible]
		3:00	20	15	8.2	10.41	—	—	120	10	125°	110°	
		11:30	18	15	10.3	10.36	—	9	1809	27	130°	115°	
WEDNESDAY	12/8	7:00	18	13	10.1	10.31	—	10	1925	30	130°	125°	Emptied Pac-Press and washed screens.
		3:00	17	12	10.3	10.20	—	—	1237	41?	130°	130°	
		11:30	16	11	8.2	10.20	—	10	2738	52	130°	120°	
THURSDAY	12/9	7:00	16	11	9.4	10.21	—	10	3158	55	140	125°	
		3:00	14	10	9.0	10.20	—	—	1173	15	145°	120°	
		11:30	14	9	8.1	10.20	—	10	2297	25	145°	120°	
FRIDAY	12/10	7:00	13	9	9.8	10.18	—	10	2665	26	150°	125°	
		3:00	12	8	11.2	10.11	—	—	1066	12	140	120	
		11:30	11	7	8.0	10.19	—	9	2360	33	140°	120°	
SATURDAY													
SUNDAY													

AKC-0013400

REF. DWG NO. 500-0007

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP °F LARGE TANK	TEMP °F SMALL TANK	COMMENTS, PROBLEMS, & REMARKS
MONDAY	12/13	7:00	10	7	8.8	10.03	–	10	2743	37	150°	125°	
		3:00	10	7	7.6	10.00	–	–	1502	13	145°	120°	
		11:30	8	7	10.9	9.99	–	10	2324	27	140°	120°	
TUESDAY	12/14	7:00	8	7	9.7	9.97	–	10	2995	29	150°	120°	~~Emptied Pac-Press~~
		3:00	7	5	8.9	9.96	–	–	1223	14	150°	115°	Probe Problems
		11:30	3	5	10.0	9.91	–	10	2116	52	140	125°	
WEDNESDAY	12/15	7:00	3	5	10.0	9.51	–	10	2116	52	140°	125°	Boiler Switch Stuck (WAHR) Stuck
		3:00	3	4	11.3	10.29	–	–	1865	7	140°	120°	Emptied Pac-Press.
		11:30	1	3	7.9	10.31	–	10	2976	22	130°	110°	
THURSDAY	12/16	7:00	1	3	8.5	10.56	–	10	3272	25	150°	105°	Added Caustic
		3:00	29	29?	10.9	10.51	–	+	1761	11	150	100	Added floc
		11:30	28	14	10.9	10.25	–	10	2808	22	140°	100°	
FRIDAY	12/17	7:00	28	14	11.5	9.42	–	–	2896	23	150°	100°	
		3:00	27	13	8.9	11.54	–	–	1751	17	130°	100°	
		11:30	26	11	11.7	10.97	–	10	2981	28	125	95	
SATURDAY													
SUNDAY													

AKC-0013401

REF. DWG NO. 500-0007

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP °F LARGE TANK	TEMP °F SMALL TANK	COMMENTS, PROBLEMS, & REMARKS
MONDAY	12/20	7:00	25	13	10.4	10.65	—	10.	3064	29	130°	115°	Emptied Pac-Press.
		3:00	25	12	11.3	11.49	—	—	4968	39	130°	120°	
		11:30	23	12	11.7	11.19	—	10-	5884	59	130°	115°	
TUESDAY	12/21	7:00	23	11	8.3	10.92	—	11-	6155 / 3091	30	130°	115°	
		3:00	22	10	11.0	10.70	—	—	1112	10	130°	110°	
		11:30	21	10	8.2	10.71	—	10	2742	31	130°	105°	
WEDNESDAY	12/22	7:00	20	9	9.7	10.64	—	10	919	32	130°	100°	Boiler shutdown for repairs. note drop in temp
		3:00	19	7	11.1	10.93	—	10	892	12	120°	95°	
		11:30	18	7	10.1	10.87	—	10	1555	35	105°	90°	Transfer pump doesn't work on auto. (hand only).
THURSDAY	12/23	7:00	18	7	10.4	10.66	—	10	1853	39	100°	90°	
		3:00	17	7	10.3	9.68	—	—	426	2	100°	85°	
		11:30											
FRIDAY		7:00											
		3:00											Holiday
		11:30											Not for you.
SATURDAY													
SUNDAY													

AKC-0013402

REF. DWG NO. 500-0007

DAILY LOG

DAY	DATE	TIME	CAUSTIC LEVEL	FLOC LEVEL	pH READING PROCESS MONITOR	pH READING OUTPUT MONITOR	pH PAPER PROCESS MONITOR	pH PAPER OUTPUT MONITOR	FLOWMETER	CYCLES	TEMP °F LARGE TANK	TEMP °F SMALL TANK	COMMENTS, PROBLEMS, & REMARKS
MONDAY	12/27	7:00	16	5	ERR	9.72	—	10	1966	19	80°	70°	Probe failure (H_2O inside & broken wire) Boiler problems
		3:00	16	5	8.1	9.75	—	—	59	5	115°	80°	
		11:30	14	4	11.1	10.01	—	10	1899	26	110°	80°	
TUESDAY	12/28	7:00	14	4	12.1	10.05	—	10	2281	29	110°	80°	
		3:00											
		11:30	15	3	8.1	12.26	—	10	3052	25	120°	85°	
WEDNESDAY	12/29	7:00	14	2	7.7	11.14	—		3052	26	130°	95°	
		3:00	14	15	13.0	10.83	—	—	2345 ?	35	130°	100°	
		11:30	13	13	9.7	10.03	—	10	3398	49	130°	100°	
THURSDAY	12/30	7:00	13	13	8.6	9.84	—	10	3398	49	130°	110°	Emptied PAC Press
		3:00	13	13	12.3	10.10	—	—	4475	12	130°	110°	
		11:30	11	12	9.7	10.68	—	10	5718	31	130°	110°	
FRIDAY	12/31	7:00											Holiday
		3:00											
		11:30											
SATURDAY													
SUNDAY													

7884
3398
2426

AKC-0013403